

Data & Information Needs

Name of Requester	Data & Information Need	Due Date	Initial Assigned To
Nicole Williams	Chapter 2 and Chapter 5: Confirm emergency release rates would for TRR West would be the same as TRR East (i.e., 7 000 cfs). Confirm no adjustments to Funks Reservoir would be needed associated with construction/operation of TRR West.	04/23/21	Peter Rude

115

Reassigned To	Status	Done
		<input type="checkbox"/>

Comments/Response to Data & Information Needs

Pete Rude = Emergency release rates of 7,000 cfs for TRR West are more complicated than TRR East, since TRR West is not adjacent to Funks Creek. Preliminary flood inundation modeling for emergency release shows that the area between TRR West and Funks Creek will be flooded. Therefore the 7,000 cfs for TRR West will overspill its banks at the inlet/outlet canal and flow south overland to Funks Creek. No additional facilities are proposed to handle the emergency flow of water out of TRR West. There will be no additional changes to Funks Reservoir with construction/operation of TRR West then for TRR East.