

## 21.1 Environmental Setting/Affected Environment

The section describes potential effects to these energy resources from construction and operation of the action alternatives in the study area (the area in which impacts may occur). The study area consists of the Plan Area (the area covered by the BDCP), which is largely formed by the statutory borders of the Delta, along with areas in Suisun Marsh and the Yolo Bypass; and the Areas of Additional Analysis (see Chapter 3, *Description of Alternatives*, Section 3.3.1). New water conveyance facilities associated with BDCP would be constructed, owned, and operated as a component of the State Water Project (SWP). While additional power used to move water through the new BDCP facilities would be procured by DWR, the pumping requirements are directly linked to the SWP and Central Valley Project (CVP) exports and the monthly water supply deliveries to the various SWP and CVP contractors. Accordingly, this section discussed the energy generation at the SWP and CVP hydropower facilities and the energy use for pumping water supplies into the various canals and tunnels in the water conveyance and distribution systems.

This chapter evaluates the energy demand for each BDCP alternative relative to Existing Conditions (for CEQA) and No Action Alternative (for NEPA). Existing Conditions (also referred to as *CEQA Baseline*) is defined as installed SWP and CVP capacity in 2010. The No Action Alternative (also referred to as the *NEPA point of comparison*) is defined as future SWP and CVP capacity in 2060 independent of BDCP actions. The difference in energy demand between each BDCP alternative and the No Action Alternative represents the net impact of the project under 2060 conditions. The difference in energy demand between each BDCP alternative and the CEQA baseline represents net impact of the project, relative to Existing Conditions (2010).

Historic CVP and SWP energy generation and use provide the energy context for evaluating the additional energy requirements for the BDCP alternatives. Energy effects are evaluated as the additional pumping energy requirements for the BDCP alternatives and the additional energy for pumping increased Delta exports for some of the BDCP alternatives. The BDCP alternatives may cause upstream reservoir operations changes that could alter the hydropower generation in some months or alter the pumping at existing facilities in other months. These changes could increase the net energy gap between the CVP and SWP hydropower generation and the pumping energy uses.

Hydropower energy generation is a major project purpose for the CVP and SWP. Hydropower energy has always been an important part of the benefits and financing of state, federal, and private water resources developments in California. The runoff from the Sierra Nevada and Cascade mountains provided a great potential for hydropower development, which has now been harnessed to pump water supplies into the CVP and SWP canals, San Luis Reservoir, and water distribution systems. Some additional energy is used for groundwater pumping for CVP and SWP contractors when surface water supplies are limited in dry years.

Additional pumping and Delta export energy requirements for the BDCP alternatives is simulated using the CALSIM model (version II). It is important to note that given the inherent complexity of the SWP, CVP, and Delta operation, planning tools such as CALSIM-II may not produce the same operational patterns, energy demand and generation profiles that have been observed in recent

1 years. The ever changing regulatory environment that the SWP and CVP projects operate under is a  
2 challenge for planning tools, such as CALSIM-II. Energy calculations based on CALSIM-II represent a  
3 reasonable, though overstated, scenario based on historic monthly flows and reservoir storage.  
4 Additional details on CALSIM-II are provided in Section 21.1.3.1, *CVP and SWP Energy Generation*.

5 Understanding the energy evaluation will be easier with a brief introduction to some basic energy  
6 units. The basic units of electrical power (capacity) are kilowatt (kW), megawatt (MW), and gigawatt  
7 (GW). A megawatt is 1,000 kW, and a gigawatt is 1,000,000 kW or 1,000 MW. It is common for  
8 energy to be reported as the power supplied or consumed over a unit of time. For instance,  
9 generating electricity at the rate of 1 kW for 1 hour is a kilowatt hour (kWh). A 100 MW (100,000  
10 kW) generating facility would produce 2,400,000 kWh (2,400 megawatt hours (MWh) or 2.4  
11 gigawatt hours [GWh]) in a day.

### 12 **21.1.1 CVP Hydropower Generation and Pumping Facilities**

13 The Bureau of Reclamation (Reclamation) planned, constructed, financed, and operates the CVP  
14 energy-producing facilities. Western is within the Department of Energy (DOE) and is responsible  
15 for providing transmission/distribution services and marketing excess energy produced by CVP  
16 facilities. Western is one of four national power marketing administrations that sells and transmits  
17 power generated by federal hydroelectric facilities (Western Area Power Administration 2009).

18 The amount of water released from CVP reservoirs controls the CVP energy generation each year.  
19 The CVP energy use for pumping water south of the Delta depends on the CVP pumping from the  
20 Delta and seasonal storage in San Luis Reservoir. On an annual basis CVP hydropower plants have  
21 historically generated energy in excess of the amount needed to pump CVP water, thus allowing  
22 Western to sell this excess energy to other electric utilities, municipalities, industrial customers, and  
23 other identified Preference Power Customers. Preference Power Customers are publicly owned  
24 systems and/or nonprofit cooperatives that are given preference by law over investor-owned  
25 utilities to receive power generated by federal projects (Bureau of Reclamation 2009). Western  
26 primarily markets power using long-term firm power contracts. When CVP generation is not  
27 sufficient to cover CVP pumping requirements on a daily basis, Western purchases needed  
28 electricity from other sources.

29 CVP hydropower and pumping facilities are discussed in the following sections. Table 21-1 shows  
30 energy generation and flow parameters; Table 21-2 shows pumping capacities and energy  
31 requirements of these facilities. Energy generation at the reservoir power plants and pumping  
32 energy at the Gianelli pumping plant depend on the reservoir storages (i.e., elevations) that controls  
33 the water heads (feet).

1 **Table 21-1. CVP Hydropower Generation Capacity of Facilities**

| Facility                                 | Water Head (feet) |     | Max Flow (cfs) | Max Volume (af/day) | Capacity (MW) | Max Generation (MWh) | Generator Efficiency | Energy Factor (kWh/af) |
|--|-------------------|-----|----------------|---------------------|---------------|----------------------|----------------------|------------------------|
|  | Min               | Max |                |                     |               |                      |                      |                        |
| Trinity Dam and Powerplant               | 245               | 470 | 4,200          | 8,400               | 140           | 3,360                | 0.85                 | 400                    |
| J. F. Carr Powerplant                    | 692               | 712 | 3,300          | 6,600               | 160           | 3,840                | 0.82                 | 582                    |
| Spring Creek Powerplant                  | 602               | 636 | 4,200          | 8,400               | 190           | 4,560                | 0.85                 | 543                    |
| Shasta Dam and Powerplant                | 260               | 487 | 18,000         | 36,000              | 710           | 17,040               | 0.97                 | 473                    |
| Keswick Dam and Powerplant               | 74                | 87  | 15,000         | 30,000              | 105           | 2,520                | 0.97                 | 84                     |
| Folsom Dam and Powerplant                | 197               | 336 | 8,000          | 16,000              | 210           | 5,040                | 0.94                 | 315                    |
| Nimbus Dam and Powerplant                | 38                | 45  | 4,500          | 9,000               | 15            | 360                  | 0.89                 | 40                     |
| New Melones Dam and Powerplant           | 200               | 480 | 10,000         | 20,000              | 380           | 9,120                | 0.95                 | 456                    |
| Gianelli Pumping-Generating Plant        | 100               | 320 | 16,000         | 32,000              | 400           | 9,600                | 0.94                 | 300                    |
| O'Neill Dam and Pumping-Generating Plant | 45                | 53  | 6,000          | 12,000              | 25            | 600                  | 0.94                 | 50                     |

af=acre-feet  
cfs=cubic feet per second

2

3 **Table 21-2. CVP Pumping Capacity of Facilities**

| Pumping Plant                     | Pumping Head (feet) |     | Max Flow (cfs) | Max Volume (af/day) | Capacity (hp) | Capacity (MVA) | Efficiency | Energy Factor (kWh/af) |
|-----------------------------------|---------------------|-----|----------------|---------------------|---------------|----------------|------------|------------------------|
|                                   | Min                 | Max |                |                     |               |                |            |                        |
| Red Bluff (under Construction)    |                     | 25  | 2,500          | 5,000               | 8,000         | 6              | 0.87       | 29                     |
| C. W. "Bill" Jones                |                     | 197 | 5,000          | 10,000              | 140,000       | 105            | 0.78       | 252                    |
| O'Neill Pumping-Generating Plant  | 45                  | 53  | 4,200          | 8,400               | 36,000        | 27             | 0.69       | 77                     |
| Gianelli Pumping-Generating Plant | 100                 | 320 | 11,000         | 22,000              | 504,000       | 378            | 0.78       | 412                    |

af=acre-feet  
cfs=cubic feet per second  
hp=horsepower  
MVA=megavolt ampere

4

### 1 **21.1.1.1 Trinity River and Sacramento River Facilities**

2 The Trinity River Division includes the Trinity Dam and Powerplant, the Lewiston Dam and  
3 Powerplant, the Judge Francis Carr Powerplant, and the Spring Creek Powerplant. The Trinity Dam  
4 and Powerplant were completed in 1962 with a maximum water storage capacity of 2,450 thousand  
5 acre-feet (TAF) (Bureau of Reclamation 2012). Trinity Powerplant has a capacity of 140 MW with a  
6 maximum water head of 470 feet at full storage of 2,450 TAF. The minimum head is about 245 feet  
7 at the minimum storage for power generation of about 325 TAF. The maximum flow through the  
8 penstocks is about 4,200 cubic feet per second (cfs) at full storage. With an assumed  
9 turbine/generator efficiency of 85%, the energy generation factor (kilowatt hours per acre-foot  
10 [kWh/af]) is 400 kWh/af at maximum storage and is about 200 kWh/af at minimum storage. (The  
11 energy generation factor is approximately the water head multiplied by the turbine/generator  
12 efficiency.)

13 Lewiston Dam and Powerplant are 7 miles downstream of Trinity Dam. Lewiston Powerplant began  
14 operation in 1964 and has one generating unit with a capacity of 500 kW (Bureau of Reclamation  
15 2012). Lewiston Powerplant generates electricity for the plant itself and the local fish hatchery, but  
16 does not generate much additional CVP power.

17 J. F. Carr Powerplant receives water from Lewiston Lake through the Clear Creek Tunnel and is  
18 located at the upstream end of Whiskeytown Lake. Operation began in 1963, and the two generating  
19 units were upgraded in 1984 to the current capacity of about 160 MW (Bureau of Reclamation  
20 2012). The Carr Powerplant was designed to allow full diversions from the Trinity River. The Trinity  
21 Restoration Program in 2002 increased the Trinity River flows and reduced the average diversion  
22 from 1,000 TAF per year (TAF/yr) to about 500 TAF/yr. This reduced the average flow through the  
23 Carr Powerplant and the Spring Creek Powerplant by about 500 TAF/yr. The maximum water head  
24 is about 712 feet, with a maximum turbine flow of 3,300 cfs. The energy generation factor is about  
25 582 kWh/af with an efficiency of 82%.

26 Spring Creek Powerplant, built in 1964, receives water from Whiskeytown Lake through the Spring  
27 Creek Tunnel and discharges water to Keswick Reservoir. The current capacity is 190 MW (Bureau  
28 of Reclamation 2012). The maximum water head is about 636 feet, with a maximum turbine flow of  
29 4,200 cfs. The energy generation factor is about 543 kWh/af with an efficiency of 85%.

30 The Shasta Division consists of Shasta Dam and Powerplant and Keswick Dam and Powerplant.  
31 Construction of these CVP facilities began in 1938 and was completed in 1945. Shasta Powerplant  
32 has five generating units (and two station units). The Shasta Temperature Curtain was constructed  
33 (completed in 1997) to allow low-level releases for temperature control to be made without  
34 bypassing the power outlets. This allows energy generation year-round while still providing the  
35 coolest possible water temperatures below Keswick Dam. The current capacity of Shasta is 710 MW  
36 (Bureau of Reclamation 2012). The maximum water head is about 487 feet at maximum storage and  
37 is about 260 feet at minimum storage. The maximum flow rate is 18,000 cfs with an energy factor of  
38 about 473 kWh/af and an efficiency of about 97%.

39 Keswick Dam and Powerplant are located downstream of the Shasta Dam on the Sacramento River.  
40 The dam regulates peaking power releases from Shasta Dam to provide a constant release from  
41 Keswick Dam to the Sacramento River. Keswick Powerplant has three generating units with a  
42 combined capacity of 105 MW (Bureau of Reclamation 2012). The water head varies from about 74  
43 feet to 87 feet (less head at high discharge). The maximum turbine flow is about 15,000 cfs with an  
44 energy factor of about 84 kWh/af and an efficiency of about 97%.

1 The Sacramento River Division includes the Red Bluff Diversion Dam, Corning Pumping Plant, and  
2 Corning and Tehama-Colusa Canals, but no facilities for the generation of electricity. The Corning  
3 Pumping Plant uses electricity and the new Red Bluff Pumping Plant (under construction) that will  
4 divert water into the Tehama-Colusa Canal (without lowering the Red Bluff diversion Dam gates)  
5 will use energy in the near future. The Corning Pumping Plant has six pumping units with a  
6 combined capacity of about 32 MW. The pumping head is about 70 feet and the flow is about 425 cfs  
7 with an efficiency of 85% and a pumping energy factor of about 85 kWh/af.

#### 8 **21.1.1.2 American River Facilities**

9 The American River Division includes Folsom Dam and Powerplant, Nimbus Dam and Powerplant,  
10 Folsom Pumping Plant, and the Folsom South Canal. The Folsom Powerplant consists of three  
11 generating units with an installed capacity of 210 MW (Bureau of Reclamation 2012). The maximum  
12 water head at the Folsom Powerplant is about 336 feet at maximum storage with a maximum flow of  
13 8,000 cfs with an energy factor of 315 kWh/af and an efficiency of 94%. The Folsom Pumping Plant  
14 supplies local domestic water supplies. The Nimbus Powerplant has two generating units with a  
15 capacity of about 15 MW. The maximum water head is 45 feet and the maximum flow is 4,500 cfs  
16 with an energy factor of about 40 kWh/af and an efficiency of 89%.

#### 17 **21.1.1.3 Stanislaus River Facilities**

18 The New Melones Dam and Powerplant are on the Stanislaus River. New Melones Reservoir has a  
19 water storage capacity of 2.4 million acre-feet at a maximum pool elevation of 1,088 feet. The New  
20 Melones Powerplant has two generators with a capacity of 380 MW. The maximum water head is  
21 about 480 feet and the maximum turbine flow is about 10,000 cfs with an energy factor of about 456  
22 kWh/af and an efficiency of 95%.

#### 23 **21.1.1.4 CVP Delta-Mendota Canal Facilities**

24 The C. W. "Bill" Jones Pumping Plant is north of the city of Tracy and consists of six pumps. The  
25 pumps are each rated at 22,500 horsepower (hp) (16.7 MW), for a maximum energy requirement  
26 (capacity) of about 100 MW. The pumping plant has a maximum water head of about 197 feet and a  
27 maximum flow of about 5,000 cfs. The pumping efficiency is about 78% and the pumping energy  
28 factor is about 252 kWh/af. (Bureau of Reclamation 2012). Water from the Jones pumping plant  
29 flows into the Delta-Mendota Canal. The Contra Costa Water District (CCWD) diverts CVP water  
30 from the Delta for municipal and industrial and irrigation purposes. The Rock Slough Pumping Plant  
31 and the Contra Costa Canal were built as part of the CVP, but the pumping plant is now operated by  
32 CCWD.

33 The California Aqueduct/ Delta-Mendota Canal Intertie (Intertie) is currently being constructed to  
34 pump water from the Delta-Mendota Canal to the California Aqueduct (Bureau of Reclamation  
35 2012). The Intertie Pumping Plant with a capacity of about 400 cfs will allow the Jones Pumping  
36 Plant to operate at full authorized pumping capacity of 5,000 cfs year-round. The lower Delta-  
37 Mendota Canal capacity of 4,200 cfs limits the Jones pumping in the winter when no water deliveries  
38 are being made. The pumping head will be about 50 feet and the energy requirement will be 2 MW  
39 (Bureau of Reclamation 2012). The Intertie will be completed in 2012. The O'Neill Dam and  
40 Pumping-Generating Plant are at the convergence of the O'Neill Forebay and the Delta-Mendota  
41 Canal. The dam was completed in 1967. The O'Neill Pumping-Generating Plant utilizes six pumping  
42 units to lift water about 53 feet (depending on the surface height of the water) from the Delta-

1 Mendota Canal to the O’Neill Forebay. The pumping units have a maximum flow of 4,200 cfs and  
2 require about 2.4 MW of energy capacity. When water is released to the Delta-Mendota Canal, the six  
3 units have a maximum flow of about 1,000 cfs and generate 25 MW (Bureau of Reclamation 2012).

4 The Gianelli Pumping-Generating Plant was constructed as a joint CVP-SWP facility between O’Neill  
5 Forebay and San Luis Reservoir. The pumping head ranges from a minimum of 100 feet at minimum  
6 storage in San Luis Reservoir to about 320 feet at maximum storage. The plant has eight pumping-  
7 generating units that can pump a maximum of 11,000 cfs with a pumping energy factor of 412  
8 kWh/af, with an efficiency of about 78% and an energy requirement of 380 MW. When releasing a  
9 maximum flow of 16,000 cfs from San Luis Reservoir to O’Neill Forebay, the 8 units generate a  
10 maximum of 400 MW with an energy factor of about 300 kWh/af and an efficiency of about 95%.  
11 Because the Gianelli Pumping-Generating Plant is a joint SWP and CVP facility, the water pumped or  
12 released by each agency determines the energy supplied or energy generated by each agency  
13 (Bureau of Reclamation 2012).

## 14 **21.1.2 SWP Hydropower Generation and Pumping Facilities**

15 The SWP is one of the largest water and power systems in the world. Hydroelectric and natural gas  
16 facilities, along with contractual arrangements, are the major power sources of SWP power  
17 operations. The multipurpose nature of the SWP affects how its facilities are operated. Most times,  
18 the top operational priority is to maximize water deliveries to State Water Contractors, within the  
19 scope of regulatory requirements. The SWP was designed and built with other important purposes  
20 in mind, including flood control, hydroelectric power generation, protection of fish and wildlife and  
21 recreation. The basic operational tools used by DWR to accomplish SWP goals have been to increase  
22 or decrease upstream water releases, change Delta pumping rates and store water conveyed  
23 through the Delta at San Luis Reservoir. For a more detailed discussion of SWP operations, refer to  
24 Section 5.1.2, *SWP and CVP Facilities and Operations* in Chapter 5, *Water Supply*.

25 SWP operations, especially Delta export pumping, are closely coordinated with those of the larger  
26 federal CVP (see Section 21.1.1). The pumping plants of both systems are located in the same area of  
27 the South Delta. Their aqueduct operations are also coordinated, as are storage and pumping at San  
28 Luis Reservoir, a key facility serving both systems. For more detail on the coordinated operations of  
29 CVP and SWP, see Section 5.1.2.3, *SWP/CVP Coordinated Facilities and Operations in Chapter 5, Water  
30 Supply*.

31 Table 21-3 and Table 21-4 provide a snapshot into the SWP 2001–2010 pumping and generating  
32 operations.

1 **Table 21-3. SWP Pump Load, SWP Hydro Generation (including Castaic), and SWP Water Deliveries**

| Parameter                          | 2001      | 2002      | 2003      | 2004      | 2005      | 2006      | 2007      | 2008      | 2009      | 2010      |
|------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Total Pump Load (GWh)              | 6,568     | 8,276     | 8,912     | 9,801     | 8,289     | 9,114     | 9,291     | 5,707     | 5,444     | 7,225     |
| Total Generation (GWh)             | 3,167     | 4,090     | 4,599     | 5,282     | 4,083     | 5,978     | 4,913     | 2,813     | 3,031     | 3,480     |
| Water (Acre-feet)                  | 1,534,263 | 2,564,857 | 2,890,215 | 2,594,999 | 2,826,210 | 2,971,851 | 2,081,217 | 1,234,240 | 1,232,753 | 1,930,929 |
| Total Water Deliveries (Acre-feet) | 3,193,771 | 4,009,873 | 4,168,151 | 4,328,460 | 4,726,363 | 4,827,082 | 4,061,696 | 2,838,128 | 2,915,435 | 3,502,986 |

2

3 **Table 21-4. Hyatt-Thermalito Generation (Monthly)**

| YEAR | Jan    | Feb    | Mar    | Apr    | May    | Jun    | Jul    | Aug    | Sep    | Oct    | Nov    | Dec    | Total for Year |
|------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|----------------|
| 2001 | 97.98  | 57.22  | 79.77  | 78.29  | 192.98 | 162.10 | 149.27 | 139.14 | 55.69  | 89.33  | 63.77  | 69.15  | 1,235          |
| 2002 | 54.06  | 27.76  | 43.08  | 78.70  | 155.01 | 218.52 | 307.66 | 222.95 | 121.50 | 102.66 | 71.77  | 81.97  | 1,486          |
| 2003 | 58.89  | 161.48 | 49.90  | 44.26  | 153.03 | 226.40 | 483.35 | 317.10 | 171.80 | 114.59 | 140.79 | 111.89 | 2,033          |
| 2004 | 95.32  | 155.12 | 235.37 | 257.63 | 172.53 | 261.17 | 374.85 | 296.46 | 124.04 | 111.09 | 108.60 | 101.40 | 2,294          |
| 2005 | 67.25  | 37.04  | 54.21  | 39.80  | 152.66 | 224.19 | 258.22 | 253.03 | 192.07 | 158.69 | 155.75 | 240.64 | 1,834          |
| 2006 | 401.36 | 263.32 | 480.71 | 518.53 | 435.88 | 265.87 | 259.89 | 266.94 | 193.04 | 139.52 | 163.05 | 122.69 | 3,511          |
| 2007 | 111.78 | 102.26 | 139.29 | 162.56 | 172.93 | 253.08 | 336.03 | 270.96 | 176.16 | 122.62 | 144.29 | 84.89  | 2,077          |
| 2008 | 43.96  | 39.18  | 27.43  | 117.73 | 126.14 | 174.43 | 142.01 | 121.72 | 57.62  | 46.72  | 48.32  | 56.00  | 1,001          |
| 2009 | 38.60  | 18.38  | 12.18  | 143.24 | 153.24 | 201.49 | 348.92 | 155.96 | 73.74  | 90.01  | 120.60 | 93.61  | 1,450          |
| 2010 | 46.14  | 30.12  | 41.37  | 14.71  | 99.70  | 122.41 | 307.05 | 309.12 | 238.19 | 114.37 | 125.46 | 74.96  | 1,524          |

4

5 From a power resourcing perspective, SWP has a diversified portfolio of resources to meet its  
6 annual pumping requirements. In Figure 21-1, the distribution of resources used to meet the load  
7 requirements in 2010 is shown. Nearly sixty-percent of the 2010 load was met with hydro resources  
8 including SWP system resources (Hyatt-Thermalito, Gianelli, and Warne, and Devil Canyon), long-  
9 term contract hydropower at Pine Flat and Castaic reservoirs, small hydro resources (Alamo, Mojave  
10 Siphon, and contract small hydro) as well as coal power from the RG4 facility, and the balance of  
11 SWP pumping needs met with short- and mid-term contract power purchases and daily and real-  
12 time purchases from the California Independent System Operator's (CAISO) energy market.

13 As DWR resources for future SWP delivery requirements, it will pursue cleaner resources to reduce  
14 SWP greenhouse gas emissions as outlined in DWR's Climate Action Plan-Phase I: Greenhouse Gas  
15 Emissions Reduction Plan (see Chapter 22, *Air Quality and Greenhouse Gas Emissions*, Section  
16 22.3.2.3, for additional details on the CAP). The 2020 portfolio (Figure 21-2) will be comprised of a  
17 portion of the Lodi Energy Center combined cycle power plant, and new renewable energy  
18 resources.

19 SWP hydropower and pumping facilities are discussed in the following sections. Refer to Table 21-3  
20 for energy generation and flow parameters and Table 21-4 for pumping capacities and energy  
21 requirements during the discussion of these facilities. Energy generation at the Hyatt powerplant

1 and energy required at the Gianelli pumping plant depend on the reservoir storages (i.e., elevations)  
 2 that controls the water heads (feet). Refer to Table 21-5 for energy generation and flow parameters  
 3 and Table 21-6 for pumping capacities and energy requirements during the discussion of these  
 4 facilities. Energy generation at the Hyatt powerplant and energy required at the Gianelli pumping  
 5 plant depends on the reservoir storages (i.e., elevations) that controls the water heads (feet).

6 **Table 21-5. SWP Hydropower Generation Capacity of Facilities**

| Facility                            | Water Head (feet) |       | Max Flow (cfs) | Max Volume (af/day) | Capacity (MW) | Generator Efficiency | Energy Factor (kWh/af) |
|-------------------------------------|-------------------|-------|----------------|---------------------|---------------|----------------------|------------------------|
|                                     | Min               | Max   |                |                     |               |                      |                        |
| Edward Hyatt Powerplant (Oroville)  | 410               | 676   | 16,950         | 33,620              | 819           | 0.86                 | 585                    |
| Thermalito Pumping-Generating Plant | 85                | 102   | 17,400         | 34,513              | 120           | 0.82                 | 83                     |
| Thermalito-Low Flow                 | 63                | 77    | 615            | 1,220               | 3             | 0.84                 | 65                     |
| Warne                               | 719               | 739   | 1,565          | 3,104               | 74            | 0.77                 | 572                    |
| Alamo                               | 115               | 141   | 1,740          | 3,451               | 17            | 0.84                 | 118                    |
| Mojave                              | 81                | 136   | 2,880          | 5,712               | 32            | 1.00                 | 136                    |
| Devil Canyon                        |                   | 1,406 | 2,940          | 5,831               | 280           | 0.82                 | 1,152                  |

7

8 **Table 21-6. SWP Pumping Capacity of Facilities**

| Pumping Plant                       | Pumping Head (feet) |       | Max Flow (cfs) | Max Volume (af/day) | Capacity (hp) | Capacity (MVA) | Efficiency | Energy Factor (kWh/af) |
|-------------------------------------|---------------------|-------|----------------|---------------------|---------------|----------------|------------|------------------------|
|                                     | Min                 | Max   |                |                     |               |                |            |                        |
| Hyatt Powerplant (Oroville)         | 500                 | 660   | 5,610          | 11,127              | 519,000       | 387            | 0.79       | 835                    |
| Thermalito Pumping-Generating Plant | 85                  | 100   | 9,120          | 18,090              | 120,000       | 89             | 0.84       | 119                    |
| Harvey O. Banks                     | 236                 | 252   | 10,670         | 21,164              | 330,000       | 246            | 0.90       | 279                    |
| South Bay                           |                     | 566   | 330            | 655                 | 27,750        | 21             | 0.75       | 759                    |
| Del Valle                           |                     | 38    | 120            | 238                 | 1,000         | 1              | 0.51       | 75                     |
| Dos Amigos                          | 107                 | 125   | 15,450         | 30,645              | 240,000       | 179            | 0.89       | 140                    |
| Las Perillas                        |                     | 55    | 461            | 914                 | 4,050         | 3              | 0.69       | 79                     |
| Badger Hill                         |                     | 151   | 500            | 992                 | 11,750        | 9              | 0.71       | 212                    |
| Devil's Den                         |                     | 521   | 134            | 266                 | 10,500        | 8              | 0.74       | 707                    |
| Bluestone                           |                     | 484   | 134            | 266                 | 10,500        | 8              | 0.68       | 707                    |
| Polonio Pass                        |                     | 533   | 134            | 266                 | 10,500        | 8              | 0.75       | 707                    |
| Buena Vista                         |                     | 205   | 5,405          | 10,721              | 144,500       | 108            | 0.85       | 241                    |
| John R. Teerink                     |                     | 233   | 5,445          | 10,800              | 150,000       | 112            | 0.94       | 249                    |
| Ira J. Chrisman Wind Gap            |                     | 518   | 4,995          | 9,908               | 330,000       | 246            | 0.87       | 596                    |
| A. D. Edmonston                     |                     | 1,926 | 4,480          | 8,886               | 1,120,000     | 835            | 0.85       | 2,256                  |
| Oso                                 |                     | 231   | 3,252          | 6,450               | 93,800        | 70             | 0.89       | 260                    |
| Pearblossom                         |                     | 540   | 2,575          | 5,108               | 203,200       | 152            | 0.76       | 712                    |

af=acre-feet

---

MVA= megavolt ampere

---

### 1    **21.1.2.1            Feather River Facilities**

2        The Oroville-Thermalito Complex includes Edward Hyatt Powerplant, Thermalito Diversion Dam  
3        and Powerplant, and the Thermalito Pumping-Generating Plant. Construction began in 1957 and the  
4        Oroville and Thermalito facilities became operational in 1968 (California Department of Water  
5        Resources 2009a, 2009b). Oroville Dam is the tallest dam in the United States, with a structural  
6        height of 770 feet with a crest elevation of 922 feet. Lake Oroville has a maximum storage capacity of  
7        3,537 TAF with a maximum water elevation of 900 feet (California Department of Water Resources  
8        2009a, 2009b). Table 21-6 gives the energy generation and flow parameters and the pumping  
9        capacities and energy requirements for each of the SWP facilities.

10       The Edward Hyatt Powerplant is an underground pumping-generating facility at the base of Oroville  
11       Dam that generates power from water released from the dam and can pump water from Thermalito  
12       Forebay for pumped-storage operations (not used very often). The water head ranges from about  
13       410 feet at minimum operating storage to about 676 feet at maximum storage. The maximum  
14       generation capacity for the Hyatt Powerplant is 819 MW with a maximum flow of about 16,950 cfs.  
15       The energy factor is about 585 kWh/af at maximum head and is about 350 kWh/af at minimum  
16       head, with an efficiency of about 86%. When pumping water from Thermalito Forebay, the pumping  
17       units have a capacity of about 5,610 cfs with a pumping energy factor of 835 kWh/af and a pumping  
18       efficiency of about 79%. The maximum energy requirement for this pumping is about 387 MW  
19       (California Department of Water Resources 2009b).

20       Thermalito Diversion Dam and Powerplant are approximately 4.5 miles downstream from Oroville  
21       Dam on the Feather River. The dam diverts water to the Thermalito Forebay Canal for use at the  
22       Thermalito Pumping-Generating Plant. The small Thermalito Diversion Dam Powerplant has one  
23       generating unit with a maximum flow of 615 cfs and a water head of 63–77 feet, generating a  
24       maximum of about 3 MW with an energy factor of about 65 kWh/af and an efficiency of about 85%.

25       The Thermalito Pumping-Generating Plant is about 4 miles west of Oroville. The Thermalito  
26       Powerplant has four units with a maximum flow 17,400 cfs and a maximum water head of about 102  
27       feet with a maximum energy requirement of 120 MW. The energy factor is about 83 kWh/af with an  
28       efficiency of about 82%. The pumping units lift water about 100 feet at a maximum flow of 9,120 cfs  
29       with a pumping energy factor of 119 kWh/af and a pumping efficiency of about 84%.

### 30    **21.1.2.2            SWP Delta Facilities**

31       The Harvey O. Banks Pumping Plant in the south Delta pumps water into the California Aqueduct  
32       (CA). The pumping plant utilizes 11 pumps; two are rated at 375 cfs capacity, five at 1,130 cfs  
33       capacity, and four at 1,067 cfs capacity. The plant lifts the water about 252 feet from the Clifton  
34       Court Forebay into the California Aqueduct. The maximum pumping capacity is about 10,670 cfs.  
35       The maximum energy requirement is about 246 MW. The pumping energy factor is about 279  
36       kWh/af with an efficiency of 90%. Pumping is scheduled to be at maximum capacity during off-peak  
37       hours each day; the Clifton Court Forebay storage capacity of about 10 TAF allows this basic  
38       operational strategy.

39       The Barker Slough Pumping Plant diverts water from Barker Slough into the North Bay Aqueduct for  
40       use by SWP contractors in Napa and Solano Counties. The current Barker Slough Pumping Plant  
41       capacity is about 150 cfs with an energy requirement of about 4 MW. The Cordelia Pumping Plant

1 has a capacity of about 130 cfs with an energy requirement of about 4 MW. The South Bay Pumping  
2 Plant is located near the Banks Pumping Plant and pumps water about 566 feet to the South Bay  
3 Aqueduct. The South Bay Pumping Plant has nine units with a maximum flow of 330 cfs. Four  
4 additional units are currently under construction (completed in 2012) with an additional capacity of  
5 180 cfs. The current energy requirement of 21 MW will therefore increase to 27 MW. The pumping  
6 energy factor is about 759 kWh/af with an efficiency of about 75% (California Department of Water  
7 Resources 2010).

### 8 **21.1.2.3 San Luis Reservoir and Canal Facilities**

9 The San Luis Unit was constructed in the 1960s and is jointly operated by DWR and Reclamation.  
10 The San Luis Reservoir has a maximum capacity of about 2,000 TAF (Bureau of Reclamation 2012).  
11 The William R. Gianelli Pumping-Generating Plant lifts water from the O'Neill Forebay to the San  
12 Luis Reservoir in the fall and winter months when water demands are reduced. San Luis Reservoir  
13 provides seasonal storage for CVP and SWP water. When water demands increase in the spring and  
14 summer months, water is released through the generating units to O'Neill Forebay and the San Luis  
15 Canal (part of the California Aqueduct). The plant energy factors have been described under the CVP  
16 facilities.

17 The Dos Amigos Pumping Plant is located along the San Luis Canal 17 miles south of the O'Neill  
18 Forebay. The Dos Amigos Pumping Plant lifts water approximately 125 feet. The pumping capacity is  
19 15,450 cfs with an energy requirement of about 179 MW. The pumping energy factor is 140 kWh/af  
20 and the pumping efficiency is about 89%. The Coastal Aqueduct connects to the California Aqueduct  
21 near Kettleman City, California, and delivers water to the Central Coast. Water is pumped through  
22 the Las Perillas, Badger Hill, Devil's Den, Bluestone, and Polonio Pass Pumping Plants. The Las  
23 Perillas Pumping Plant lifts water about 55 feet from the California Aqueduct to the first section of  
24 the coastal branch. The plant contains six pumping units with a capacity of about 461 cfs and an  
25 energy requirement of 3 MW. The Badger Hill Pumping Plant contains six pumping units that lift  
26 water 151 feet with a capacity of about 500 cfs and an energy requirement of 9 MW. Three pumping  
27 plants (Devil's Den, Bluestone and Polonio) lift water a total of 1,500 feet in a pipeline with a  
28 capacity of 130 cfs. The combined pumping energy requirement for these three plants is 24 MW. The  
29 pumping efficiency for these plants is about 75% with an energy factor of 2,000 kWh/af.

### 30 **21.1.2.4 California Aqueduct Facilities**

31 Some water is delivered to Kern County SWP contractors before reaching the Buena Vista Pumping  
32 Plant. All other water flowing to southern California SWP contractors must be lifted at several  
33 pumping plants over the Tehachapi Mountains. The Buena Vista Pumping Plant is about 24 miles  
34 southwest of Bakersfield. The plant contains ten pumping units with maximum capacity of 5,405 cfs  
35 that lift the water 205 feet. The energy requirement is about 108 MW with an energy factor of 241  
36 kWh/af and an efficiency of 85%. The John R. Teerink Pumping Plant contains nine units that lift a  
37 maximum of 5,445 cfs about 233 feet. The plant energy requirement is about 112 MW with an  
38 energy factor of 249 kWh/af with an efficiency of 94%. The Ira J. Chrisman Wind Gap Pumping Plant  
39 contains nine units that lift a maximum of 4,995 cfs about 518 feet. The plant energy requirement is  
40 about 246 MW with an energy factor of 596 kWh/af with an efficiency of 87%. The A. D. Edmonston  
41 Pumping Plant is the highest lift pumping plant in the United States, pumping water over the  
42 Tehachapi Mountains to Southern California. The plant contains 14 pumping units each with four-  
43 stage impellers. The plant lifts water 1,926 feet and has a maximum capacity of 4,480 cfs. The energy

1 requirement for the Edmonston Pumping Plant is 835 MW. The pumping energy factor is 2,256  
2 kWh/af with an efficiency of about 85%.

3 The California Aqueduct continues over the Tehachapi Mountains into Southern California and splits  
4 into two branches—the East Branch and West Branch. The West Branch delivers water to Lake  
5 Castaic and provides water to western Los Angeles County and vicinity. The East Branch delivers  
6 water to the Antelope Valley, San Bernardino/Riverside areas, and eventually to Lake Perris near  
7 Hemet. The Oso Pumping Plant is the first major structure on the West Branch of the California  
8 Aqueduct. The plant is located approximately 7 miles east of Gorman. The plant lifts water 231 feet  
9 and has a maximum capacity of 3,252 cfs. The energy requirement is about 70 MW. The pumping  
10 energy factor is about 260 kWh/af with an efficiency of about 89%. The west branch water then  
11 flows to Pyramid Lake through the Warne Powerplant. The William E. Warne Powerplant is located  
12 at Pyramid Lake. The plant contains two units with a capacity of 1,500 cfs. The water head is about  
13 740 feet. The generation capacity is 74 MW with an energy factor of 570 kWh/af and an efficiency of  
14 about 77%. The Warne Powerplant recovers some of the energy used to pump West Branch  
15 aqueduct water over the Tehachapi Mountains. The Castaic Powerplant is owned and operated by  
16 the Los Angeles Department of Water and Power (LADWP). The plant is located between Pyramid  
17 Lake and the Elderberry Forebay within Castaic Lake. The Castaic Powerplant is operated as a  
18 pump-back facility, providing peaking generation for LADWP. The plant contains seven generating  
19 units with a maximum flow of 3,470 cfs and a generating capacity of 1,250 MW. Six pumping units  
20 lift water about 1,075 feet with a combined capacity of 2,300 cfs. The pumping units require a total  
21 of 1,450 MW.

22 The Alamo Powerplant is on the East Branch of the California Aqueduct. The plant has a head of  
23 about 140 feet with a flow of 1,740 cfs that generates about 17 MW. The energy factor is about 120  
24 kWh/af with an efficiency of about 85%. The Pearblossom Pumping Plant is on the East Branch,  
25 about 25 miles west of Lancaster. The plant contains nine pumping units with a combined capacity  
26 of 2,575 cfs with a pumping head of 540 feet. Aqueduct capacity restrictions limit the flow to about  
27 2,000 cfs. The energy requirement for a flow of 2,000 cfs is about 120 MW with an energy factor of  
28 about 712 kWh/af and an efficiency of 76%. The Mojave Siphon Powerplant is located at Silverwood  
29 Lake. The plant is operated at a maximum flow of 2,000 cfs due to aqueduct restrictions. The  
30 generating capacity at 2,000 cfs with a maximum head of 135 feet (Silverwood Lake at low  
31 elevation) is about 23 MW. The energy factor is about 115 kWh/af and the efficiency is about 85%.  
32 Water from Silverwood Lake flows through the San Bernardino Tunnel to the Devil Canyon  
33 Powerplant, 5 miles north of San Bernardino. The plant contains four units with a maximum flow of  
34 2,600 cfs due to capacity restrictions at the afterbay. The water head is 1,400 feet and the maximum  
35 generation capacity is 235 MW. The energy factor is 1,150 kWh/af with an efficiency of about 82%.

### 36 **21.1.3 CVP and SWP Energy Generation and Pumping Use**

37 The generation of electrical energy at the CVP and SWP generating plants is dependent on the water  
38 runoff conditions and therefore can vary greatly from year to year. Tables 21-1, 21-2, 21-5, and 21-6  
39 provide summaries of CVP and SWP hydropower generation capacities, but the monthly water flows  
40 (TAF) are needed to calculate the energy that would be generated (GWh) each month. Each of the  
41 generating plants has a water flow capacity, and high flows would spill (be released through other  
42 gates or spillways). The CVP and SWP facilities have been designed to utilize the majority of the  
43 flows at each generating plant. The energy required to pump and deliver water from the Delta to the  
44 CVP and SWP water contractors is totally dependent on the volume of water delivered each month

1 and the pumping plants that are needed to deliver the water to the contractors. Because the  
2 percentage of each year's water supply that is delivered to each CVP and SWP contractor is  
3 relatively constant, and the pumping energy required to seasonally store water in San Luis or to  
4 deliver water to each contractor is constant, the total monthly energy requirement for CVP and SWP  
5 pumping can be estimated from the annual CVP and SWP pumping from the Delta.

### 6 **21.1.3.1 CVP and SWP Energy Generation**

7 For planning purposes such as this energy evaluation of the BDCP alternatives, the monthly CVP and  
8 SWP energy generation can be estimated from the monthly flows (TAF) and reservoir storage (TAF)  
9 simulated with the CALSIM-II model for each BDCP alternative. The CALSIM-II model is a water  
10 resources simulation planning tool developed jointly by DWR and Reclamation. The CALSIM-II  
11 model is applied to the SWP, the CVP, and the Delta. The model is designed to evaluate the  
12 performance of the CVP and SWP systems for: existing or future levels of land development,  
13 potential future facilities, and current or alternative operational policies and regulatory  
14 environments. Key model output includes reservoir storage, in-stream river flow, water delivery,  
15 Delta exports and conditions, biological indicators, and operational and regulatory metrics. CALSIM-  
16 II represents the best available planning model for the CVP-SWP system.

17 CVP and SWP water deliveries are simulated, in CALSIM-II, based on a method that estimates the  
18 actual forecast allocation process. The North of Delta (NOD) and South of Delta (SOD) deliveries for  
19 both the CVP and SWP contractors are determined using a set of rules for governing the allocation of  
20 water. CALSIM-II uses a water supply and water demand relationship to find delivery quantities  
21 given available water, operational constraints, and desired reservoir carryover storage volumes.  
22 CALSIM-II simulates a suite of environments to represent the CVP and SWP systems. The regulatory  
23 environments consist of the SWRCB D-1641 (also referred to as the 1995 Water Quality Control Plan  
24 "WQCP"), and the CVPIA (b)(2) regulatory environment which implements fish protection actions  
25 and the Joint Point of Diversion (JPOD) where water is exported or "wheeled" at the Delta pumping  
26 facilities.

27 Given the relatively generalized representation in CALSIM-II model of the complex physical  
28 operational environment of the SWP, CVP, and the Delta, caution is required when interpreting  
29 outputs from the model results as a basis for trying to predict energy consumption associated with  
30 water deliveries. The CALSIM-II model is not designed to reproduce actual historical operations of  
31 the different SWP and CVP system power generation and pumping plants. Also, different regulatory  
32 environment settings in the CALSIM-II model would produce different allocations and system water  
33 deliveries, thereby also incidentally affecting energy consumption. For these reasons, CALSIM-II  
34 outputs represent a good starting place for assessing power consumption for related water  
35 deliveries. In DWR's experience, the CALSIM-II outputs tend to overstate, rather than understate,  
36 actual power consumption, and thus analysis tends to err on the side of overstating impacts.

37 Results from the CALSIM-II modeling indicate that the basic operation of each of the CVP and SWP  
38 reservoirs is largely determined by the reservoir inflow, the maximum reservoir storage (flood  
39 control) values, and the minimum downstream flow requirements for each reservoir. The seasonal  
40 energy generation follows the seasonal inflows and reservoir storage patterns. The generation  
41 energy factor (MWh/TAF) for each reservoir is highest when the reservoir is full, but the seasonal  
42 range of water heads (reservoir elevation minus tailwater elevation) is generally about 75% of the  
43 maximum value in most years. Only in a few dry year sequences (about 10% of the years) are the  
44 Trinity or Shasta storage levels low enough to reduce the water head to less than 50% of the

1 maximum head. The monthly reservoir inflows (and releases) vary much more dramatically from  
2 the spring runoff months to the low flow summer months or between wet and dry years.

3 There are some variations in the seasonal storage and release patterns for a given year between  
4 alternatives, but the energy generation for each year is largely determined by the reservoir inflows.  
5 There are therefore very few differences in the monthly and annual upstream CVP and SWP energy  
6 generation patterns between the BDCP alternatives. The small changes in the monthly reservoir  
7 release patterns between alternatives will cause only small changes in the energy generation.  
8 Therefore, the only substantial changes in the CVP and SWP energy generation patterns will be  
9 caused by the assumed future effects of climate change on altered runoff patterns.

10 The energy generation calculations based on upstream reservoir operations (storage and release  
11 flows) will be demonstrated as an example for the Existing Conditions (2010) for the upstream CVP  
12 and SWP Powerplants. The maximum monthly generation depends on the monthly release flow  
13 (TAF) and the reservoir storage (TAF) which controls the water head and corresponding energy  
14 factor. The BDCP energy analysis assumes that the upstream energy generation at the CVP and SWP  
15 facilities would not change for the different baselines (i.e., Existing Conditions under CEQA and No  
16 Action Alternative under NEPA) since this is based on runoff and reservoir elevations, and would  
17 not change for the BDCP alternatives. Therefore, only energy uses for pumping at the proposed  
18 North Delta pumping plants and at the existing CVP and SWP Delta and south of Delta pumping  
19 plants are evaluated for each of the BDCP alternatives. The energy generation values shown in the  
20 following monthly tables provide examples of the variations in the monthly generation caused by  
21 changes in hydrology at each CVP and SWP facility for Existing Conditions; the monthly generation  
22 for the No Action Alternative would be very similar.

23 Table 21-7a shows the monthly cumulative distributions of Trinity Reservoir storage (TAF) for  
24 Existing Conditions (with historical inflows) as simulated by CALSIM-II for 1922–2003. The  
25 maximum storage was about 2,400 TAF in May and June of a few years. The minimum storage was  
26 about 240 TAF (10% of maximum storage) in the fall months of a few years.

27 **Table 21-7a. CALSIM-II -Simulated Monthly Cumulative Distributions of Trinity Storage (TAF) for**  
28 **Existing Conditions**

|         | Oct   | Nov   | Dec   | Jan   | Feb   | Mar   | Apr   | May   | Jun   | Jul   | Aug   | Sep   |
|---------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Minimum | 240   | 240   | 242   | 250   | 267   | 355   | 476   | 533   | 551   | 541   | 414   | 276   |
| 10%     | 633   | 667   | 684   | 675   | 764   | 812   | 974   | 1,077 | 1,029 | 946   | 785   | 680   |
| 20%     | 895   | 890   | 926   | 1,027 | 1,019 | 1,146 | 1,288 | 1,319 | 1,270 | 1,188 | 1,047 | 951   |
| 30%     | 1,102 | 1,099 | 1,132 | 1,197 | 1,296 | 1,410 | 1,527 | 1,558 | 1,512 | 1,518 | 1,308 | 1,185 |
| 40%     | 1,241 | 1,216 | 1,252 | 1,316 | 1,422 | 1,601 | 1,747 | 1,819 | 1,740 | 1,641 | 1,461 | 1,320 |
| 50%     | 1,370 | 1,341 | 1,374 | 1,446 | 1,617 | 1,718 | 1,879 | 1,956 | 1,867 | 1,755 | 1,608 | 1,446 |
| 60%     | 1,460 | 1,421 | 1,577 | 1,715 | 1,758 | 1,872 | 2,035 | 2,066 | 1,995 | 1,866 | 1,696 | 1,552 |
| 70%     | 1,693 | 1,681 | 1,750 | 1,786 | 1,868 | 2,017 | 2,159 | 2,213 | 2,154 | 2,057 | 1,925 | 1,800 |
| 80%     | 1,909 | 1,838 | 1,838 | 1,866 | 1,950 | 2,050 | 2,178 | 2,259 | 2,263 | 2,226 | 2,116 | 2,004 |
| 90%     | 1,913 | 1,850 | 1,850 | 1,875 | 1,950 | 2,050 | 2,195 | 2,310 | 2,361 | 2,319 | 2,210 | 2,063 |
| Maximum | 1,913 | 1,850 | 1,850 | 1,875 | 2,054 | 2,154 | 2,200 | 2,360 | 2,434 | 2,359 | 2,210 | 2,063 |
| Average | 1,336 | 1,307 | 1,338 | 1,396 | 1,483 | 1,600 | 1,738 | 1,810 | 1,790 | 1,703 | 1,564 | 1,432 |

29

1 Table 21-7b shows the monthly cumulative distributions of the calculated Trinity Powerplant water  
 2 head (feet) for Existing Conditions. The surface elevation is estimated from an equation that was  
 3 determined from the Trinity Reservoir elevation and volume. The equation includes a factor unique  
 4 to the facility based on the actual relationship to storage volume and reservoir elevation. In the  
 5 equation below, the value of 2.47 is unique to Trinity; other reservoirs have their own conversion  
 6 factors. The equation for Trinity elevation (similar for each reservoir) is:

$$\text{Surface elevation (feet)} = 2.47 \times \text{storage (acre-feet [af])}^{0.3509} + 1,940 \text{ (base elevation)}$$

8 **Table 21-7b. Monthly Cumulative Distributions of Estimated Trinity Reservoir Head (feet) for Existing**  
 9 **Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Minimum | 231 | 231 | 231 | 233 | 238 | 259 | 283 | 293 | 295 | 294 | 271 | 241 |
| 10%     | 308 | 313 | 316 | 314 | 326 | 333 | 352 | 363 | 358 | 349 | 329 | 315 |
| 20%     | 343 | 342 | 347 | 358 | 357 | 370 | 384 | 387 | 382 | 374 | 360 | 349 |
| 30%     | 366 | 365 | 369 | 375 | 385 | 395 | 405 | 408 | 404 | 405 | 386 | 374 |
| 40%     | 380 | 377 | 381 | 387 | 396 | 411 | 423 | 428 | 422 | 415 | 400 | 387 |
| 50%     | 392 | 389 | 392 | 398 | 413 | 421 | 433 | 438 | 432 | 424 | 412 | 398 |
| 60%     | 400 | 396 | 409 | 420 | 424 | 432 | 444 | 446 | 441 | 432 | 419 | 407 |
| 70%     | 419 | 418 | 423 | 426 | 432 | 443 | 452 | 456 | 452 | 445 | 436 | 427 |
| 80%     | 435 | 430 | 430 | 432 | 438 | 445 | 454 | 459 | 459 | 457 | 450 | 442 |
| 90%     | 435 | 431 | 431 | 433 | 438 | 445 | 455 | 462 | 466 | 463 | 456 | 446 |
| Maximum | 435 | 431 | 431 | 433 | 445 | 452 | 455 | 466 | 470 | 465 | 456 | 446 |
| Average | 389 | 386 | 389 | 394 | 402 | 411 | 422 | 428 | 426 | 420 | 408 | 397 |

11 The tailwater elevation for the Trinity Powerplant (upstream end of Lewiston Reservoir) is  
 12 normally about 1,900 feet. The maximum head for the Trinity Powerplant was about 470 feet and  
 13 the median monthly heads range from 390 feet in the fall months to 430 feet in the spring months  
 14 when the reservoir is highest. The minimum head was about 230 feet. The generating plant cannot  
 15 operate below a minimum water elevation (penstock opening).

16 Table 21-7c shows the monthly cumulative distributions of Trinity Powerplant release flow (TAF)  
 17 for the No Action Alternative as simulated by CALSIM-II for 1922–2003. Because the maximum  
 18 penstock flow is about 4,200 cfs (260 TAF per month) there are some months with flow that must be  
 19 released from the river gates, without generating energy. Most of the release flows were in the  
 20 spring and summer months. Releases were made in every month to supply Trinity River flows below  
 21 Lewiston Reservoir. The Trinity generating plant was at maximum capacity in May for about half of  
 22 the years. This is the month with the peak flow requirements for the Trinity River.

1 **Table 21-7c. CALSIM-II simulated Monthly Cumulative Distributions of Trinity Powerplant Flow (TAF)**  
 2 **for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 12  | 9   | 16  | 16  | 14  | 16  | 24  | 98  | 55  | 44  | 43  | 39  | 576    |
| 10%     | 38  | 18  | 18  | 18  | 16  | 17  | 27  | 171 | 61  | 120 | 99  | 76  | 812    |
| 20%     | 38  | 18  | 18  | 18  | 16  | 18  | 34  | 187 | 91  | 130 | 120 | 86  | 972    |
| 30%     | 69  | 24  | 24  | 24  | 18  | 18  | 36  | 195 | 121 | 151 | 120 | 116 | 1,011  |
| 40%     | 69  | 24  | 24  | 24  | 22  | 24  | 41  | 256 | 137 | 160 | 123 | 116 | 1,064  |
| 50%     | 69  | 37  | 25  | 25  | 22  | 24  | 45  | 257 | 149 | 160 | 135 | 116 | 1,130  |
| 60%     | 94  | 47  | 33  | 34  | 22  | 30  | 51  | 260 | 152 | 160 | 151 | 146 | 1,197  |
| 70%     | 119 | 47  | 34  | 51  | 30  | 33  | 56  | 260 | 169 | 172 | 151 | 146 | 1,288  |
| 80%     | 133 | 48  | 34  | 93  | 32  | 61  | 61  | 260 | 194 | 191 | 194 | 171 | 1,410  |
| 90%     | 147 | 54  | 86  | 160 | 65  | 114 | 101 | 260 | 252 | 231 | 222 | 182 | 1,640  |
| Maximum | 226 | 252 | 260 | 260 | 235 | 260 | 172 | 260 | 252 | 260 | 231 | 213 | 2,198  |
| Average | 88  | 40  | 46  | 58  | 39  | 49  | 55  | 225 | 148 | 163 | 146 | 126 | 1,184  |

3  
 4 Table 21-7d shows the monthly cumulative distributions of calculated Trinity Powerplant energy  
 5 generation (GWh) for Existing Conditions for 1922–2003. The maximum generation is about 103  
 6 MW at the maximum release flow at the highest head. The generation efficiency is about 85% and  
 7 the generation energy factor is the head times the efficiency. The seasonal generation pattern can be  
 8 summarized with the median monthly values; the generation is highest in May and moderately high  
 9 in June-September and much less in October–April. The median annual generation for the No Action  
 10 Alternative was calculated to be about 400 GWh and the average annual generation was 418 GWh.  
 11 [This represents about \$20 million in energy value assuming an average energy cost of \$50/MWh].  
 12 The range in annual generation reflects the range in annual runoff from the Trinity watershed. The  
 13 10% cumulative annual generation was 241 GWh (0.6 x median) and the 90% cumulative annual  
 14 generation was 622 GWh (1.55 x median).

1 **Table 21-7d. Monthly Cumulative Distributions of Estimated Trinity Powerplant Energy Generation**  
 2 **(GWh) for Existing Conditions**

|         | Oct  | Nov  | Dec  | Jan  | Feb  | Mar   | Apr  | May   | Jun   | Jul   | Aug  | Sep  | Annual |
|---------|------|------|------|------|------|-------|------|-------|-------|-------|------|------|--------|
| Minimum | 2.4  | 1.7  | 3.6  | 3.6  | 3.5  | 3.9   | 7.6  | 27.9  | 15.3  | 11.0  | 11.1 | 9.6  | 152    |
| 10%     | 10.4 | 5.4  | 5.3  | 5.0  | 4.6  | 5.2   | 9.5  | 44.6  | 18.8  | 33.0  | 32.0 | 21.8 | 241    |
| 20%     | 11.2 | 5.9  | 5.9  | 6.1  | 5.2  | 6.1   | 10.6 | 64.0  | 30.9  | 41.2  | 38.0 | 25.5 | 290    |
| 30%     | 19.8 | 6.6  | 7.0  | 7.1  | 6.0  | 6.7   | 13.1 | 70.3  | 43.0  | 52.9  | 44.3 | 36.9 | 347    |
| 40%     | 22.9 | 7.1  | 7.6  | 7.9  | 7.0  | 8.0   | 14.5 | 85.5  | 49.6  | 57.0  | 45.6 | 38.2 | 378    |
| 50%     | 24.3 | 12.0 | 8.2  | 8.8  | 7.6  | 8.7   | 16.2 | 94.7  | 56.7  | 59.1  | 49.6 | 41.7 | 401    |
| 60%     | 32.2 | 15.4 | 11.1 | 11.0 | 8.0  | 9.9   | 17.5 | 98.4  | 58.9  | 60.7  | 52.3 | 50.0 | 435    |
| 70%     | 37.2 | 15.9 | 11.7 | 17.8 | 10.0 | 11.3  | 19.8 | 100.6 | 60.6  | 62.3  | 54.8 | 52.5 | 479    |
| 80%     | 48.4 | 16.8 | 12.3 | 31.2 | 11.6 | 23.1  | 21.4 | 101.6 | 71.8  | 68.9  | 61.2 | 56.2 | 527    |
| 90%     | 51.0 | 19.6 | 31.4 | 49.1 | 24.2 | 42.9  | 38.9 | 102.3 | 98.2  | 81.6  | 74.1 | 68.1 | 622    |
| Maximum | 81.7 | 91.5 | 95.3 | 95.7 | 89.0 | 100.1 | 66.4 | 103.0 | 100.7 | 103.0 | 86.2 | 75.6 | 841    |
| Average | 29.1 | 13.4 | 15.9 | 20.2 | 13.9 | 17.8  | 19.9 | 82.3  | 54.7  | 58.0  | 50.1 | 43.2 | 418    |

3

4 Table 21-7e shows the monthly cumulative distributions of calculated Trinity Powerplant energy  
 5 generation (GWh) for the No Action Alternative for 1922–2003. The average inflow was slightly  
 6 more modified, with more inflow shifted into the early spring months with even less snowmelt  
 7 runoff in May and June, but the release patterns and energy generation were nearly identical to the  
 8 No Action Alternative. The average annual Trinity Powerplant energy generation was 415 GWh,  
 9 reduced by about 1% from the No Action Alternative.

10 **Table 21-7e. Monthly Cumulative Distributions of Estimated Trinity Powerplant Energy Generation**  
 11 **(GWh) for the No Action Alternative**

|         | Oct  | Nov  | Dec  | Jan  | Feb  | Mar   | Apr  | May   | Jun   | Jul   | Aug  | Sep  | Annual |
|---------|------|------|------|------|------|-------|------|-------|-------|-------|------|------|--------|
| Minimum | 0.0  | 1.7  | 1.8  | 1.8  | 3.6  | 3.7   | 7.7  | 20.8  | 14.0  | 11.4  | 1.3  | 1.4  | 126    |
| 10%     | 5.8  | 4.5  | 4.4  | 4.7  | 4.4  | 4.9   | 9.3  | 46.1  | 17.7  | 27.0  | 28.2 | 12.2 | 247    |
| 20%     | 10.7 | 6.0  | 5.5  | 5.7  | 5.1  | 6.0   | 11.2 | 64.3  | 31.4  | 36.6  | 37.1 | 23.8 | 274    |
| 30%     | 11.8 | 6.6  | 6.5  | 6.4  | 5.8  | 6.5   | 13.5 | 69.5  | 42.8  | 45.1  | 44.6 | 26.0 | 323    |
| 40%     | 19.5 | 7.1  | 7.1  | 7.2  | 6.6  | 7.4   | 15.3 | 84.1  | 56.9  | 56.5  | 46.0 | 35.4 | 362    |
| 50%     | 23.3 | 7.3  | 7.7  | 7.9  | 7.0  | 8.3   | 16.6 | 91.5  | 58.7  | 58.9  | 53.0 | 41.7 | 401    |
| 60%     | 24.7 | 15.4 | 10.9 | 11.3 | 7.8  | 9.3   | 18.1 | 97.6  | 70.2  | 59.8  | 54.0 | 50.0 | 440    |
| 70%     | 33.4 | 15.9 | 11.3 | 11.8 | 8.3  | 10.9  | 19.9 | 99.3  | 80.7  | 61.7  | 55.1 | 51.6 | 478    |
| 80%     | 36.2 | 17.3 | 11.8 | 33.3 | 20.1 | 19.7  | 24.5 | 101.1 | 90.4  | 66.4  | 62.2 | 59.1 | 538    |
| 90%     | 46.7 | 40.2 | 16.0 | 61.2 | 42.7 | 52.6  | 41.9 | 102.0 | 97.2  | 74.1  | 72.0 | 68.4 | 652    |
| Maximum | 81.7 | 76.1 | 95.3 | 96.7 | 90.7 | 102.2 | 94.0 | 103.0 | 100.7 | 103.0 | 81.2 | 83.7 | 836    |
| Average | 24.1 | 15.8 | 12.8 | 20.3 | 16.5 | 17.9  | 21.5 | 81.7  | 59.9  | 54.3  | 49.6 | 40.9 | 415    |

12

13 Although not shown here (see Chapter 5, *Water Supply*), the Trinity Reservoir storage patterns and  
 14 the Trinity release patterns were nearly identical for all of the BDCP (operations) alternatives. The  
 15 energy generation at all of the CVP and SWP generation plants was nearly identical for each of the  
 16 BDCP alternatives. The only major factor affecting the monthly and annual CVP and SWP energy  
 17 generation was the hydrology (inflow) conditions.

1 Tables 21-8a through 21-8h show the calculated monthly cumulative distribution of energy  
 2 generated at each of the other major upstream CVP and SWP facilities for Existing Conditions. Table  
 3 21-8a shows the monthly generation patterns for the Carr Powerplant, and Table 21-8b shows the  
 4 monthly generation patterns for the Spring Creek Powerplant. Both of these power plants are  
 5 dependent on the Trinity River exports that are greatest in the summer months of July-October, with  
 6 occasional exports in high flow winter months. The average annual generation was 294 GWh for the  
 7 Carr Power Plant and 378 GWh for the Spring Creek Powerplant. Table 21-8c shows the monthly  
 8 generation patterns for the Shasta Powerplant, and Table 21-8d shows the monthly generation  
 9 patterns for the Keswick Powerplant. The Shasta generation was highest in the months of May  
 10 through August, because of high reservoir elevations (i.e., head) and high releases. The annual  
 11 average Shasta generation was 2,049 GWh. The Keswick generation was more uniform in all months  
 12 but was highest in June–August. The annual average generation was 469 GWh. Table 21-8e shows  
 13 the monthly generation patterns for Folsom and Table 21-8f shows the monthly generation for  
 14 Nimbus. Both power plants had fairly uniform energy generation, with the highest generation in  
 15 January–July, and the lowest generation in September. The annual average generation was 579 GWh  
 16 at Folsom and 72 GWh at Nimbus. Table 21-8g shows the monthly generation patterns at the New  
 17 Melones Powerplant. The highest generation was in the months of April-July, corresponding to peak  
 18 snowmelt and irrigation diversions. The annual average generation was 477 gWh. Table 21-8h  
 19 shows the monthly generation pattern for the Hyatt and Thermalito Power Plants (combined).  
 20 These are the two SWP power plants on the Feather River. The highest generation was in the  
 21 months of May through September. The lowest generation was in October-December. The annual  
 22 average generation was 2,292 GWh.

23 **Table 21-8a. Monthly Cumulative Distributions of Estimated Carr Powerplant Energy Generation**  
 24 **(GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Min     | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 1   | 0   | 83     |
| 10%     | 8   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 43  | 42  | 8   | 158    |
| 20%     | 8   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 51  | 51  | 33  | 199    |
| 30%     | 25  | 0   | 0   | 0   | 0   | 0   | 3   | 0   | 2   | 51  | 51  | 42  | 225    |
| 40%     | 25  | 3   | 3   | 3   | 0   | 3   | 5   | 0   | 8   | 51  | 52  | 49  | 257    |
| 50%     | 25  | 4   | 3   | 3   | 3   | 3   | 8   | 0   | 8   | 51  | 59  | 49  | 291    |
| 60%     | 25  | 15  | 8   | 4   | 3   | 3   | 10  | 0   | 25  | 59  | 68  | 65  | 318    |
| 70%     | 42  | 16  | 8   | 8   | 3   | 6   | 13  | 3   | 25  | 68  | 68  | 65  | 350    |
| 80%     | 60  | 16  | 12  | 20  | 3   | 8   | 16  | 8   | 25  | 75  | 85  | 82  | 387    |
| 90%     | 66  | 30  | 31  | 61  | 8   | 28  | 41  | 8   | 42  | 112 | 100 | 85  | 456    |
| Max     | 112 | 68  | 59  | 88  | 31  | 112 | 86  | 81  | 105 | 112 | 112 | 108 | 643    |
| Average | 34  | 11  | 10  | 15  | 3   | 9   | 13  | 6   | 17  | 60  | 63  | 53  | 294    |

25

1 **Table 21-8b. Monthly Cumulative Distributions of Estimated Spring Creek Powerplant Energy**  
 2 **Generation (GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 4   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 0   | 6   | 3   | 113    |
| 10%     | 13  | 3   | 0   | 0   | 2   | 0   | 0   | 0   | 0   | 38  | 39  | 24  | 201    |
| 20%     | 14  | 5   | 1   | 5   | 5   | 3   | 0   | 0   | 0   | 47  | 47  | 31  | 263    |
| 30%     | 26  | 6   | 4   | 8   | 10  | 6   | 0   | 0   | 2   | 47  | 48  | 46  | 292    |
| 40%     | 29  | 11  | 7   | 16  | 16  | 13  | 1   | 1   | 5   | 48  | 51  | 46  | 339    |
| 50%     | 32  | 17  | 9   | 21  | 25  | 18  | 7   | 3   | 7   | 50  | 56  | 49  | 377    |
| 60%     | 45  | 19  | 16  | 26  | 28  | 24  | 15  | 5   | 15  | 55  | 63  | 62  | 407    |
| 70%     | 60  | 22  | 24  | 40  | 34  | 36  | 19  | 8   | 19  | 63  | 67  | 63  | 426    |
| 80%     | 65  | 25  | 32  | 51  | 40  | 44  | 26  | 10  | 24  | 80  | 84  | 73  | 446    |
| 90%     | 73  | 31  | 46  | 85  | 62  | 64  | 43  | 21  | 39  | 106 | 106 | 85  | 548    |
| Maximum | 116 | 90  | 110 | 138 | 125 | 131 | 89  | 109 | 111 | 117 | 138 | 104 | 951    |
| Average | 40  | 17  | 19  | 33  | 27  | 26  | 15  | 9   | 15  | 59  | 63  | 54  | 378    |

3

4 **Table 21-8c. Monthly Cumulative Distributions of Estimated Shasta Powerplant Energy Generation**  
 5 **(GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 36  | 39  | 46  | 0   | 30  | 43  | 50  | 79  | 126 | 102 | 45  | 32  | 875    |
| 10%     | 65  | 58  | 53  | 48  | 49  | 58  | 72  | 118 | 198 | 203 | 139 | 57  | 1,269  |
| 20%     | 78  | 74  | 64  | 60  | 58  | 69  | 91  | 133 | 210 | 236 | 161 | 72  | 1,456  |
| 30%     | 93  | 81  | 71  | 69  | 64  | 78  | 98  | 161 | 227 | 250 | 178 | 86  | 1,603  |
| 40%     | 101 | 88  | 75  | 75  | 72  | 86  | 115 | 169 | 238 | 268 | 197 | 96  | 1,760  |
| 50%     | 107 | 99  | 84  | 86  | 83  | 95  | 133 | 183 | 247 | 275 | 203 | 108 | 1,917  |
| 60%     | 112 | 121 | 91  | 96  | 96  | 109 | 148 | 201 | 257 | 291 | 212 | 136 | 2,281  |
| 70%     | 124 | 142 | 111 | 145 | 176 | 167 | 162 | 219 | 262 | 303 | 223 | 184 | 2,457  |
| 80%     | 139 | 177 | 195 | 206 | 385 | 259 | 183 | 229 | 276 | 320 | 232 | 228 | 2,656  |
| 90%     | 156 | 204 | 333 | 419 | 464 | 409 | 243 | 260 | 302 | 332 | 256 | 255 | 2,907  |
| Maximum | 194 | 491 | 509 | 513 | 489 | 539 | 532 | 390 | 413 | 369 | 301 | 321 | 3,605  |
| Average | 108 | 123 | 136 | 150 | 175 | 164 | 150 | 189 | 246 | 271 | 197 | 139 | 2,049  |

6

1 **Table 21-8d. Monthly Cumulative Distributions of Estimated Keswick Powerplant Energy Generation**  
 2 **(GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Min     | 13  | 15  | 15  | 15  | 14  | 15  | 15  | 17  | 33  | 40  | 33  | 15  | 268    |
| 10%     | 20  | 16  | 15  | 15  | 14  | 15  | 17  | 25  | 40  | 49  | 40  | 20  | 317    |
| 20%     | 23  | 18  | 15  | 15  | 14  | 15  | 20  | 28  | 43  | 54  | 42  | 22  | 338    |
| 30%     | 26  | 19  | 16  | 15  | 14  | 15  | 20  | 30  | 44  | 57  | 44  | 25  | 367    |
| 40%     | 27  | 21  | 18  | 18  | 16  | 18  | 24  | 32  | 45  | 59  | 47  | 26  | 393    |
| 50%     | 28  | 23  | 18  | 20  | 19  | 21  | 25  | 35  | 47  | 61  | 49  | 29  | 429    |
| 60%     | 29  | 26  | 20  | 21  | 19  | 21  | 28  | 38  | 49  | 64  | 50  | 36  | 492    |
| 70%     | 31  | 31  | 25  | 34  | 39  | 38  | 32  | 41  | 51  | 69  | 51  | 44  | 532    |
| 80%     | 34  | 40  | 40  | 48  | 63  | 55  | 34  | 42  | 54  | 69  | 55  | 54  | 580    |
| 90%     | 40  | 44  | 69  | 70  | 63  | 70  | 52  | 50  | 57  | 69  | 59  | 59  | 677    |
| Max     | 46  | 68  | 70  | 70  | 63  | 70  | 68  | 70  | 68  | 70  | 66  | 68  | 934    |
| Average | 29  | 28  | 31  | 38  | 43  | 39  | 31  | 36  | 48  | 61  | 49  | 36  | 469    |

3

4 **Table 21-8e. Monthly Cumulative Distributions of Estimated Folsom Powerplant Energy Generation**  
 5 **(GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Min     | 5   | 5   | 6   | 10  | 8   | 4   | 4   | 4   | 4   | 4   | 4   | 3   | 76     |
| 10%     | 11  | 11  | 11  | 12  | 16  | 14  | 15  | 15  | 20  | 23  | 14  | 12  | 250    |
| 20%     | 20  | 20  | 20  | 21  | 19  | 17  | 23  | 20  | 26  | 43  | 20  | 18  | 323    |
| 30%     | 22  | 23  | 24  | 25  | 21  | 25  | 26  | 25  | 31  | 49  | 30  | 23  | 372    |
| 40%     | 23  | 28  | 30  | 27  | 27  | 29  | 32  | 32  | 39  | 55  | 36  | 29  | 474    |
| 50%     | 24  | 30  | 31  | 28  | 43  | 40  | 40  | 49  | 47  | 68  | 40  | 37  | 556    |
| 60%     | 25  | 34  | 31  | 43  | 68  | 56  | 50  | 62  | 53  | 75  | 46  | 45  | 665    |
| 70%     | 25  | 48  | 32  | 75  | 84  | 70  | 71  | 74  | 70  | 80  | 52  | 63  | 720    |
| 80%     | 25  | 53  | 52  | 105 | 108 | 91  | 85  | 89  | 85  | 85  | 63  | 68  | 807    |
| 90%     | 27  | 67  | 110 | 121 | 116 | 130 | 111 | 148 | 124 | 87  | 70  | 75  | 922    |
| Max     | 57  | 125 | 129 | 129 | 117 | 134 | 136 | 148 | 143 | 111 | 78  | 80  | 1,328  |
| Average | 23  | 38  | 41  | 53  | 57  | 54  | 53  | 60  | 58  | 61  | 42  | 41  | 579    |

6

1 **Table 21-8f. Monthly Cumulative Distributions of Estimated Nimbus Powerplant Energy Generation**  
 2 **(GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Min     | 0.9 | 0.9 | 0.9 | 1.5 | 1.3 | 0.6 | 0.6 | 0.6 | 0.6 | 0.7 | 0.6 | 0.6 | 12     |
| 10%     | 1.5 | 1.4 | 1.5 | 1.5 | 1.9 | 1.6 | 1.8 | 1.8 | 2.2 | 3.2 | 1.8 | 1.6 | 31     |
| 20%     | 2.6 | 2.5 | 2.6 | 2.8 | 2.4 | 2.0 | 2.5 | 2.2 | 3.1 | 4.8 | 2.7 | 2.4 | 38     |
| 30%     | 2.8 | 2.9 | 3.1 | 3.1 | 2.4 | 2.8 | 2.9 | 2.7 | 3.1 | 5.4 | 3.4 | 2.7 | 44     |
| 40%     | 2.8 | 3.4 | 3.7 | 3.1 | 3.1 | 3.2 | 3.3 | 3.2 | 4.1 | 5.9 | 4.2 | 3.5 | 53     |
| 50%     | 2.8 | 3.6 | 3.7 | 3.2 | 4.9 | 4.5 | 4.3 | 5.1 | 4.9 | 7.0 | 4.6 | 4.3 | 61     |
| 60%     | 2.8 | 4.0 | 3.7 | 5.0 | 7.8 | 6.2 | 5.3 | 6.2 | 5.4 | 8.5 | 5.2 | 5.4 | 73     |
| 70%     | 2.8 | 5.5 | 3.7 | 8.5 | 8.3 | 7.7 | 7.4 | 7.4 | 7.0 | 9.2 | 5.9 | 7.0 | 93     |
| 80%     | 2.8 | 6.3 | 5.9 | 9.2 | 8.3 | 9.2 | 8.9 | 8.9 | 8.9 | 9.2 | 6.7 | 7.6 | 109    |
| 90%     | 3.1 | 7.8 | 9.2 | 9.2 | 8.3 | 9.2 | 8.9 | 9.2 | 8.9 | 9.2 | 7.4 | 8.5 | 124    |
| Max     | 6.2 | 8.9 | 9.2 | 9.2 | 8.3 | 9.2 | 8.9 | 9.2 | 8.9 | 9.2 | 8.2 | 8.9 | 183    |
| Average | 2.7 | 4.9 | 6.0 | 8.1 | 8.3 | 6.8 | 5.8 | 6.4 | 6.3 | 6.7 | 4.7 | 4.8 | 72     |

3

4 **Table 21-8g. Monthly Cumulative Distributions of Estimated New Melones Powerplant Energy**  
 5 **Generation (GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Min     | 6   | 3   | 1   | 0   | 0   | 4   | 18  | 36  | 27  | 29  | 29  | 17  | 214    |
| 10%     | 14  | 8   | 7   | 3   | 2   | 11  | 45  | 47  | 35  | 38  | 35  | 21  | 298    |
| 20%     | 21  | 9   | 8   | 5   | 5   | 16  | 51  | 54  | 41  | 43  | 42  | 23  | 339    |
| 30%     | 24  | 9   | 8   | 8   | 6   | 22  | 58  | 61  | 43  | 45  | 44  | 26  | 376    |
| 40%     | 26  | 9   | 9   | 8   | 9   | 28  | 62  | 66  | 46  | 48  | 47  | 27  | 394    |
| 50%     | 28  | 11  | 9   | 9   | 11  | 34  | 69  | 78  | 50  | 49  | 48  | 29  | 429    |
| 60%     | 31  | 13  | 10  | 10  | 13  | 43  | 77  | 85  | 69  | 57  | 52  | 32  | 481    |
| 70%     | 33  | 14  | 11  | 10  | 15  | 51  | 81  | 89  | 78  | 62  | 57  | 35  | 523    |
| 80%     | 35  | 16  | 13  | 15  | 19  | 56  | 83  | 94  | 84  | 68  | 62  | 38  | 573    |
| 90%     | 40  | 19  | 14  | 15  | 31  | 62  | 89  | 101 | 86  | 72  | 65  | 43  | 729    |
| Max     | 54  | 94  | 138 | 221 | 161 | 162 | 100 | 117 | 201 | 197 | 127 | 94  | 1,390  |
| Average | 28  | 14  | 13  | 16  | 18  | 39  | 68  | 75  | 62  | 58  | 53  | 34  | 477    |

6

1 **Table 21-8h. Monthly Cumulative Distributions of Estimated Hyatt and Thermalito (combined) Power**  
 2 **Plant Energy Generation (GWh) for Existing Conditions**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 26  | 20  | 21  | 19  | 20  | 19  | 47  | 54  | 109 | 40  | 40  | 33  | 721    |
| 10%     | 36  | 25  | 26  | 23  | 31  | 24  | 72  | 103 | 141 | 219 | 80  | 56  | 1,183  |
| 20%     | 41  | 33  | 42  | 28  | 40  | 39  | 92  | 118 | 155 | 295 | 143 | 75  | 1,447  |
| 30%     | 68  | 49  | 54  | 46  | 50  | 58  | 97  | 125 | 173 | 354 | 194 | 116 | 1,559  |
| 40%     | 89  | 55  | 56  | 55  | 54  | 73  | 105 | 127 | 190 | 395 | 261 | 148 | 1,815  |
| 50%     | 114 | 70  | 59  | 58  | 57  | 138 | 116 | 133 | 212 | 415 | 273 | 160 | 1,985  |
| 60%     | 131 | 82  | 92  | 59  | 103 | 201 | 126 | 139 | 234 | 424 | 300 | 255 | 2,470  |
| 70%     | 142 | 85  | 121 | 67  | 212 | 248 | 153 | 193 | 250 | 451 | 310 | 320 | 2,880  |
| 80%     | 156 | 89  | 156 | 199 | 379 | 357 | 226 | 329 | 271 | 471 | 325 | 376 | 3,337  |
| 90%     | 169 | 94  | 229 | 540 | 563 | 549 | 358 | 481 | 350 | 490 | 336 | 416 | 3,581  |
| Maximum | 223 | 561 | 670 | 669 | 623 | 671 | 666 | 698 | 569 | 508 | 377 | 441 | 4,777  |
| Average | 107 | 75  | 119 | 148 | 182 | 203 | 170 | 216 | 232 | 380 | 244 | 217 | 2,292  |

3

#### 4 **21.1.3.2 CVP and SWP Energy Use for Water Pumping**

5 The monthly CVP and SWP energy use for pumping water from the Delta into the Delta-Mendota  
 6 Canal and California Aqueduct can be reliably estimated from the monthly pumping flows (TAF) at  
 7 each of the CVP and SWP pumping plants. The pumping energy used at the Gianelli Pumping Plant to  
 8 seasonally store CVP and SWP water in San Luis Reservoir depends on the San Luis Reservoir  
 9 elevation (water head) estimated from storage. There is some generation of energy at the Gianelli  
 10 and O'Neill Power Plant as water is released from San Luis Reservoir during the summer months.  
 11 There is considerable generation of energy at other SWP power plants along the East and West  
 12 Aqueducts, which recover some of the energy required to pump water over the Tehachapi  
 13 Mountains. The net energy required for CVP pumping and for SWP pumping can be calculated from  
 14 the monthly sequence of flows simulated by CALSIM-II for each alternative. As discussed in Section  
 15 21.1, *Environmental Setting/Affected Environment*, the energy calculations based on CALSIM-II  
 16 presented in this chapter represent a reasonable, though overestimated, assessment of actual  
 17 energy requirements for the BDCP alternatives.

18 The net energy use for CVP deliveries and SWP deliveries can be calculated from the average CVP  
 19 Jones pumping (TAF/yr) and the average SWP Banks Pumping. The distribution of CVP water to  
 20 each contractor is somewhat variable from year to year but the average energy use reflects the  
 21 normal portion of the deliveries that are seasonally stored in San Luis Reservoir. The Existing  
 22 Conditions CALSIM-II results were used as an example of the baseline to calculate the CVP and SWP  
 23 energy generation and pumping uses for south of Delta CVP and SWP water deliveries. The energy  
 24 analysis assumes that the upstream operations and energy generation for Existing Conditions and  
 25 the No Action Alternative (2060) would be the same since upstream generation is a function of  
 26 runoff and reservoir elevations. The net energy use factor (MWh/TAF) for south of Delta CVP and  
 27 SWP water deliveries is assumed to remain the same for each of the other baselines and for each of  
 28 the BDCP alternatives; the energy use for south of Delta water deliveries will vary with the annual  
 29 deliveries. Because each of the baselines have different average annual water deliveries, the CEQA

1 Existing Conditions (2010) and the NEPA No Action Alternative (2060) each have slightly different  
2 average energy uses for south of Delta water deliveries.

### 3 **21.1.4 Energy Transmission for the BDCP Pumping Plants**

4 In California, energy is generated throughout the state and is owned or sold to utility companies  
5 within defined areas of service and other users. Electric energy is distributed to consumers by the  
6 electrical grid, which is made up of transmission lines (High Voltage for long distance) and  
7 distribution lines (Low Voltage for short distance). Substations take high voltage energy from the  
8 transmission lines and reduce the voltage for distribution lines. There are several Balancing  
9 Authorities (BA) that operate within the state, including the CAISO and Balancing Authority of  
10 Northern California (BANC). The BAs are responsible for ensuring there are sufficient resources to  
11 balance the grid within their jurisdictional areas. The CAISO provides transmission access and a  
12 power market within its BA Area. Scheduling and management of transmission and energy for the  
13 BDCP would be similar to scheduling and management of transmission and energy for the CVP and  
14 SWP pumping plants in the south Delta. The additional energy needed for the BDCP alternatives  
15 would be provided from the power portfolios of SWP and CVP and in proportion to their  
16 participation in BDCP. Energy needed for pumping water would be provided from a mix of CVP and  
17 SWP hydroelectric generation, power purchase contracts, power exchanges, and power markets.

18 Three electric utilities could potentially provide transmission interconnection and service to  
19 support the supply of power to the BDCP: Sacramento Municipal Utility District (SMUD), Pacific Gas  
20 and Electric Company (PG&E) (under the CAISO BA) and Western. DWR has the flexibility to  
21 regulate SWP pumping on an hourly basis and thus manages the system to make the most economic  
22 decisions for acquisition of power. By scheduling as much off-peak pumping as possible, DWR is able  
23 to take advantage of less expensive surplus electrical generation. Conversely, DWR maximizes its  
24 power generation for the benefit of the interconnected electrical grid during the on-peak hours  
25 when electrical demand is highest. In this manner, DWR is able to manage a comprehensive power  
26 resources program that helps minimize the cost of water deliveries to SWP water supply contractors  
27 while maximizing the benefits of the statewide electrical grid.

28 DWR will conduct a System Impact Study which will evaluate the electrical transmission and power  
29 needed for the conveyance facilities. The study will be completed in time to procure the necessary  
30 power to support construction and operation of the facilities. Typically, DWR's power and planning  
31 process begins with a review of all projected loads and resources including pump load, generation  
32 from DWR's facilities, generation from joint facilities, sales purchases, and exchanges. The net of  
33 these loads and resources yields a power portfolio in which DWR often has a net deficit during the  
34 off-peak hours and a net surplus during the on-peak hours. This System Impact Study for BDCP is  
35 expected to take between five and seven years. Impacts that may result from the construction and  
36 operation of new transmission infrastructure are addressed throughout the individual resource  
37 sections.

38 Electrical power for new north Delta pumping plant facilities would be delivered through a single  
39 230 kV transmission line, owned by either a utility or the BDCP, which would interconnect with  
40 either Western or PG&E at a new or existing utility substation depending on the conveyance  
41 alignment and whichever utility can provide the requisite transmission facilities, connections, and  
42 service according to the construction schedule. Some utility grid upgrade would likely be needed to  
43 accommodate this large new pumping energy requirement. The new or upgraded transmission line  
44 would terminate at the new 230 kV substation that would be constructed as part of the BDCP. There,

1 the electrical power would be transformed from 230 kV to 69 kV and delivered on new overhead 69  
2 kV transmission lines to the pumping plants.

## 3 **21.2 Regulatory Setting**

4 Energy generation at CVP facilities is managed by Western. SWP energy generation is managed and  
5 sold by DWR. Regulations applicable to energy generation and transmission that are relevant to  
6 evaluating the potential impacts of the BDCP alternatives on energy generation and use are  
7 discussed in this section.

### 8 **21.2.1 Federal Plans, Policies, and Regulations**

#### 9 **21.2.1.1 Federal Energy Regulatory Commission**

10 The Federal Energy Regulatory Commission (FERC) regulates transmission of oil, natural gas, and  
11 electricity in interstate commerce. FERC also licenses and inspects private, municipal, and state  
12 hydropower projects, and supervises environmental concerns related to hydroelectricity and major  
13 electricity policy initiatives. FERC monitors and investigates energy markets and ensures the  
14 reliability of interstate transmission systems (Federal Energy Regulatory Commission 2006). The  
15 energy utilities in the Delta region are subject to the regulations of FERC.

16 FERC passed Order No. 888 and Order No. 889 in April 1996. These orders work to establish fair  
17 competition of the wholesale power marketplace and establish lower cost power for consumers in  
18 the United States. Order No. 888 requires utilities that own, control, or operate interstate electric  
19 energy transmission facilities to have open access, nondiscriminatory tariffs on transmission. Order  
20 No. 888 also allows public utilities and transmitting utilities to seek the recovery of stranded costs  
21 associated with providing open access and Federal Power Act Section 211 transmission services.  
22 Order No. 889 requires public utilities and transmitting utilities that own, control, or operate  
23 interstate electric energy transmission facilities to create or participate in an Open Access Same-  
24 Time Information System program. Such programs provide existing and potential open access  
25 transmission customers with available transmission capacity, price, and additional information to  
26 enable them to obtain open access nondiscriminatory transmission service (Federal Energy  
27 Regulatory Commission 2009a, 2009b).

#### 28 **Licensing for Oroville Facilities**

29 DWR is currently implementing the Settlement Agreement developed during the FERC relicensing  
30 process for the Oroville facilities on the Feather River to continue to own, operate, and maintain  
31 them. FERC has the authority to license the construction and operation of non-federal hydroelectric  
32 development. Although no additional facilities are planned for Oroville, DWR's license application  
33 proposes several programs to enhance habitats, improve recreational use of the facilities, and  
34 address the protection of cultural resources (California Department of Water Resources 2006).  
35 Oroville is the only facility in the study area to have recently undergone the relicensing process.

#### 36 **21.2.1.2 Western Area Power Administration**

37 Western markets and delivers power from multiuse water projects that are operated by  
38 Reclamation, the U.S. Army Corps of Engineers (USACE), and the International Boundary and Water

1 Commission. Western markets and delivers CVP's installed capacity of 2,099 MW through 865  
2 circuit-miles of transmission lines (Western Area Power Administration 2009). Western is  
3 organized into five regions throughout the western and central United States. The CVP is within  
4 Western's Sierra Nevada Region.

### 5 **21.2.1.3 Other**

6 Many of the energy operations within the Delta are subject to the following federal acts: the Rivers  
7 and Harbors Appropriation Act of 1899, Section 10; the Rivers and Harbors Act of 1935; the Rivers  
8 and Harbors Act of 1937; the Rivers and Harbors Act of 1940; the Auburn-Folsom South Unit  
9 Authorization Agreement; the Emergency Relief Appropriation Act of 1935; the Flood Control Act of  
10 1944; the Federal Endangered Species Act; and the Central Valley Project Improvement Act (CVPIA)  
11 Section 3406 (b)(2). The Rivers and Harbors Appropriation Act of 1899 assigned the USACE  
12 responsibility for the regulation of navigable waters of the United States. In 1935, the federal  
13 government approved the Emergency Relief Appropriation Act and in doing so approved \$20 million  
14 in Emergency Relief Funds for the CVP. The Flood Control Act of 1944 approved the construction of  
15 the Shasta, Folsom, and New Melones Dams for the CVP.

16 The Rivers and Harbors Act of 1937 reauthorized the CVP and stated purposes of the project. Energy  
17 operations within the statutory Delta are also subject to regulations within the CVPIA. These acts are  
18 discussed further in Chapter 5, *Water Supply*, Section 5.2.1. Congress adopted the Auburn-Folsom  
19 South Unit Authorization Agreement in 1965 to authorize the construction and operation of the  
20 Auburn-Folsom South Unit and the development of recreational facilities associated with the unit.  
21 This agreement is further discussed in Chapter 5, *Water Supply*, Section 5.2.1. Energy operations are  
22 also subject to the Federal Endangered Species Act, which is discussed in Chapter 11, *Fish and*  
23 *Aquatic Resources*, Section 11.2.1.1, and Chapter 12, *Terrestrial Biological Resources*, Section 12.2.1.2.

## 24 **21.2.2 State Plans, Policies, and Regulations**

### 25 **21.2.2.1 California Public Utilities Commission**

26 The California Public Utilities Commission (CPUC) regulates utilities to establish safe and reliable  
27 utility service, protect consumers against fraud, provide service at reasonable costs, and promote a  
28 healthy state economy. The CPUC regulates privately owned natural gas, electric,  
29 telecommunications, water, railroad, rail transit, and passenger transportation companies  
30 (California Public Utilities Commission 2007). The CPUC does not, however, regulate CVP or SWP  
31 energy facilities or pumping plants.

### 32 **21.2.2.2 California Independent System Operator**

33 CAISO was created in 1996 by an act of California Legislature and became operational in 1998 as a  
34 not-for-profit public benefit corporation to act as the independent operator of California's  
35 transmission grid. While transmission lines remain owned by utility companies, CAISO ensures that  
36 non-discriminatory open access to transmission service is available to all users. Starting in 2009,  
37 CAISO manages transmission congestion through use of locational marginal pricing and manages an  
38 integrated forward market for energy purchases and sales. Additionally, CAISO coordinates  
39 transmission usage and energy flows with neighboring Balancing Authorities. (California  
40 Independent System Operator 2009).

### 1    **21.2.2.3           California Energy Commission**

2       The Warren-Alquist Energy Resources Conservation and Delivery Act, also called the Warren-  
 3       Alquist Act, was passed in 1974. The Warren-Alquist Act established the CEC and granted it  
 4       statutory authority (California Energy Commission 2009b).The CEC promotes energy efficiency  
 5       throughout the state, supports renewable energy and public interest energy research, and plans and  
 6       directs the state’s responses to energy emergencies. The CEC provides one-stop permitting for new  
 7       energy facilities. The CEC also regulates the state’s energy operations and provides funds for a  
 8       variety of technologies that would reduce greenhouse gases (GHGs) (California Energy Commission  
 9       2009a).

### 10   **21.2.2.4           CEQA Guidelines**

11       State CEQA guidelines Appendix F, *Energy Conservation*, outlines analysis requirements for the  
 12       evaluation of potential energy impacts of proposed projects. Particular emphasis is placed on  
 13       “avoiding or reducing inefficient, wasteful, and unnecessary consumption of energy.” Moreover, the  
 14       CEQA guidelines state that significant energy impacts should be “considered in an EIR to the extent  
 15       relevant and applicable to the project.” The review of potential impacts should include a discussion  
 16       of project energy requirements, effects on local and regional energy supplies, effects on peak and  
 17       base period demands, compliance with energy standards, and effects on energy resources.  
 18       Alternatives should be compared in terms of total and inefficient energy use. Mitigation for potential  
 19       significant energy impacts could include a variety of strategies, including measures to reduce  
 20       wasteful energy consumption and project siting.

## 21   **21.3   Environmental Consequences**

22       This section describes the potential effects of the BDCP alternatives on energy generation at CVP and  
 23       SWP hydropower facilities and energy uses for water supply pumping plants. The estimated  
 24       electrical energy required for construction of the water conveyance facilities associated with BDCP  
 25       are also described. The relatively large energy requirements for pumping CVP and especially SWP  
 26       water supplies from the Delta are well described and understood (California Energy Commission  
 27       2005; Natural Resources Defense Council 2004).

28       Effects on energy production and use have been evaluated for the existing CVP and SWP facilities, as  
 29       well as the additional BDCP conveyance and pumping facilities. The existing transmission lines,  
 30       switching stations, and substations have been designed and constructed to accommodate the normal  
 31       seasonal patterns of energy generation at the CVP and SWP hydropower facilities and the electrical  
 32       energy uses at water supply pumping plants. Because the additional energy requirements for the  
 33       BDCP conveyance facilities are moderate relative to the normal seasonal energy transmission  
 34       capacity, there would not likely be any substantial impacts on electrical grid capacity or electrical  
 35       grid reliability associated with the increased energy uses for the BDCP alternatives.

36       The potential effects of the BDCP are discussed under 2025 and 2060 conditions. Potential effects of  
 37       climate change on hydrology (runoff and sea level rise) may modify BDCP operations and cause the  
 38       BDCP alternatives to have slightly different energy effects within these two future periods. Results  
 39       from the monthly CALSIM-II water resources model were used to provide the monthly flows and  
 40       diversions for each BDCP alternative at each time frame so that monthly and annual electrical  
 41       energy budgets could be calculated and compared.

1 The following energy effects have been evaluated.

- 2 • Monthly or annual changes in hydroelectric energy generation that would affect the regional  
3 energy supply.
- 4 • Monthly or annual increases in energy consumption (pumping) that would affect the regional  
5 energy consumption.
- 6 • Monthly or annual changes in energy use that would cause additional energy generation at  
7 facilities with higher pollutant or GHGs emissions during operation (or construction). These are  
8 considered more fully in Chapter 22, *Air Quality and Greenhouse Gases*, Sections 22.3.3.2 through  
9 22.3.3.16.

## 10 **21.3.1 Methods for Analysis**

11 This section discusses the methods to analyze the electrical energy required for the construction of  
12 the water conveyance facilities (CM1) and the additional energy required for pumping at the  
13 alternative BDCP north Delta intakes and associated conveyance facilities. The additional energy  
14 would be related to the monthly north Delta pumping patterns for each alternative, and would  
15 depend on the hydraulic head losses associated with each conveyance alignment (pipeline/tunnel,  
16 east, or west). Larger pumps and a greater canal/tunnel capacity would be required for alternatives  
17 with higher maximum flows. The required monthly pumping energy would be proportional to the  
18 monthly water flow volume and will depend on the pumping head (lift) necessary for each  
19 conveyance alternative.

### 20 **21.3.1.1 Construction**

21 Electrical energy needs for construction were evaluated based on the estimated annual energy  
22 required for each alternative. The construction energy requirements were estimated from the  
23 facilities that would require electrical energy during construction, as described in DWR design  
24 documents for each alternative. The construction-related energy demand is considered temporary  
25 (i.e., will cease once construction is complete). Construction of the water conveyance facility would  
26 require the use of electricity for lighting, tunnel ventilation, tunnel boring, earth removal from the  
27 tunnels, and other construction machinery. Annual electrical energy use estimates for each  
28 alternative were provided by DWR and are summarized in Table 21-9.

1 **Table 21-9. Temporary Annual Electrical Use Estimates for Construction (GWh)**

| Alternative  | Year 1 | Year 2 | Year 3 | Year 4 | Year 5 | Year 6 | Year 7 | Year 8 <sup>a</sup> | Year 9 <sup>a</sup> |
|--|--------|--------|--------|--------|--------|--------|--------|---------------------|---------------------|
| Alternative 1A, 2A, 6A<br>(15,000 cfs, 2 33-ft<br>Tunnels)           | 20     | 32     | 56     | 220    | 324    | 376    | 236    | 81                  | 81                  |
| Alternative 4<br>(9,000 cfs, 2 40-ft<br>Tunnels)                     | 74     | 197    | 345    | 449    | 480    | 483    | 363    | 129                 | 28                  |
| Alternative 7, 8 (9,000<br>cfs, 2 33-ft Tunnels)                     | 13     | 21     | 45     | 209    | 314    | 366    | 231    | 78                  | 78                  |
| Alternative 3<br>(6,000 cfs, 2 33-ft<br>Tunnels)                     | 10     | 16     | 40     | 204    | 308    | 361    | 228    | 77                  | 77                  |
| Alternative 5<br>(3,000 cfs, 1 33-ft<br>Tunnel)                      | 7      | 11     | 24     | 112    | 170    | 197    | 124    | 43                  | 43                  |
| Alternative 1C, 2C, 6C<br>(West Alignment)                           | 22     | 34     | 45     | 121    | 169    | 196    | 120    | 42                  | 42                  |
| Alternative 1B, 2B, 6B<br>(East Alignment)                           | 22     | 41     | 66     | 83     | 70     | 62     | 26     | 18                  | 18                  |
| Alternative 9 <sup>b</sup><br>(Through Delta/<br>Separate Corridors) | 11     | 21     | 33     | 42     | 35     | 31     | 13     | -                   | -                   |

- No construction

<sup>a</sup> DWR estimated electrical use to be one-quarter of year 5 use.

<sup>b</sup> DWR estimated electrical use to be one-half of Alternatives 1B, 2B, 6B (east alignment).

2

3 **21.3.1.2 Operation**

4 Energy effects from BDCP operations are generally evaluated as a reduction in the amount of  
5 hydropower energy generated or as the increase in energy use because this additional energy must  
6 be supplied from other energy sources that may have subsequent environmental consequences  
7 (land disturbance, air pollution, GHG impacts) and higher costs (economic effects). Energy effects  
8 were evaluated under 2025 and 2060 conditions because potential effects of climate change on  
9 hydrology (runoff and sea level rise) may modify the BDCP operations and cause the BDCP  
10 alternatives to have slightly different energy effects for these two future timeframes. The potential  
11 energy of a water volume that is pumped to a higher elevation is calculated as the weight of water  
12 (gravity) times the elevation difference plus losses (Total Dynamic head). Conveniently, the  
13 potential energy of 1 af of water with 1 foot of head is equal to 2,712,481 lb<sub>f</sub>/ft<sup>3</sup>. Also, 1 kWh of  
14 Energy is equal to 2,655,224 ft-lb<sub>f</sub>. Therefore, the energy required to pump 1 af of water can be  
15 estimated as:

$$16 \quad \text{Energy (kWh/af)} = 1.02 * \text{Total Dynamic Head (feet)} / \text{pumping efficiency}$$

17 Pumping efficiency represent the wire to water efficiency of a Motor/pump setup and could be in  
18 the 80–90% range. For simple calculations, the formula above can be simplified by ignoring head  
19 losses (and use elevation head instead), and the 1.02 coefficient, which results in

1           Energy (kWh/af) = elevation head (feet) / pumping efficiency

2           For example, the energy required to pump water at the CVP Jones pumping plant is estimated to be  
3           about 252 kWh/af because the elevation head is about 197 feet and the efficiency is about 78%  
4           (Table 21-2). The pumping energy factor for the SWP Banks pumping plant is estimated to be about  
5           279 kWh/af because the elevation head is about 252 feet and the efficiency is about 90% (Table 21-  
6           6).

7           The CALSIM-II monthly volumes (TAF) diverted (pumped) at the north Delta intakes for each BDCP  
8           alternative were used to calculate the monthly and annual energy requirements. Energy effects were  
9           then evaluated from these monthly and annual energy requirements for each BDCP alternative  
10          compared to Existing Conditions and No Action Alternative. As described above, the upstream CVP  
11          and SWP energy generation was assumed to be very similar for each of the BDCP baselines and  
12          alternatives, because the upstream reservoir operations are largely controlled by natural runoff  
13          conditions. The energy requirements for the CVP and SWP south Delta pumping plants (total Delta  
14          exports) may shift with the BDCP alternatives, because the monthly and annual exports may shift.  
15          The energy requirements for pumping and seasonal storage in San Luis Reservoir would remain  
16          similar for CVP and SWP deliveries. Therefore, the changes in energy requirements for each BDCP  
17          alternative will depend on the CALSIM-II simulated north Delta diversions and the total CVP and  
18          SWP Delta exports. The baseline (Existing Conditions or No Action Alternative) energy generation  
19          and pumping energy factor for CVP and SWP south of Delta pumping have been described in Section  
20          21.1, *Environmental Setting/Affected Environment*.

21          The energy requirements were estimated from the monthly north Delta pumping operations  
22          simulated with the monthly CVP and SWP operations model (CALSIM-II) for each alternative. The  
23          monthly energy requirements were calculated by multiplying the monthly pumping volume (TAF)  
24          by the energy requirement per water volume pumped, referred to as the pumping energy factor  
25          (MWh/TAF). The pumping energy factor could be different for each alternative. The pumping  
26          energy factor for the intake pumps and for canal sections would remain constant. The pumping  
27          energy factor for a tunnel or pipeline section will increase as the flow is increased, because the head  
28          loss in a pipeline or tunnel section is proportional to the water velocity squared. The derivation of  
29          these energy factors for each alternative is summarized below.

30          Alternatives 1A, 2A, and 6A would include two 35-mile long tunnels with inside diameters of 33 feet,  
31          constructed between the north Forebay near Hood and the Byron Tract Forebay, adjacent to Clifton  
32          Court Forebay. Five screened intake facilities located along the Sacramento River between Freeport  
33          and Courtland, with a pumping capacity of 3,000 cfs each, would be constructed with pipelines or  
34          canals connecting these intakes and pumping plants to the north (intermediate) Forebay. The  
35          intermediate Forebay will have a water surface elevation of about 25 feet (NAVD 88 datum) and will  
36          provide temporary storage to regulate the tunnel flow and allow a pumping schedule that might  
37          vary with the tides. The intermediate Forebay provides enough energy head (water elevation) to  
38          allow some water to flow by gravity to the Byron Tract Forebay, which would have a water surface  
39          elevation of 0–5 feet. Preliminary hydraulic calculations indicate that a flow of about 3,000 cfs in  
40          each of the 33-foot diameter tunnels would be possible under gravity. Additional pumping will be  
41          required for higher flows.

42          The Darcy-Weisbach energy loss equation for pipes was used to estimate the head losses for the 33-  
43          foot diameter tunnels, with a Darcy friction factor of 0.0125 corresponding to relatively smooth  
44          (concrete lined) tunnels. The Darcy-Weisbach formula is:

1           Energy loss (ft) = f x Length (ft) x Velocity <sup>2</sup>/ [Diameter (ft) x 2 g]

2           Where f is the friction coefficient (0.0125 assumed), velocity has units of ft/sec, and g is the  
3           gravitational force of 32.2 (ft/sec<sup>2</sup>). Table 21-10 shows the energy loss calculations for a 33-foot  
4           diameter tunnel (35 miles long). This was the basis for estimating the gravity flow capacity, the  
5           capacity and lift for the low-lift pumps, and the maximum lift for the high-lift pumps (with a  
6           maximum capacity of 7,500 cfs).

7           **Table 21-10. Energy Losses for Flow of 500 cfs to 7,500 cfs in a 35-mile Tunnel, Estimated with the**  
8           **Darcy-Weisbach Pipe Formula**

| 35-mile Tunnel 33-foot Diameter |                   |                    | 35-mile Tunnel 40-foot Diameter |                   |                    |
|---------------------------------|-------------------|--------------------|---------------------------------|-------------------|--------------------|
| Flow (cfs)                      | Velocity (ft/sec) | Energy Loss (feet) | Flow (cfs)                      | Velocity (ft/sec) | Energy Loss (feet) |
| 500                             | 0.6               | 0.4                | 500                             | 0.4               | 0.1                |
| 1,000                           | 1.2               | 1.5                | 1,000                           | 0.8               | 0.6                |
| 1,500                           | 1.8               | 3.3                | 1,500                           | 1.2               | 1.3                |
| 2,000                           | 2.3               | 5.9                | 2,000                           | 1.6               | 2.3                |
| 2,500                           | 2.9               | 9.3                | 2,500                           | 2.0               | 3.5                |
| 3,000                           | 3.5               | 13.4               | 3,000                           | 2.4               | 5.1                |
| 3,500                           | 4.1               | 18.2               | 3,500                           | 2.8               | 7.0                |
| 4,000                           | 4.7               | 23.8               | 4,000                           | 3.2               | 9.1                |
| 4,500                           | 5.3               | 30.1               | 4,500                           | 3.6               | 11.5               |
| 5,000                           | 5.8               | 37.1               | 5,000                           | 4.0               | 14.2               |
| 5,500                           | 6.4               | 44.9               | 5,500                           | 4.4               | 17.2               |
| 6,000                           | 7.0               | 53.5               | 6,000                           | 4.8               | 20.4               |
| 6,500                           | 7.6               | 62.8               | 6,500                           | 5.2               | 24.0               |
| 7,000                           | 8.2               | 72.8               | 7,000                           | 5.6               | 27.8               |
| 7,500                           | 8.8               | 83.6               | 7,500                           | 6.0               | 31.9               |

9

10           Alternatives 1A, 2A, and 6A would have two sets of pumps at the intermediate Forebay to provide  
11           two pumping options: 1) additional energy head (lift) of about 25 feet for a total energy head of  
12           about 50 feet, which would allow a maximum flow of 4,500 cfs (capacity of low-head pumps) in each  
13           tunnel, and 2) additional energy head (lift) of 65 feet for a total energy head of about 90 feet, which  
14           would allow a maximum flow of 7,500 cfs in each tunnel. When low-head or high-head pumping is  
15           required, all the tunnel flow must be pumped. This dual-pumping design will reduce the energy  
16           required, because no intermediate pumping will be required for daily average flows of less than  
17           6,000 cfs, and only a moderate pumping energy (25 feet) will be required for daily average flows of  
18           6,000 cfs to 9,000 cfs. Full pumping energy (65 feet) will be required for daily flows of more than  
19           9,000 cfs. The intake pumps will lift the water to the intermediate Forebay and this pumping energy  
20           will be required for any daily flow. Flows of less than 6,000 cfs will have a pumping energy factor of  
21           about 65 MWh/TAF, assuming an average lift of 50 feet with an efficiency of about 0.8. Flows of  
22           6,000 cfs to 9,000 cfs will have an energy factor of about 95 MWh/TAF, and flows of more than  
23           9,000 cfs will have an energy factor of about 145 MWh/TAF.

24           The CALSIM-II results for monthly pumping at the north Delta intakes were used to estimate the  
25           monthly energy use for Alternative 1A, 2A, 6A. Figure 21-3 shows the monthly north Delta pumping  
26           flows for Alternative 1A under 2025 conditions. Most of the months (75%) had flows of less than

1 6,000 cfs and would require only intake pumping with an energy factor of 65 MWh/TAF. About 10%  
2 of the months had flows between 6,000 cfs and 9,000 cfs, and would require intake pumping and  
3 low-head intermediate pumping with an energy factor of 95 MWh/TAF. About 10% of the months  
4 had flows of greater than 9,000 cfs and would require intake pumping and high-head intermediate  
5 pumping, with an energy factor of 145 MWh/TAF. Figure 21-4 shows the relationship between  
6 monthly pumping flow (cfs) and monthly pumping energy (GWh) for Alternative 1A under 2025  
7 conditions. The monthly energy generally increases with monthly flow, but the slope of the  
8 relationship is greater for flows that require the low-head intermediate pumping (6,000 cfs to 9,000  
9 cfs) or the high-head intermediate pumping (9,000 cfs to 15,000 cfs). The average energy factor for  
10 Alternative 1A under 2025 conditions was calculated to be 105 MWh/TAF, because about 37% of  
11 the water volume would require just the intake pumping, 23% of the water volume would require  
12 intake pumping and low-head intermediate pumping, and 40% of the water volume would require  
13 intake pumping and high-head intermediate pumping.

14 The pumping energy factors for Alternative 2A and 6A would be slightly different than for  
15 Alternative 1A because the monthly north Delta pumping flows simulated with CALSIM-II were  
16 different. The average energy factor for Alternative 2A was calculated to be about 112 MWh/TAF.  
17 The average energy factor for Alternative 6A was calculated to be about 115 MWh/TAF. More  
18 months with simulated north Delta pumping flows of greater than 6,000 cfs will increase the  
19 average energy factor for these alternatives.

20 Alternatives 1B, 2B and 6B include five intakes pumping to a canal section on the east side of the  
21 Sacramento River, with a water surface elevation of about 20 feet (NAVD 88). The canal would have  
22 a slope of less than 6 inches per mile (similar to the Delta-Mendota Canal and the California  
23 Aqueduct), but there would be about 2.5 miles of dual 33-foot diameter tunnels and about 3 miles of  
24 large culverts (four adjacent 26 feet x 26 feet box culverts) that would cause additional energy  
25 losses, designed for the maximum flow of 15,000 cfs. Therefore, an intermediate pumping plant with  
26 a lift of about 30 feet would be required. Because all flows will require these two pumping lifts at the  
27 intakes and at the intermediate pumping plant (50 feet total), the pumping energy factor for  
28 Alternative 1B would be about 65 MWh/TAF).

29 Alternatives 1C, 2C, and 6C include five intakes pumping to a canal section on the west side of the  
30 Sacramento River, with a water surface elevation of about 30 feet (NAVD 88). The canal will have a  
31 slope of less than 6 inches per mile, but there would be 17 miles of dual 33-foot diameter tunnels  
32 and about 3 miles of large culverts (four adjacent 26 feet x 26 feet box culverts) that would cause  
33 additional energy losses, designed for the maximum flow of 15,000 cfs. Therefore, an intermediate  
34 pumping plant with a lift of about 55 feet would be required. Because the canal water surface at the  
35 intermediate pumping plant will be about 15 feet (NAVD 88) and the Byron Tract Forebay elevation  
36 will be about 5 feet, there is the possibility of about 2,500 cfs of gravity flow; however Alternative 1C  
37 does not include a gravity flow bypass. Therefore, all flows will require these two pumping lifts at  
38 the intakes and at the intermediate pumping plant (85 feet total), and the pumping energy factor for  
39 Alternative 1C would be about 110 MWh/TAF.

40 Alternative 3 includes two intakes for a maximum capacity of 6,000 cfs. The intermediate Forebay  
41 and two 33-foot diameter tunnels would be the same as for Alternative 1A. Because a maximum of  
42 6,000 cfs would be pumped, the tunnels would operate under gravity flow without the need for  
43 intermediate pumping. Therefore, the pumping energy factor for Alternative 3 would be about 65  
44 MWh/TAF.

1 Alternative 4 includes three intakes for a maximum capacity of 9,000 cfs with the intermediate  
2 Forebay with a water surface elevation of 25 feet (NAVD 88). The two tunnels from the intermediate  
3 Forebay to the proposed expanded Clifton Court Forebay will be larger, with inside diameters of 40  
4 feet, to allow the maximum flow of 9,000 cfs to flow in the tunnels under gravity, without the need  
5 for intermediate pumping (Table 21-10). The intake pumping energy factor would be about 65  
6 MWh/TAF. The construction energy required for boring and spoils disposal for these larger tunnel  
7 sections would be higher (see Table 21-9). DOE has estimated that the 40-foot diameter tunnel  
8 construction energy (2,549 GWh) would be about 78% more than the electrical energy needed for  
9 construction of the water conveyance facilities associated Alternatives 1A, 2A and 6A (1,428 GWh).  
10 The additional construction energy will allow the pumping energy factor for Alternative 4 to be  
11 reduced to intake pumping alone (65 MWh/TAF). Without the larger tunnels, Alternative 4 would  
12 have required the intermediate low-head pumping plant for flows of more than 6,000 cfs; the  
13 additional energy was calculated to be about 50 GWh per year, which would be “recovered” after 25  
14 years of Alternative 4 operation.

15 Alternative 5 includes one intake and one 33-foot diameter tunnel. The flow in the tunnel will be less  
16 than the gravity flow capacity (Table 21-10) so the energy factor for Alternative 5 would be about  
17 65 MWh/TAF.

18 Alternatives 7 and 8 will have three intakes (9,000 cfs capacity) with two 33-foot diameter tunnels;  
19 the energy factor would be 65 MWh/TAF for flows of less than 6,000 cfs and would be 95 MWh/taf  
20 for flow of greater than 6,000 cfs. The average energy factor for Alternative 7 was calculated to be  
21 83 MWh/taf. The average energy factor for Alternative 8 was calculated to be 86 MWh/taf. More  
22 months with simulated north Delta pumping flows of greater than 6,000 cfs will increase the  
23 average energy factor for these alternatives.

24 Alternative 9 requires additional pumping energy to provide a constant pumping flow of 500 cfs (1  
25 taf per day) between tidal channels that would be separated with barriers in the south Delta.  
26 Although the difference in water elevations will be less than 5 feet, DOE estimated that the pumping  
27 energy (lift) would be about 35 feet (energy factor of about 44 MWh/TAF); the additional pumping  
28 energy for Alternative 9 was estimated to be a constant 2 MW (18 GWh/yr).

### 29 **21.3.2 Determination of Effects**

30 The effects of the BDCP alternatives on energy consumption may result from both construction and  
31 operation of the BDCP features. Alternative 1A, which includes a tunnel conveyance from five north  
32 Delta intakes to the south Delta pumping plants, would require about 182 MW of power (capacity)  
33 to pump and transport a maximum flow of 15,000 cfs from the Sacramento River near Hood to the  
34 existing CVP and SWP pumps near Tracy through a tunnel conveyance. DWR has determined that  
35 the maximum pumping energy factor for the 15,000 cfs tunnel would be about 145 MWh/TAF.  
36 Pumping about 30 TAF/day would therefore require 4,350 MWh per day of energy, with a maximum  
37 power of 182 MW. The daily energy requirement would depend on the daily pumping volume.

38 The west alignment (Alternatives 1C, 2C, and 6C, which include several tunnel sections) would  
39 require about 132 MW of additional power (capacity) to pump a maximum flow of 15,000 cfs. DWR  
40 has determined that the pumping energy factor for the 15,000 cfs west alignment would be about  
41 110 MWh/TAF. Pumping about 30 TAF/day would therefore require 3,300 MWh per day of energy,  
42 with a maximum power of 138 MW. The daily energy requirement would depend on the daily  
43 pumping volume.

1 The east alignment (Alternatives 1B, 2B, and 6B) would require about 82 MW of additional power  
2 (capacity) to pump a maximum flow of 15,000 cfs. DWR has determined that the pumping energy  
3 factor for the 15,000 cfs east alignment would be about 65 MWh/TAF. Pumping about 30 TAF/day  
4 would therefore require 1,950 MWh per day of energy, with a maximum power of 82 MW. The daily  
5 energy requirement would depend on the daily pumping volume.

6 The through Delta/separate corridors alignment (Alternative 9) would require about 2 MW of  
7 additional power (capacity) for circulation pumps (500 cfs capacity) in the south Delta. The SWP  
8 and CVP water supplies would be conveyed through the existing Delta channels as they are now  
9 conveyed (with tidal energy and gravity flow).

10 The amount of energy needed each year for an alternative would be proportional to the water  
11 pumped from the north Delta (times the energy factor assumed for each alternative) and the amount  
12 of water pumped from the south Delta (times the overall energy factor for the CVP and SWP  
13 deliveries). As described above, the overall energy factor for the CVP and the SWP is assumed to  
14 remain constant for all BDCP alternatives, so the overall energy use for pumping and delivery from  
15 the Delta would be proportional to the total Delta exports. The total energy use for an alternative  
16 will be calculated from the north Delta energy use added to the energy used for pumping and  
17 delivery of Delta exports to CVP and SWP contractors.

18 Total energy use for each BDCP alternative was compared to Existing Conditions and No Action  
19 Alternative to determine net energy use. At the south Delta, net energy use is directly related to the  
20 change in the total CVP and SWP Delta exports, and represents a greater utilization of the existing  
21 (2010) pumping facilities, rather than a new requirement for energy beyond the generating capacity  
22 of existing facilities. Because the existing CVP and SWP pumping facilities at the south delta have  
23 been planned and previously operated for a maximum monthly energy requirement that is greater  
24 than the energy requirement estimated for BDCP, increased use of the existing pumping facilities is  
25 not considered a new energy impact and is not discussed further.

26 Under State CEQA guidelines Appendix F, *Energy Conservation*, a project should consider the effects  
27 on the local and regional energy supplies and requirements for additional capacity. The review of  
28 these effects and the discussion of potential impacts should include particular emphasis on avoiding  
29 or reducing inefficient consumption of energy. Accordingly, for the purposes of this analysis, an  
30 adverse energy effect would occur if the project resulted in wasteful or unnecessary energy  
31 consumption during either construction or operation.

### 32 **21.3.2.1 Potential for New Energy Resources**

33 Power planning for loads within California is the responsibility of the CEC on a state-wide basis and  
34 the loads' Local Regulatory Authority (LRA) on a Load Serving Entity (LSE) basis. The CEC develops  
35 and adopts an Integrated Energy Policy Report (IEPR) every two years and an update every other  
36 year. Preparation of the IEPR involves close collaboration with federal, state, and local agencies and  
37 a wide variety of stakeholders in an extensive public process to identify critical energy issues and  
38 develop strategies to address those issues. The most recent report was completed in 2011 and was  
39 updated in 2012. BDCP facilities were not included in the studies for the 2011 IEPR or 2012 IEPR  
40 Update. However, with 270 MW as construction load and 57 MW as permanent load, the BDCP  
41 facilities would be approximately 0.40% and 0.09%, respectively, of the state's load. In addition, the  
42 BDCP construction load is less than one-half of the lower end of the annual growth rate for the  
43 state's load.

1 According to a final Order issued by the FERC on January 22, 2007, the SWP is considered a LSE for  
2 Resource Adequacy (RA) purposes. In response to an earlier Order from FERC, on August 31, 2006,  
3 DWR executive management signed documentation that established DWR as the LRA over the SWP.  
4 DWR most recent version of its RA Program, dated October 30, 2011, requires that the SWP comply  
5 with the CAISO Tariff Section 40.1 regarding RA requirements of an LSE within the CAISO's BA. Per  
6 the RA Program and CAISO Tariff, SWP submits demand forecasts to CEC and CAISO on a year-ahead  
7 and month-ahead basis. SWP also submits RA compliance demonstrations to the CAISO on a year-  
8 ahead and month-ahead basis. In addition, the RA Program includes a 15% Planning Reserve Margin  
9 on all firm load. Consequently, SWP will procure power and capacity for BDCP through long-term  
10 and mid-term contracts, and the CAISO power markets, sufficient to meet the power and RA capacity  
11 requirements of the CAISO Tariff and DWR's RA Program. The potential for new or expanded  
12 electrical power generation facilities is therefore not discussed in this section as it will be addressed  
13 through SWP power purchase programs.

### 14 **21.3.3 Effects and Mitigation Approaches**

15 A summary of average annual energy requirements for each BDCP alternative is provided in Table  
16 21-11. The average annual north Delta intake pumping and associated energy requirements for each  
17 BDCP alternative are summarized for easy comparison. The average annual Delta export pumping  
18 and associated energy uses for CVP and SWP water deliveries are also included in Table 21-11. This  
19 allows the average annual net energy use for each BDCP alternative to be compared to Existing  
20 Conditions and the No Action Alternative.

21 The pumping energy factor for south of Delta CVP and SWP water deliveries are identical under  
22 Existing Conditions and No Action Alternative (1.5 GWh/TAF/year). Likewise, no new energy  
23 demand at the North Delta would be created under Existing Conditions or the No Action Alternative.  
24 Accordingly, the CEQA (Existing Conditions) and NEPA (No Action Alternative) baselines have  
25 different total energy uses that are proportional to the simulated CVP and SWP exports (TAF).  
26 However, each of the baselines use the same amount of energy for each TAF of water deliveries. In  
27 other words, energy intensity for water deliveries under the NEPA and CEQA baselines is identical  
28 (1.5 GWh/TAF/year).

1 **Table 21-11. Summary of Annual Average Pumping (TAF) and Net Energy Use (GWh) for BDCP Alternatives <sup>a</sup>**

| BDCP Alternative                                  | Condition | North Delta Pumping (TAF/yr) | North Delta Energy (GWh) | Energy Factor (MWh/TAF) | Total Delta Pumping (TAF/yr) | South of Delta Energy (GWh) | Relative to NEPA Point of Comparison |                      | Relative to CEQA Baseline  |                      |
|---|-----------|------------------------------|--------------------------|-------------------------|------------------------------|-----------------------------|--------------------------------------|----------------------|----------------------------|----------------------|
|   |           |                              |                          |                         |                              |                             | Increased Energy Use (GWh)           | Percent Increase (%) | Increased Energy Use (GWh) | Percent Increase (%) |
| Existing Conditions <sup>b</sup>                  | 2010      | 0                            | 0                        | 0                       | 5,144                        | 7,716                       | -                                    | -                    | -                          | -                    |
| No Action Alternative <sup>c</sup>                | 2060      | 0                            | 0                        | 0                       | 4,441                        | 6,662                       | -                                    | -                    | -                          | -                    |
| Alternative 1A                                    | 2025      | 2,928                        | 308                      | 105                     | 5,914                        | 8,871                       | -                                    | -                    | 1,463                      | 19%                  |
| Pipeline/Tunnel-Variable energy factor            | 2060      | 2,704                        | 291                      | 108                     | 5,456                        | 8,184                       | 1,814                                | 27%                  | 759                        | 10%                  |
| Alternative 1B                                    | 2025      | 2,928                        | 190                      | 65                      | 5,914                        | 8,871                       | -                                    | -                    | 1,345                      | 17%                  |
| East Alignment-65 MWh/TAF                         | 2060      | 2,704                        | 176                      | 65                      | 5,456                        | 8,184                       | 1,699                                | 25%                  | 644                        | 8%                   |
| Alternative 1C                                    | 2025      | 2,928                        | 322                      | 110                     | 5,914                        | 8,871                       | -                                    | -                    | 1,477                      | 19%                  |
| West Alignment-110 MWh/TAF                        | 2060      | 2,704                        | 297                      | 110                     | 5,456                        | 8,184                       | 1,820                                | 27%                  | 765                        | 10%                  |
| Alternative 2A                                    | 2025      | 3,080                        | 341                      | 111                     | 5,389                        | 8,084                       | -                                    | -                    | 709                        | 9%                   |
| 15,000 cfs Pipeline/Tunnel-Variable energy factor | 2060      | 2,930                        | 328                      | 112                     | 5,068                        | 7,602                       | 1,269                                | 19%                  | 214                        | 3%                   |
| Alternative 2B                                    | 2025      | 3,080                        | 200                      | 65                      | 5,389                        | 8,084                       | -                                    | -                    | 568                        | 7%                   |
| East Alignment-65 MWh/TAF                         | 2060      | 2,930                        | 190                      | 65                      | 5,068                        | 7,602                       | 1,131                                | 17%                  | 76                         | 1%                   |
| Alternative 2C                                    | 2025      | 3,080                        | 339                      | 110                     | 5,389                        | 8,084                       | -                                    | -                    | 707                        | 9%                   |
| West Alignment-110 MWh/TAF                        | 2060      | 2,930                        | 322                      | 110                     | 5,068                        | 7,602                       | 1,263                                | 19%                  | 208                        | 3%                   |
| Alternative 3                                     | 2025      | 2,051                        | 134                      | 65                      | 5,818                        | 8,727                       | -                                    | -                    | 1,145                      | 15%                  |
| 6,000 cfs Pipeline/Tunnel-65 MWh/TAF              | 2060      | 1,864                        | 122                      | 65                      | 5,371                        | 8,057                       | 1,517                                | 23%                  | 463                        | 6%                   |
| Alternative 4 (Scenario H1)                       | 2025      | 2,674                        | 175                      | 65                      | 5,591                        | 8,387                       | -                                    | -                    | 846                        | 11%                  |
| 65 MWh/TAF  | 2060      | 2,463                        | 161                      | 65                      | 5,255                        | 7,883                       | 1,382                                | 21%                  | 328                        | 4%                   |
| Alternative 4 (Scenario H2)                       | 2025      | 2,353                        | 153                      | 65                      | 5,005                        | 7,508                       | -                                    | -                    | -56                        | -1%                  |
| 65 MWh/TAF  | 2060      | 2,149                        | 141                      | 65                      | 4,710                        | 7,065                       | 545                                  | 8%                   | -510                       | -7%                  |
| Alternative 4 (Scenario H3)                       | 2025      | 2,603                        | 170                      | 65                      | 5,265                        | 7,898                       | -                                    | -                    | 352                        | 5%                   |
| 65 MWh/TAF  | 2060      | 2,435                        | 157                      | 65                      | 4,945                        | 7,418                       | 913                                  | 14%                  | -142                       | -2%                  |

|   | Condition | North Delta Pumping (TAF/yr) | North Delta Energy (GWh) | Energy Factor (MWh/TAF) | Total Delta Pumping (TAF/yr) | South of Delta Energy (GWh) | Relative to NEPA Point of Comparison |                      | Relative to CEQA Baseline  |                      |
|---|-----------|------------------------------|--------------------------|-------------------------|------------------------------|-----------------------------|--------------------------------------|----------------------|----------------------------|----------------------|
|   |           |                              |                          |                         |                              |                             | Increased Energy Use (GWh)           | Percent Increase (%) | Increased Energy Use (GWh) | Percent Increase (%) |
| BDCP Alternative                                  |           |                              |                          |                         |                              |                             |                                      |                      |                            |                      |
| Alternative 4 (Scenario H4)                       | 2025      | 2,288                        | 150                      | 65                      | 4,705                        | 7,898                       | -                                    | -                    | -509                       | -7%                  |
| Large Diameter Pipeline/Tunnel-65 MWh/taf         | 2060      | 2,144                        | 140                      | 65                      | 4,414                        | 7,418                       | 100                                  | 1%                   | -955                       | -12%                 |
| Alternative 5                                     | 2025      | 1,278                        | 84                       | 65                      | 5,183                        | 7,775                       | -                                    | -                    | 143                        | 2%                   |
| 3,000 cfs Pipeline/Tunnel-65 MWh/TAF              | 2060      | 1,191                        | 78                       | 65                      | 4,786                        | 7,179                       | 596                                  | 9%                   | -459                       | -6%                  |
| Alternative 6A                                    | 2025      | 4,031                        | 466                      | 115                     | 4,031                        | 6,047                       | -                                    | -                    | -1,204                     | -16%                 |
| 15,000 cfs Pipeline/Tunnel-Variable energy factor | 2060      | 3,758                        | 421                      | 112                     | 3,759                        | 5,639                       | -602                                 | -9%                  | -1,657                     | -21%                 |
| Alternative 6B                                    | 2025      | 4,031                        | 262                      | 65                      | 4,031                        | 6,047                       | -                                    | -                    | -1,408                     | -18%                 |
| East Alignment-65 MWh/TAF                         | 2060      | 3,758                        | 244                      | 65                      | 3,759                        | 5,639                       | -779                                 | -12%                 | -1,834                     | -24%                 |
| Alternative 6C                                    | 2025      | 4,031                        | 443                      | 110                     | 4,031                        | 6,047                       | -                                    | -                    | -1,227                     | -16%                 |
| West Alignment-110 MWh/TAF                        | 2060      | 3,758                        | 413                      | 110                     | 3,759                        | 5,639                       | -610                                 | -9%                  | -1,665                     | -22%                 |
| Alternative 7                                     | 2025      | 2,502                        | 207                      | 83                      | 3,989                        | 5,984                       | -                                    | -                    | -1,526                     | -20%                 |
| 9,000 cfs Pipeline/Tunnel-Variable energy factor  | 2060      | 2,338                        | 193                      | 83                      | 3,754                        | 5,631                       | -838                                 | -13%                 | -1,892                     | -25%                 |
| Alternative 8                                     | 2025      | 2,326                        | 199                      | 86                      | 3,312                        | 4,968                       | -                                    | -                    | -2,549                     | -33%                 |
| 9,000 cfs Pipeline/Tunnel-Variable energy factor  | 2060      | 2,182                        | 185                      | 85                      | 3,098                        | 4,647                       | -1,830                               | -27%                 | -2,884                     | -37%                 |
| Alternative 9                                     | 2025      | 0                            | 18                       | 0                       | 4,629                        | 6,944                       | -                                    | -                    | -755                       | -10%                 |
| Through Delta/Separate Corridors                  | 2060      | 0                            | 18                       | 0                       | 4,377                        | 6,566                       | -78                                  | -1%                  | -1,133                     | -15%                 |

- Not used for energy comparison

<sup>a</sup> Energy calculations based on CALSIM-II represent a reasonable, though overstated, scenario based on historic monthly flows and reservoir storage.

<sup>b</sup> Installed SWP and CVP capacity in 2010.

<sup>c</sup> Future SWP and CVP capacity in 2060 independent of BDCP actions.

1 In the event that Delta water deliveries could not meet south of Delta water supply, alternative  
2 water sources for south of the Delta service areas could be accessed to supplement deliveries. New  
3 south of Delta surface water storage, groundwater pumping, and desalination plants could provide  
4 some of the necessary supplies and would create additional energy demands. While it is important  
5 to acknowledge this possibility, it is difficult to quantify and analyze the variety of supplemental  
6 water sources in a meaningful way. The uncertainty around additional water supplies would need to  
7 be addressed and analyzed on a case by case basis as they become feasible alternatives.

### 8 **21.3.3.1 No Action Alternative**

9 The No Action Alternative assumes continued energy generation and use at CVP and SWP facilities  
10 similar to those for recent operations (Existing Conditions) in the year 2060. Slight variances would  
11 be expected from the potential reoperation of reservoirs and energy generation facilities to  
12 accommodate changes in future precipitation and snowmelt runoff patterns and increased release  
13 flows in some months to improve habitat conditions in the rivers and tidal sloughs of the Plan Area.  
14 Additionally, RPMs under the 2008 and 2009 NMFS and USFWS Biological Opinions would  
15 potentially require changes to South Delta pumping.

16 The CALSIM-II simulation of No Action Alternative (2060) upstream reservoir operations and river  
17 flows was used to estimate the No Action energy generation at the upstream CVP and SWP facilities.  
18 The energy use for south of Delta pumping and delivery of water to CVP and SWP contractors was  
19 estimated from the CALSIM-II simulations of CVP and SWP pumping and deliveries for 1922–2003.

20 Tables 21-12a through 21-12f show the monthly and annual summary of CVP and SWP upstream  
21 energy generation and use for pumping and delivery to CVP and SWP contractors for the No Action  
22 Alternative. These tables were estimated from the monthly and annual pumping volumes (TAF) at  
23 each CVP and SWP pumping plant and the assumed pumping energy factors (MWh/TAF). For  
24 evaluation purposes, the average annual energy factor for SWP deliveries and the annual average  
25 energy factor for CVP deliveries were calculated and used to compare the energy needed for Delta  
26 exports.

27 Table 21-12a shows the monthly and annual cumulative distributions of CVP upstream energy  
28 generation (GWh) for the No Action Alternative. The average annual upstream CVP energy  
29 generation was 4,789 GWh for the No Action Alternative.

1 **Table 21-12a. Monthly and Annual Cumulative Distributions of Estimated Upstream CVP Energy**  
 2 **Generation (GWh) for the No Action Alternative**

|         | Oct | Nov | Dec | Jan   | Feb | Mar   | Apr | May | Jun   | Jul   | Aug | Sep | Annual |
|---------|-----|-----|-----|-------|-----|-------|-----|-----|-------|-------|-----|-----|--------|
| Minimum | 89  | 79  | 86  | 90    | 90  | 105   | 154 | 225 | 293   | 346   | 278 | 132 | 2,528  |
| 10%     | 196 | 134 | 120 | 139   | 123 | 143   | 239 | 293 | 384   | 523   | 405 | 224 | 3,111  |
| 20%     | 230 | 159 | 140 | 154   | 143 | 168   | 260 | 363 | 459   | 566   | 468 | 269 | 3,541  |
| 30%     | 239 | 183 | 152 | 161   | 152 | 186   | 292 | 408 | 474   | 602   | 506 | 308 | 3,889  |
| 40%     | 268 | 201 | 176 | 180   | 186 | 217   | 305 | 435 | 502   | 640   | 522 | 321 | 4,168  |
| 50%     | 286 | 225 | 184 | 209   | 199 | 241   | 325 | 458 | 528   | 663   | 543 | 364 | 4,682  |
| 60%     | 309 | 260 | 200 | 261   | 258 | 269   | 345 | 482 | 553   | 686   | 560 | 417 | 5,143  |
| 70%     | 333 | 285 | 246 | 367   | 386 | 375   | 378 | 508 | 565   | 712   | 574 | 536 | 5,407  |
| 80%     | 404 | 346 | 337 | 489   | 647 | 609   | 420 | 583 | 583   | 728   | 589 | 603 | 6,101  |
| 90%     | 451 | 411 | 662 | 714   | 700 | 760   | 565 | 692 | 604   | 755   | 645 | 656 | 6,647  |
| Maximum | 530 | 779 | 945 | 1,077 | 860 | 1,060 | 828 | 830 | 1,036 | 1,052 | 789 | 755 | 9,536  |
| Average | 302 | 256 | 270 | 322   | 329 | 349   | 360 | 475 | 523   | 652   | 536 | 416 | 4,789  |

3

4 Table 21-12b shows the monthly and annual cumulative distributions of CVP Jones pumping (TAF)  
 5 for the No Action Alternative.

6 **Table 21-12b. Monthly and Annual Cumulative Distributions of CALSIM-II-Simulated CVP Delta**  
 7 **Pumping (TAF) for the No Action Alternative**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 81  | 81  | 90  | 46  | 36  | 35  | 36  | 49  | 36  | 39  | 37  | 48  | 984    |
| 10%     | 149 | 131 | 181 | 122 | 70  | 57  | 48  | 49  | 48  | 129 | 130 | 146 | 1,525  |
| 20%     | 176 | 165 | 222 | 144 | 114 | 116 | 48  | 49  | 57  | 218 | 216 | 166 | 1,929  |
| 30%     | 190 | 198 | 239 | 165 | 130 | 138 | 48  | 49  | 92  | 247 | 283 | 207 | 2,126  |
| 40%     | 200 | 229 | 247 | 189 | 157 | 146 | 48  | 49  | 102 | 279 | 283 | 242 | 2,189  |
| 50%     | 216 | 243 | 262 | 200 | 175 | 162 | 51  | 49  | 138 | 280 | 283 | 273 | 2,301  |
| 60%     | 237 | 274 | 283 | 208 | 187 | 188 | 54  | 49  | 153 | 283 | 283 | 274 | 2,364  |
| 70%     | 257 | 274 | 283 | 211 | 205 | 216 | 58  | 55  | 168 | 283 | 292 | 274 | 2,458  |
| 80%     | 279 | 274 | 283 | 236 | 220 | 256 | 67  | 69  | 205 | 283 | 321 | 274 | 2,619  |
| 90%     | 283 | 340 | 283 | 272 | 255 | 283 | 96  | 103 | 274 | 283 | 330 | 281 | 2,769  |
| Maximum | 283 | 399 | 283 | 283 | 265 | 283 | 162 | 267 | 274 | 380 | 343 | 336 | 3,007  |
| Average | 218 | 236 | 249 | 192 | 166 | 171 | 62  | 68  | 140 | 244 | 260 | 233 | 2,237  |

8

9 Table 21-12c shows the monthly and annual cumulative distributions of CVP energy use (GWh) for  
 10 CVP water pumping at Jones and all other pumping plants along the Delta-Mendota Canal, including  
 11 pumping at O'Neill and Gianelli pumping plants to store water in San Luis Reservoir. The energy  
 12 generation at these generating plants was subtracted from the monthly CVP energy use values. The  
 13 average net energy factor for CVP exports was about 363 MWh/TAF, based on the average No Action  
 14 Alternative CVP Jones pumping of 2,237 TAF/yr and the average net CVP energy use of 814 GWh/yr.

1 **Table 21-12c. Monthly and Annual Cumulative Distributions of Estimated CVP Net Energy Use (GWh)**  
 2 **for Delta Export Pumping and Delivery for the No Action Alternative**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 12  | 28  | 41  | 21  | 11  | -1  | -17 | -31 | -25 | -16 | -16 | -25 | 277    |
| 10%     | 46  | 52  | 92  | 60  | 29  | 13  | -12 | -20 | -14 | 21  | 25  | 34  | 495    |
| 20%     | 55  | 68  | 113 | 74  | 47  | 44  | -8  | -16 | -4  | 55  | 60  | 53  | 695    |
| 30%     | 63  | 83  | 122 | 84  | 61  | 51  | -5  | -11 | 2   | 67  | 72  | 64  | 744    |
| 40%     | 68  | 101 | 128 | 96  | 73  | 55  | -3  | -9  | 5   | 73  | 79  | 81  | 774    |
| 50%     | 75  | 113 | 135 | 103 | 83  | 67  | -1  | -7  | 14  | 75  | 82  | 93  | 828    |
| 60%     | 83  | 125 | 142 | 107 | 89  | 85  | 3   | -4  | 27  | 80  | 87  | 94  | 856    |
| 70%     | 92  | 132 | 144 | 112 | 102 | 97  | 7   | -2  | 33  | 82  | 91  | 95  | 920    |
| 80%     | 102 | 135 | 146 | 125 | 116 | 125 | 12  | 4   | 58  | 85  | 103 | 96  | 979    |
| 90%     | 108 | 157 | 150 | 147 | 129 | 138 | 32  | 22  | 89  | 87  | 107 | 106 | 1,075  |
| Maximum | 147 | 186 | 161 | 169 | 150 | 157 | 66  | 112 | 99  | 127 | 111 | 126 | 1,275  |
| Average | 77  | 107 | 128 | 100 | 80  | 75  | 5   | -1  | 25  | 67  | 75  | 77  | 814    |

3

4 Table 21-12d shows the monthly and annual cumulative distributions of SWP upstream energy  
 5 generation (GWh) for the No Action Alternative. The average annual upstream SWP energy  
 6 generation was 2,292 GWh for the No Action Alternative.

7 **Table 21-12d. Monthly and Annual Cumulative Distributions of Estimated Upstream SWP Energy**  
 8 **Generation (GWh) for the No Action Alternative**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 26  | 20  | 21  | 19  | 20  | 19  | 47  | 54  | 109 | 40  | 40  | 33  | 721    |
| 10%     | 36  | 25  | 26  | 23  | 31  | 24  | 72  | 103 | 141 | 219 | 80  | 56  | 1,183  |
| 20%     | 41  | 33  | 42  | 28  | 40  | 39  | 92  | 118 | 155 | 295 | 143 | 75  | 1,447  |
| 30%     | 68  | 49  | 54  | 46  | 50  | 58  | 97  | 125 | 173 | 354 | 194 | 116 | 1,559  |
| 40%     | 89  | 55  | 56  | 55  | 54  | 73  | 105 | 127 | 190 | 395 | 261 | 148 | 1,815  |
| 50%     | 114 | 70  | 59  | 58  | 57  | 138 | 116 | 133 | 212 | 415 | 273 | 160 | 1,985  |
| 60%     | 131 | 82  | 92  | 59  | 103 | 201 | 126 | 139 | 234 | 424 | 300 | 255 | 2,470  |
| 70%     | 142 | 85  | 121 | 67  | 212 | 248 | 153 | 193 | 250 | 451 | 310 | 320 | 2,880  |
| 80%     | 156 | 89  | 156 | 199 | 379 | 357 | 226 | 329 | 271 | 471 | 325 | 376 | 3,337  |
| 90%     | 169 | 94  | 229 | 540 | 563 | 549 | 358 | 481 | 350 | 490 | 336 | 416 | 3,581  |
| Maximum | 223 | 561 | 670 | 669 | 623 | 671 | 666 | 698 | 569 | 508 | 377 | 441 | 4,777  |
| Average | 107 | 75  | 119 | 148 | 182 | 203 | 170 | 216 | 232 | 380 | 244 | 217 | 2,292  |

9

10 Table 21-12e shows the monthly and annual cumulative distributions of SWP Banks pumping (TAF)  
 11 for the No Action Alternative.

1 **Table 21-12e. Monthly and Annual Cumulative Distributions of CALSIM-II-Simulated SWP Delta Export**  
 2 **Pumping (TAF) for the No Action Alternative**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 59  | 18  | 81  | 18  | 21  | 18  | 18  | 18  | 18  | 18  | 18  | 55  | 896    |
| 10%     | 107 | 18  | 172 | 134 | 105 | 81  | 42  | 43  | 38  | 333 | 24  | 125 | 1,723  |
| 20%     | 136 | 18  | 228 | 151 | 138 | 140 | 42  | 43  | 58  | 375 | 295 | 202 | 2,154  |
| 30%     | 154 | 63  | 242 | 177 | 168 | 154 | 42  | 43  | 84  | 400 | 338 | 239 | 2,277  |
| 40%     | 167 | 107 | 257 | 189 | 185 | 179 | 48  | 43  | 95  | 408 | 347 | 268 | 2,424  |
| 50%     | 182 | 140 | 276 | 202 | 198 | 215 | 51  | 44  | 113 | 411 | 358 | 277 | 2,588  |
| 60%     | 197 | 172 | 348 | 208 | 217 | 248 | 55  | 50  | 150 | 411 | 393 | 296 | 2,811  |
| 70%     | 219 | 228 | 378 | 216 | 269 | 288 | 63  | 56  | 167 | 411 | 411 | 363 | 3,006  |
| 80%     | 253 | 319 | 431 | 241 | 328 | 376 | 71  | 69  | 223 | 411 | 411 | 394 | 3,272  |
| 90%     | 297 | 397 | 435 | 338 | 406 | 446 | 96  | 103 | 303 | 411 | 411 | 397 | 3,477  |
| Maximum | 411 | 397 | 472 | 523 | 472 | 465 | 364 | 380 | 397 | 411 | 411 | 397 | 4,433  |
| Average | 196 | 166 | 306 | 217 | 229 | 237 | 63  | 68  | 146 | 381 | 324 | 279 | 2,614  |

3

4 Table 21-12f shows the monthly and annual cumulative distributions of SWP net energy use for  
 5 SWP water pumping (GWh) at Banks and all other pumping plants along the California Aqueduct.  
 6 The energy generation at the SWP generating plants on the west and east branches of the aqueduct  
 7 in southern California (which recovers a fraction of the energy required to pump the water over the  
 8 Tehachapi Mountains) is subtracted from the monthly energy use values. The average net energy  
 9 factor for SWP exports was about 2,420 MWh/TAF, based on the average No Action Alternative SWP  
 10 Banks pumping of 2,614 TAF/yr and the average net SWP energy use of 6,327 GWh/yr.

11 **Table 21-12f. Monthly and Annual Cumulative Distributions of Estimated SWP Net Energy Use (GWh)**  
 12 **for Delta Export Pumping and Delivery for the No Action Alternative**

|         | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Annual |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Minimum | 124 | 77  | 113 | 46  | 88  | 120 | 151 | 53  | 42  | 272 | 32  | 155 | 2,290  |
| 10%     | 216 | 183 | 258 | 140 | 165 | 217 | 293 | 374 | 264 | 521 | 383 | 332 | 4,283  |
| 20%     | 396 | 344 | 350 | 154 | 215 | 294 | 417 | 461 | 317 | 671 | 654 | 552 | 5,145  |
| 30%     | 438 | 400 | 392 | 186 | 285 | 355 | 425 | 482 | 471 | 683 | 676 | 586 | 5,693  |
| 40%     | 459 | 441 | 464 | 217 | 389 | 408 | 438 | 496 | 507 | 699 | 693 | 618 | 6,115  |
| 50%     | 517 | 469 | 503 | 347 | 485 | 502 | 481 | 508 | 536 | 723 | 719 | 657 | 6,564  |
| 60%     | 544 | 483 | 535 | 431 | 592 | 658 | 503 | 538 | 562 | 746 | 737 | 671 | 6,955  |
| 70%     | 564 | 503 | 597 | 508 | 704 | 721 | 523 | 562 | 592 | 760 | 752 | 687 | 7,231  |
| 80%     | 603 | 532 | 626 | 716 | 751 | 813 | 547 | 576 | 637 | 788 | 780 | 710 | 7,638  |
| 90%     | 678 | 602 | 712 | 765 | 801 | 891 | 592 | 668 | 734 | 851 | 831 | 759 | 8,038  |
| Maximum | 903 | 782 | 896 | 933 | 888 | 960 | 837 | 881 | 853 | 890 | 891 | 858 | 9,930  |
| Average | 492 | 441 | 491 | 399 | 489 | 538 | 470 | 516 | 503 | 704 | 673 | 611 | 6,327  |

13

14 The average energy factor for combined CVP and SWP south of Delta pumping can be estimated as  
 15 the flow weighted average of the CVP and SWP energy factors. The average CVP pumping was 2,237  
 16 TAF/yr with an energy factor of 363 MWh/TAF. The average SWP pumping was 2,614 TAF/yr with  
 17 an energy factor of 2,420 MWh/TAF. The combined energy factor would be about 1.5 GWh/TAF.  
 18 Accordingly, the No Action Alternative would not increase the energy use factor (1.5 GWh/TAF) and  
 19 would not result in an adverse effect on energy resources.

## 1 **Climate Change and Catastrophic Seismic Risks**

2 The Delta and vicinity are within a highly active seismic area, with a generally high potential for  
 3 major future earthquake events along nearby and/or regional faults, and with the probability for  
 4 such events increasing over time. Based on the location, extent and non-engineered nature of many  
 5 existing levee structures in the Delta area, the potential for significant damage to, or failure of, these  
 6 structures during a major local seismic event is generally moderate to high. In the instance of a large  
 7 seismic event, levees constructed on liquefiable foundations are expected to experience large  
 8 deformations (in excess of 10 feet) under a moderate to large earthquake in the region. While there  
 9 are no set thresholds for salinity, bromide, or other contaminants at which the Banks and/or Jones  
 10 Pumping Plants would cease operations, an event that would alter the hydrology of the Delta such  
 11 that brackish water or seawater is drawn into the southwest portion of the Delta would likely result  
 12 in these pumps shutting down until freshwater flows can be reestablished and flush the brackish  
 13 water/seawater from the vicinity of these pumping plants' intakes. (See Appendix 3E, *Potential*  
 14 *Seismic and Climate Change Risks to SWP/CVP Water Supplies* for more detailed discussion)  
 15 Depending on the duration of the interruption, this could result in a substantial decrease in energy  
 16 use at the SWP and CVP Delta pumping plants. This decrease in energy use could be offset if south of  
 17 Delta water uses switch to alternative water supplies. To reclaim land or rebuild levees after a  
 18 catastrophic event due to climate change or a seismic event would create an increase in energy use  
 19 during construction.

20 **CEQA Conclusion:** The energy use factor (1.5 GWh/TAF) under the No Action Alternative and  
 21 Existing Conditions would be identical. Because the No Action Alternative would not increase the  
 22 energy use factor, it would not result in a significant impact on energy resources.

### 23 **21.3.3.2 Alternative 1A—Dual Conveyance with Pipeline/Tunnel and** 24 **Intakes 1–5 (15,000 cfs; Operational Scenario A)**

25 Alternative 1A includes a pumping capacity of 15,000 cfs at north Delta intakes and conveyance  
 26 through the tunnel. The maximum power requirements to operate the alternative would be about  
 27 182 MW for pumping (and associated equipment) to transport a maximum flow of 15,000 cfs from  
 28 the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The maximum north  
 29 Delta intakes and conveyance maximum energy factor for Alternative 1A is 145 MWh/TAF.

#### 30 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

31 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 32 construction period would be about 1,426 GWh. That is an average of 158 GWh/year, with a peak  
 33 use of 376 GWh occurring in year 6, concurrent with expected tunnel boring activity. As discussed in  
 34 Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.2, construction of the water conveyance  
 35 facilities associated with Alternative 1A includes all feasible control measures to improve equipment  
 36 efficiency and energy use. Although energy will be consumed as a result of construction activities,  
 37 BMPs will ensure that only high-efficiency equipment is utilized during construction. Construction  
 38 activities would therefore not result in the wasteful, inefficient or unnecessary consumption of  
 39 energy. Accordingly, there would be no adverse effect.

40 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 41 associated with Alternative 1A equate to 1,426 GWh over the 9-year construction period. As  
 42 discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.2, construction activities

1 include all feasible control measures to improve equipment efficiency and energy use. Construction  
 2 of the water conveyance facilities associated with Alternative 1A would therefore not result in the  
 3 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
 4 than significant and no mitigation is required.

### 5 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

6 **NEPA Effects:** The average north Delta intake pumping would be 2,928 TAF/yr under 2025  
 7 conditions and 2,704 TAF/yr under 2060 conditions. The energy use for north Delta intake pumping  
 8 was estimated to be 308 GWh/yr under 2025 conditions and 291 GWh/yr for LLT, which is greater  
 9 than the No Action Alternative (requires no pumping at the North Delta). However, operation of the  
 10 water conveyance facility would be managed to maximize efficient energy use, including off-peak  
 11 pumping and use of gravity. Accordingly, implementation of Alternative 1A would not result in a  
 12 wasteful or inefficient energy use. There would be no adverse effect.

13 **CEQA Conclusion:** Operation of Alternative 1A would require an additional 308 GWh/yr under 2025  
 14 conditions and 291 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 15 Conditions. However, operation of the water conveyance facility would be managed to maximize  
 16 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 17 Alternative 1A would not result in a wasteful or inefficient energy use. Accordingly, this impact  
 18 would be less than significant. No mitigation is required.

### 19 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 20 **with Plans and Policies**

21 **NEPA Effects:** Constructing the proposed water conveyance facilities (CM1) and implementing CM2–  
 22 CM22 could result in the potential for incompatibilities with plans and policies related to energy  
 23 resources. A number of plans and policies that coincide with the study area provide guidance for  
 24 energy resource issues as overviewed in *Section 21.2, Regulatory Setting*. This overview of plan and  
 25 policy compatibility evaluates whether Alternative 1A is compatible or incompatible with such  
 26 enactments, rather than whether impacts are adverse or not adverse or significant or less than  
 27 significant. If the incompatibility relates to an applicable plan, policy, or regulation adopted to avoid  
 28 or mitigate energy effects, then an incompatibility might be indicative of a related significant or  
 29 adverse effect under CEQA and NEPA, respectively. Such physical effects of Alternative 1A on energy  
 30 resources are addressed in Impacts ENG-1 and ENG-2. The following is a summary of compatibility  
 31 evaluations related to energy resources for plans and policies relevant to the BDCP. Note that as  
 32 discussed in Chapter 13, *Land Use*, Section 13.2.3, state and federal agencies are not generally  
 33 subject to local land use regulations; incompatibilities with plans and policies are not, by  
 34 themselves, physical consequences to the environment.

- 35 • The BDCP alternative would be constructed and operated in compliance with regulations related  
 36 to energy resources enforced by FERC and other federal agencies. The alternative would not  
 37 interfere or obstruct FERC Order No. 888 and Order No. 889, or CAISO Tariff Section 40.1.  
 38 Compatibility with other federal acts, including the Rivers and Harbors Appropriation Act of  
 39 1899, Section 10; the Rivers and Harbors Act of 1935; the Rivers and Harbors Act of 1937; the  
 40 Rivers and Harbors Act of 1940; the Auburn-Folsom South Unit Authorization Agreement; the  
 41 Emergency Relief Appropriation Act of 1935; the Flood Control Act of 1944; the Federal  
 42 Endangered Species Act; and the Central Valley Project Improvement Act (CVPIA) Section 3406

(b)(2) is discussed in Chapter 5, *Water Supply*; Chapter 11, *Fish and Aquatic Resources*; and Chapter 12, *Terrestrial Biological Resources*.

- The BDCP alternative will not conflict with the Warren-Alquist Act, which promotes energy efficiency throughout the state.
- The BDCP alternative is consistent with CEQA Guidelines, Appendix F, *Energy Conservation*.

**CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the consistency of the alternative with relevant plans and polices. The relationship between plans, policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land Use*, Section 13.2.3.

### 21.3.3.3 Alternative 1B—Dual Conveyance with East Alignment and Intakes 1–5 (15,000 cfs; Operational Scenario A)

Alternative 1B would require energy transmission and use for a pumping capacity of 15,000 cfs at north Delta intakes and conveyance through the east alignment canal. The maximum power requirements to operate the alternative would be about 82 MW for pumping to transport a maximum flow of 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The north Delta intakes and conveyance energy factor for Alternative 1B is 65 MWh/TAF.

#### Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities

**NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year construction period would be about 406 GWh. This is an average of 45 GWh/year, with a peak use of 83 GWh occurring in year 4. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.3, construction of the water conveyance facilities associated with Alternative 1B includes all feasible control measures to improve equipment efficiency and energy use. Although energy will be consumed as a result of construction activities, BMPs will ensure that only high-efficiency equipment is utilized during construction. Construction activities would therefore not result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse effect.

**CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities associated with Alternative 1B equate to 406 GWh over the 9-year construction period. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.3, construction activities include all feasible control measures to improve equipment efficiency and energy use. Construction of the water conveyance facilities associated with Alternative 1B would therefore not result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than significant and no mitigation is required.

#### Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance

**NEPA Effects:** As shown in Table 21-11 for Alternative 1B, the average north Delta intake pumping would be 2,928 TAF/yr under 2025 conditions and 2,704 TAF/yr under 2060 conditions. The energy use for north Delta intake pumping and east alignment conveyance was estimated to be 190 GWh/yr under 2025 conditions and 176 GWh/yr under 2060 conditions, which is greater than the No Action Alternative (requires no pumping at the North Delta). However, operation of the water

1 conveyance facility would be managed to maximize efficient energy use, including off-peak pumping  
 2 and use of gravity. Accordingly, implementation of Alternative 1B would not result in a wasteful or  
 3 inefficient energy use. There would be no adverse effect.

4 **CEQA Conclusion:** Operation of Alternative 1B would require an additional 190 GWh/yr under 2025  
 5 conditions and 176 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 6 Conditions. However, operation of the water conveyance facility would be managed to maximize  
 7 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 8 Alternative 1B would not result in a wasteful or inefficient energy use. Accordingly, this impact  
 9 would be less than significant. No mitigation is required.

### 10 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 11 **with Plans and Policies**

12 **NEPA Effects:** The potential for inconsistencies with plans or policies would be similar to the  
 13 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 1B  
 14 would be compatible with applicable plans and policies related to energy sources.

15 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 16 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 17 consistency of the alternative with relevant plans and policies. The relationship between plans,  
 18 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 19 *Use*, Section 13.2.3.

### 20 **21.3.3.4 Alternative 1C—Dual Conveyance with West Alignment and** 21 **Intakes W1–W5 (15,000 cfs; Operational Scenario A)**

22 Alternative 1C would require energy transmission and use for a pumping capacity of 15,000 cfs at  
 23 north Delta intakes and conveyance through the west alignment canal. The maximum power  
 24 requirements to operate the alternative would be about 138 MW for pumping to transport a  
 25 maximum flow of 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay  
 26 near Tracy. The north Delta intakes and conveyance energy factor for Alternative 1C is 110  
 27 MWh/TAF.

### 28 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

29 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 30 construction period would be about 791 GWh. That is an average of 88 GWh/year, with a peak use of  
 31 196 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
 32 22.3.3.4, construction of the water conveyance facilities associated with Alternative 1C includes all  
 33 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
 34 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
 35 equipment is utilized during construction. Construction activities would therefore not result in the  
 36 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
 37 effect.

38 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 39 associated with Alternative 1C equate to 791 GWh over the 9-year construction period. As discussed  
 40 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.4, construction activities include all  
 41 feasible control measures to improve equipment efficiency and energy use. Construction of the

1 water conveyance facilities associated with Alternative 1C would therefore not result in the  
 2 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
 3 than significant and no mitigation is required.

#### 4 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

5 **NEPA Effects:** As shown in Table 21-11 for Alternative 1C, the average north Delta intake pumping  
 6 would be 2,928 TAF/yr under 2025 conditions and 2,704 TAF/yr under 2060 conditions. The  
 7 energy use for north Delta intake pumping and west alignment conveyance was estimated to be 322  
 8 GWh/yr under 2025 conditions and 297 GWh/yr under 2060 conditions, which is greater than the  
 9 No Action Alternative (requires no pumping at the North Delta). However, operation of the water  
 10 conveyance facility would be managed to maximize efficient energy use, including off-peak pumping  
 11 and use of gravity. Accordingly, implementation of Alternative 1C would not result in a wasteful or  
 12 inefficient energy use. There would be no adverse effect. No mitigation is required.

13 **CEQA Conclusion:** Operation of Alternative 1C would require an additional 322 GWh/yr under 2025  
 14 conditions and 297 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 15 Conditions. However, operation of the water conveyance facility would be managed to maximize  
 16 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 17 Alternative 1C would not result in a wasteful or inefficient energy use. Accordingly, this impact  
 18 would be less than significant.

#### 19 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 20 **with Plans and Policies**

21 The potential for inconsistencies with plans or polices would be similar to the discussion in  
 22 Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 1C would be  
 23 compatible with applicable plans and policies related to energy sources.

24 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 25 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 26 consistency of the alternative with relevant plans and polices. The relationship between plans,  
 27 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 28 *Use*, Section 13.2.3.

### 29 **21.3.3.5 Alternative 2A—Dual Conveyance with Pipeline/Tunnel and Five** 30 **Intakes (15,000 cfs; Operational Scenario B)**

31 Alternative 2A would require energy transmission and use for a pumping capacity of 15,000 cfs at  
 32 north Delta intakes and conveyance through the tunnel. The maximum power requirements to  
 33 operate the alternative would be about 182 MW for pumping to transport a maximum flow of  
 34 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The  
 35 maximum north Delta intakes and conveyance energy factor for Alternative 2A is 145 MWh/TAF.

#### 36 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

37 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 38 construction period would be about 1,426 GWh. That is an average of 158 GWh/year, with a peak  
 39 use of 376 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*,  
 40 Section 22.3.3.5, construction of the water conveyance facilities associated with Alternative 2A

1 includes all feasible control measures to improve equipment efficiency and energy use. Although  
 2 energy will be consumed as a result of construction activities, BMPs will ensure that only high-  
 3 efficiency equipment is utilized during construction. Construction activities would therefore not  
 4 result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would  
 5 be no adverse effect.

6 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 7 associated with Alternative 2A equate to 1,426 GWh over the 9-year construction period. As  
 8 discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.5, construction activities  
 9 include all feasible control measures to improve equipment efficiency and energy use. Construction  
 10 of the water conveyance facilities associated with Alternative 2A would therefore not result in the  
 11 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
 12 than significant and no mitigation is required.

### 13 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

14 **NEPA Effects:** As shown in Table 21-11 for Alternative 2A, the average north Delta intake pumping  
 15 would be 3,080 TAF/yr under 2025 conditions and 2,930 TAF/yr under 2060 conditions. The  
 16 energy use for north Delta intake pumping and tunnel conveyance was estimated to be 341 GWh/yr  
 17 under 2025 conditions and 328 GWh/yr for LLT, which is greater than the No Action Alternative  
 18 (requires no pumping at the North Delta). However, operation of the water conveyance facility  
 19 would be managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
 20 Accordingly, implementation of Alternative 2A would not result in a wasteful or inefficient energy  
 21 use. There would be no adverse effect.

22 **CEQA Conclusion:** Operation of Alternative 2A would require an additional 524 GWh/yr under 2025  
 23 conditions and 498 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 24 Conditions. However, operation of the water conveyance facility would be managed to maximize  
 25 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 26 Alternative 2A would not result in a wasteful or inefficient energy use. Accordingly, this impact  
 27 would be less than significant. No mitigation is required.

### 28 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 29 **with Plans and Policies**

30 **NEPA Effects:** The potential for inconsistencies with plans or policies would be similar to the  
 31 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 2A  
 32 would be compatible with applicable plans and policies related to energy sources.

33 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 34 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 35 consistency of the alternative with relevant plans and policies. The relationship between plans,  
 36 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 37 *Use*, Section 13.2.3.

## 38 **21.3.3.6 Alternative 2B—Dual Conveyance with East Alignment and Five** 39 **Intakes (15,000 cfs; Operational Scenario B)**

40 Alternative 2B would require energy transmission and use for a pumping capacity of 15,000 cfs at  
 41 north Delta intakes and conveyance through the east alignment. The maximum power requirements

1 to operate the alternative would be about 82 MW for pumping to transport a maximum flow of  
2 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The  
3 north Delta intakes and conveyance energy factor for Alternative 2B is 65 MWh/TAF.

#### 4 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

5 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
6 construction period would be about 406 GWh. This is an average of 45 GWh/year, with a peak use of  
7 83 GWh occurring in year 4. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
8 22.3.3.6, construction of the water conveyance facilities associated with Alternative 2B includes all  
9 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
10 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
11 equipment is utilized during construction. Construction activities would therefore not result in the  
12 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
13 effect.

14 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
15 associated with Alternative 2B equate to 406 GWh over the 9-year construction period. As discussed  
16 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.6, construction activities include all  
17 feasible control measures to improve equipment efficiency and energy use. Construction of the  
18 water conveyance facilities associated with Alternative 2B would therefore not result in the  
19 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
20 than significant and no mitigation is required.

#### 21 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

22 **NEPA Effects:** As shown in Table 21-11 for Alternative 2B, the average north Delta intake pumping  
23 would be 3,080 TAF/yr under 2025 conditions and 2,930 TAF/yr under 2060 conditions. The  
24 energy use for north Delta intake pumping and east alignment conveyance was estimated to be 200  
25 GWh/yr under 2025 conditions and 190 GWh/yr for LLT, which is greater than the No Action  
26 Alternative (requires no pumping at the North Delta). However, operation of the water conveyance  
27 facility would be managed to maximize efficient energy use, including off-peak pumping and use of  
28 gravity. Accordingly, implementation of Alternative 2B would not result in a wasteful or inefficient  
29 energy use. There would be no adverse effect.

30 **CEQA Conclusion:** Operation of Alternative 2B would require an additional 200 GWh/yr under 2025  
31 conditions and 190 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
32 Conditions. However, operation of the water conveyance facility would be managed to maximize  
33 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
34 Alternative 2B would not result in a wasteful or inefficient energy use. Accordingly, this impact  
35 would be less than significant. No mitigation is required.

#### 36 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 37 **with Plans and Policies**

38 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
39 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 2B  
40 would be compatible with applicable plans and policies related to energy sources.

1 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 2 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 3 consistency of the alternative with relevant plans and polices. The relationship between plans,  
 4 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 5 *Use*, Section 13.2.3.

### 6 **21.3.3.7 Alternative 2C—Dual Conveyance with West Alignment and** 7 **Intakes W1–W5 (15,000 cfs; Operational Scenario B)**

8 Alternative 2C would require energy transmission and use for a pumping capacity of 15,000 cfs at  
 9 north Delta intakes and conveyance through the west alignment. The maximum power  
 10 requirements to operate the alternative would be about 138 MW for pumping to transport a  
 11 maximum flow of 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay  
 12 near Tracy. The north Delta intakes and conveyance energy factor for Alternative 2C is 110  
 13 MWh/TAF.

#### 14 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

15 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 16 construction period would be about 790 GWh. This is an average of 88 GWh/year, with a peak use of  
 17 196 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
 18 22.3.3.7, construction of the water conveyance facilities associated with Alternative 2C includes all  
 19 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
 20 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
 21 equipment is utilized during construction. Construction activities would therefore not result in the  
 22 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
 23 effect.

24 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 25 associated with Alternative 2C equate to 790 GWh over the 9-year construction period. As discussed  
 26 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.7, construction activities include all  
 27 feasible control measures to improve equipment efficiency and energy use. Construction of the  
 28 water conveyance facilities associated with Alternative 2C would therefore not result in the  
 29 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
 30 than significant and no mitigation is required.

#### 31 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

32 **NEPA Effects:** As shown in Table 21-11 for Alternative 2C, the average north Delta intake pumping  
 33 would be 3,080 TAF/yr under 2025 conditions and 2,930 TAF/yr under 2060 conditions. The  
 34 energy use for north Delta intake pumping and west alignment conveyance was estimated to be 339  
 35 GWh/yr under 2025 conditions and 322 GWh/yr for LLT, which is greater than the No Action  
 36 Alternative (requires no pumping at the North Delta). However, operation of the water conveyance  
 37 facility would be managed to maximize efficient energy use, including off-peak pumping and use of  
 38 gravity. Accordingly, implementation of Alternative 2C would not result in a wasteful or inefficient  
 39 energy use. There would be no adverse effect.

40 **CEQA Conclusion:** Operation of Alternative 2C would require an additional 339 GWh/yr under 2025  
 41 conditions and 322 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 42 Conditions. However, operation of the water conveyance facility would be managed to maximize

1 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 2 Alternative 2C would not result in a wasteful or inefficient energy use. Accordingly, this impact  
 3 would be less than significant. No mitigation is required.

#### 4 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 5 **with Plans and Policies**

6 **NEPA Effects:** The potential for inconsistencies with plans or policies would be similar to the  
 7 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 2C  
 8 would be compatible with applicable plans and policies related to energy sources.

9 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 10 in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
 11 consistency of the alternative with relevant plans and policies. The relationship between plans,  
 12 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 13 *Use*, Section 13.2.3.

#### 14 **21.3.3.8 Alternative 3—Dual Conveyance with Pipeline/Tunnel and** 15 **Intakes 1 and 2 (6,000 cfs; Operational Scenario A)**

16 Alternative 3 would require energy transmission and use for a pumping capacity of 6,000 cfs at  
 17 north Delta intakes and conveyance through the proposed tunnel. The maximum power  
 18 requirements to operate the alternative would be about 33 MW for pumping to transport a  
 19 maximum flow of 6,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay  
 20 near Tracy. The north Delta intakes and conveyance energy factor for Alternative 3 is 65 MWh/TAF.

#### 21 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

22 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 23 construction period would be about 1,320 GWh. This is an average of 147 GWh/year, with a peak  
 24 use of 361 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*,  
 25 Section 22.3.3.8, construction of the water conveyance facilities associated with Alternative 3  
 26 includes all feasible control measures to improve equipment efficiency and energy use. Although  
 27 energy will be consumed as a result of construction activities, BMPs will ensure that only high-  
 28 efficiency equipment is utilized during construction. Construction activities would therefore not  
 29 result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would  
 30 be no adverse effect.

31 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 32 associated with Alternative 3 equate to 1,320 GWh over the 9-year construction period. As discussed  
 33 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.8, construction activities include all  
 34 feasible control measures to improve equipment efficiency and energy use. Construction of the  
 35 water conveyance facilities associated with Alternative 3 would therefore not result in the wasteful,  
 36 inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than  
 37 significant and no mitigation is required.

#### 38 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

39 **NEPA Effects:** As shown in Table 21-11 for Alternative 3, the average north Delta intake pumping  
 40 would be 2,051 TAF/yr under 2025 conditions and 1,864 TAF/yr under 2060 conditions. The

1 energy use for north Delta intake pumping and tunnel conveyance was estimated to be 134 GWh/yr  
 2 under 2025 conditions and 122 GWh/yr for LLT, which is greater than the No Action Alternative  
 3 (requires no pumping at the North Delta). However, operation of the water conveyance facility  
 4 would be managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
 5 Accordingly, implementation of Alternative 3 would not result in a wasteful or inefficient energy use.  
 6 There would be no adverse effect.

7 **CEQA Conclusion:** Operation of Alternative 3 would require an additional 134 GWh/yr under 2025  
 8 conditions and 122 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
 9 Conditions. However, operation of the water conveyance facility would be managed to maximize  
 10 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
 11 Alternative 3 would not result in a wasteful or inefficient energy use. Accordingly, this impact would  
 12 be less than significant. No mitigation is required.

### 13 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 14 **with Plans and Policies**

15 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
 16 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 3  
 17 would be compatible with applicable plans and policies related to energy sources.

18 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 19 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 20 consistency of the alternative with relevant plans and polices. The relationship between plans,  
 21 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 22 *Use*, Section 13.2.3

### 23 **21.3.3.9 Alternative 4—Dual Conveyance with Modified Pipeline/Tunnel** 24 **and Intakes 2, 3, and 5 (9,000 cfs; Operational Scenario H)**

25 Alternative 4 would require energy transmission and use for a pumping capacity of 9,000 cfs at  
 26 north Delta intakes and conveyance through the tunnel. The maximum power requirements to  
 27 operate the alternative would be about 50 MW for pumping to transport a maximum flow of 9,000  
 28 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The north  
 29 Delta intakes and conveyance energy factor for Alternative 4 is 65 MWh/TAF.

#### 30 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

31 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 32 construction period would be about 2,549 GWh. This is an average of 283 GWh/year, with a peak  
 33 use of 483 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*,  
 34 Section 22.3.3.9, construction of the water conveyance facilities associated with Alternative 4  
 35 includes all feasible control measures to improve equipment efficiency and energy use. Although  
 36 energy will be consumed as a result of construction activities, BMPs will ensure that only high-  
 37 efficiency equipment is utilized during construction. Construction activities would therefore not  
 38 result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would  
 39 be no adverse effect.

40 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 41 associated with Alternative 4 would equate to 2,549 GWh over the 9-year construction period. As

discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.9, construction activities include all feasible control measures to improve equipment efficiency and energy use. Construction of the water conveyance facilities associated with Alternative 4 would therefore not result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than significant and no mitigation is required.

### **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

**NEPA Effects:** As shown in Table 21-11 for Alternative 4, the average north Delta intake pumping under Scenario H1 would be 2,674 TAF/yr under 2025 conditions and 2,463 TAF/yr under 2060 conditions. Under Scenario H4, average north Delta intake pumping would be 2,2883 TAF/yr under 2025 conditions and 2,144 TAF/yr under 2060 conditions. The energy use for north Delta intake pumping and tunnel conveyance was estimated to be 161 GWh/yr (2060 conditions) and 140 GWh/yr (2060 conditions) for Scenarios H1 and H4, respectively. These two scenarios reflect the range of effects that would result from the four potential outcomes under Alternative 4. While all scenarios would increase energy demand at the north delta, relative to the No Action Alternative, operation of the water conveyance facility would be managed to maximize efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of Alternative 4 would not result in a wasteful or inefficient energy use. There would be no adverse effect.

**CEQA Conclusion:** Operation of Alternative 4 under Scenario H1 would require an additional 175 GWh/yr under 2025 conditions and 161 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing Conditions. Operation of Alternative 4 under Scenario H4 would require an additional 150 GWh/yr under 2025 conditions and 140 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing Conditions. operation of the water conveyance facility would be managed to maximize efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of Alternative 4 would not result in a wasteful or inefficient energy use. Accordingly, this impact would be less than significant. No mitigation is required.

### **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22 with Plans and Policies**

**NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 4 would be compatible with applicable plans and policies related to energy sources.

**CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the consistency of the alternative with relevant plans and polices. The relationship between plans, policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land Use*, Section 13.2.3

#### **21.3.3.10 Alternative 5—Dual Conveyance with Pipeline/Tunnel and Intake 1 (3,000 cfs; Operational Scenario C)**

Alternative 5 would require energy transmission and use for a pumping capacity of 3,000 cfs at north Delta intakes and conveyance through the tunnel. The maximum power requirements to operate the alternative would be about 16 MW for pumping to transport a maximum flow of 3,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The north Delta intakes and conveyance energy factor for Alternative 5 is 65 MWh/TAF.

### 1 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

2 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
3 construction period would be about 731 GWh. This is an average of 81 GWh/year, with a peak use of  
4 197 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
5 22.3.3.10, construction of the water conveyance facilities associated with Alternative 5 includes all  
6 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
7 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
8 equipment is utilized during construction. Construction activities would therefore not result in the  
9 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
10 effect.

11 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
12 associated with Alternative 5 equate to 731 GWh over the 9-year construction period. As discussed  
13 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.10, construction activities include all  
14 feasible control measures to improve equipment efficiency and energy use. Construction of the  
15 water conveyance facilities associated with Alternative 5 would therefore not result in the wasteful,  
16 inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than  
17 significant and no mitigation is required.

### 18 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

19 **NEPA Effects:** As shown in Table 21-11 for Alternative 5, the average north Delta intake pumping  
20 would be 1,278 TAF/yr under 2025 conditions and 1,191 TAF/yr under 2060 conditions. The  
21 energy use for north Delta intake pumping and tunnel conveyance for Alternative 5 is estimated to  
22 be 84 GWh/yr under 2025 conditions and 78 GWh/yr for LLT, which is greater than the No Action  
23 Alternative (requires no pumping at the North Delta). However, operation of the water conveyance  
24 facility would be managed to maximize efficient energy use, including off-peak pumping and use of  
25 gravity. Accordingly, implementation of Alternative 5 would not result in a wasteful or inefficient  
26 energy use. There would be no adverse effect.

27 **CEQA Conclusion:** Operation of Alternative 5 would require an additional 84 GWh/yr under 2025  
28 conditions and 78 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
29 Conditions. However, operation of the water conveyance facility would be managed to maximize  
30 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
31 Alternative 5 would not result in a wasteful or inefficient energy use. Accordingly, this impact would  
32 be less than significant. No mitigation is required.

### 33 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 34 **with Plans and Policies**

35 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
36 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 5  
37 would be compatible with applicable plans and policies related to energy sources.

38 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
39 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
40 consistency of the alternative with relevant plans and polices. The relationship between plans,  
41 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
42 *Use*, Section 13.2.3

### 21.3.3.11 Alternative 6A—Isolated Conveyance with Pipeline/Tunnel and Intakes 1-5 (15,000 cfs; Operational Scenario D)

Alternative 6A would require energy transmission and use for a pumping capacity of 15,000 cfs at north Delta intakes and conveyance through the tunnel. The maximum power requirements to operate the alternative would be about 182 MW for pumping to transport a maximum flow of 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The maximum north Delta intakes and conveyance energy factor for Alternative 6A is 145 MWh/TAF.

#### Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities

**NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year construction period would be about 1,426 GWh. This is an average of 158 GWh/year, with a peak use of 376 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.11, construction of the water conveyance facilities associated with Alternative 6A includes all feasible control measures to improve equipment efficiency and energy use. Although energy will be consumed as a result of construction activities, BMPs will ensure that only high-efficiency equipment is utilized during construction. Construction activities would therefore not result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse effect.

**CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities associated with Alternative 6A equate to 1,426 GWh over the 9-year construction period. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.11, construction activities include all feasible control measures to improve equipment efficiency and energy use. Construction of the water conveyance facilities associated with Alternative 6A would therefore not result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than significant and no mitigation is required.

#### Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance

**NEPA Effects:** As shown in Table 21-11 for Alternative 6A, the average north Delta intake pumping would be 4,031 TAF/yr under 2025 conditions and 3,758 TAF/yr under 2060 conditions. The energy use for north Delta intake pumping and tunnel conveyance was estimated to be 466 GWh/yr under 2025 conditions and 421 GWh/yr for LLT, which is greater than the No Action Alternative (requires no pumping at the North Delta). However, operation of the water conveyance facility would be managed to maximize efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of Alternative 6A would not result in a wasteful or inefficient energy use. There would be no adverse effect.

**CEQA Conclusion:** Operation of Alternative 6A would require additional energy for north Delta pumping of 466 GWh/yr under 2025 conditions and 421 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing Conditions. However, operation of the water conveyance facility would be managed to maximize efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of Alternative 6A would not result in a wasteful or inefficient energy use. Accordingly, this impact would be less than significant. No mitigation is required.

1 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22**  
 2 **with Plans and Policies**

3 **NEPA Effects:** The potential for inconsistencies with plans or policies would be similar to the  
 4 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 6A  
 5 would be compatible with applicable plans and policies related to energy sources.

6 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 7 in impacts ENG-1 and ENG -2, above and no additional CEQA conclusion is required related to the  
 8 consistency of the alternative with relevant plans and policies. The relationship between plans,  
 9 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 10 *Use*, Section 13.2.3.

11 **21.3.3.12 Alternative 6B—Isolated Conveyance with East Alignment and**  
 12 **Intakes 1–5 (15,000 cfs; Operational Scenario D)**

13 Alternative 6B would require energy transmission and use for a pumping capacity of 15,000 cfs at  
 14 north Delta intakes and conveyance through the east alignment. The maximum power requirements  
 15 to operate the alternative would be about 820 MW for pumping to transport a maximum flow of  
 16 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The  
 17 north Delta intakes and conveyance energy factor for Alternative 6B is 65 MWh/TAF.

18 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

19 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
 20 construction period would be about 406 GWh. This is an average of 45 GWh/year, with a peak use of  
 21 83 GWh occurring in year 4. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
 22 22.3.3.12, construction of the water conveyance facilities associated with Alternative 6B includes all  
 23 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
 24 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
 25 equipment is utilized during construction. Construction activities would therefore not result in the  
 26 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
 27 effect.

28 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 29 associated with Alternative 6B equate to 406 GWh over the 9-year construction period. As discussed  
 30 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.12, construction activities include all  
 31 feasible control measures to improve equipment efficiency and energy use. Construction of the  
 32 water conveyance facilities associated with Alternative 6B would therefore not result in the  
 33 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
 34 than significant and no mitigation is required.

35 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

36 **NEPA Effects:** As shown in Table 21-11 for Alternative 6B, the average north Delta intake pumping  
 37 would be 4,031 TAF/yr under 2025 conditions and 3,758 TAF/yr under 2060 conditions. The  
 38 energy use for north Delta intake pumping and east alignment conveyance was estimated to be 262  
 39 GWh/yr under 2025 conditions and 244 GWh/yr for LLT, which is greater than the No Action  
 40 Alternative (requires no pumping at the North Delta). However, operation of the water conveyance  
 41 facility would be managed to maximize efficient energy use, including off-peak pumping and use of

1 gravity. Accordingly, implementation of Alternative 6B would not result in a wasteful or inefficient  
2 energy use. There would be no adverse effect.

3 **CEQA Conclusion:** Operation of Alternative 6B would require an additional 262 GWh/yr under 2025  
4 conditions and 244 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
5 Conditions. However, operation of the water conveyance facility would be managed to maximize  
6 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
7 Alternative 6B would not result in a wasteful or inefficient energy use. Accordingly, this impact  
8 would be less than significant. No mitigation is required.

9 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22**  
10 **with Plans and Policies**

11 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
12 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 6B  
13 would be compatible with applicable plans and policies related to energy sources.

14 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
15 in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
16 consistency of the alternative with relevant plans and polices. The relationship between plans,  
17 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
18 *Use*, Section 13.2.3.

19 **21.3.3.13 Alternative 6C—Isolated Conveyance with West Alignment and**  
20 **Intakes W1–W5 (15,000 cfs; Operational Scenario D)**

21 Alternative 6C would require energy transmission and use for a pumping capacity of 15,000 cfs at  
22 north Delta intakes and conveyance through the west alignment. The maximum power  
23 requirements to operate the alternative would be about 138 MW for pumping to transport a  
24 maximum flow of 15,000 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay  
25 near Tracy. The north Delta intakes and conveyance energy factor for Alternative 6C is 110  
26 MWh/TAF.

27 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

28 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
29 construction period would be about 790 GWh. This is an average of 88 GWh/year, with a peak use of  
30 196 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
31 22.3.3.13, construction of the water conveyance facilities associated with Alternative 6C includes all  
32 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
33 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
34 equipment is utilized during construction. Construction activities would therefore not result in the  
35 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
36 effect.

37 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
38 associated with Alternative 6C equate to 790 GWh over the 9-year construction period. As discussed  
39 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.13, construction activities include all  
40 feasible control measures to improve equipment efficiency and energy use. Construction of the  
41 water conveyance facilities associated with Alternative 6C would therefore not result in the

1 wasteful, inefficient or unnecessary consumption of energy. Accordingly, this impact would be less  
2 than significant and no mitigation is required.

### 3 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

4 **NEPA Effects:** As shown in Table 21-11 for Alternative 6C, the average north Delta intake pumping  
5 would be 4,031 TAF/yr under 2025 conditions and 3,758 TAF/yr under 2060 conditions. The  
6 energy use for north Delta intake pumping and west alignment conveyance was estimated to be 443  
7 GWh/yr under 2025 conditions and 413 GWh/yr for LLT, which is greater than the No Action  
8 Alternative (requires no pumping at the North Delta). However, operation of the water conveyance  
9 facility would be managed to maximize efficient energy use, including off-peak pumping and use of  
10 gravity. Accordingly, implementation of Alternative 6C would not result in a wasteful or inefficient  
11 energy use. There would be no adverse effect.

12 **CEQA Conclusion:** Operation of Alternative 6C require additional energy for north Delta pumping of  
13 443 GWh/yr under 2025 conditions and 413 GWh/yr under 2060 conditions for north Delta  
14 pumping, relative to Existing Conditions. However, operation of the water conveyance facility would  
15 be managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
16 Accordingly, implementation of Alternative 6C would not result in a wasteful or inefficient energy  
17 use. Accordingly, this impact would be less than significant. No mitigation is required.

### 18 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2-CM22** 19 **with Plans and Policies**

20 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
21 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 6C  
22 would be compatible with applicable plans and policies related to energy sources.

23 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
24 in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
25 consistency of the alternative with relevant plans and polices. The relationship between plans,  
26 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
27 *Use*, Section 13.2.3

#### 28 **21.3.3.14 Alternative 7—Dual Conveyance with Pipeline/Tunnel, Intakes 2,** 29 **3, and 5, and Enhanced Aquatic Conservation (9,000 cfs;** 30 **Operational Scenario E)**

31 Alternative 7 would require energy transmission and use for a pumping capacity of 9,000 cfs at  
32 north Delta intakes and conveyance through the tunnel. The maximum power requirements to  
33 operate the alternative would be about 80 MW for pumping to transport a maximum flow of 9,000  
34 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The  
35 maximum north Delta intakes and conveyance energy factor for Alternative 7 is 105 MWh/TAF.

### 36 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

37 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
38 construction period would be about 1,355 GWh. This is an average of 151 GWh/year, with a peak  
39 use of 366 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*,  
40 Section 22.3.3.14, construction of the water conveyance facilities associated with Alternative 7

1 includes all feasible control measures to improve equipment efficiency and energy use. Although  
2 energy will be consumed as a result of construction activities, BMPs will ensure that only high-  
3 efficiency equipment is utilized during construction. Construction activities would therefore not  
4 result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would  
5 be no adverse effect.

6 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
7 associated with Alternative 7 equate to 1,355 GWh over the 9-year construction period. As discussed  
8 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.14, construction activities include all  
9 feasible control measures to improve equipment efficiency and energy use. Construction of the  
10 water conveyance facilities associated with Alternative 7 would therefore not result in the wasteful,  
11 inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than  
12 significant and no mitigation is required.

### 13 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

14 **NEPA Effects:** As shown in Table 21-11 for Alternative 7, the average north Delta intake pumping  
15 was 2,502 TAF/yr under 2025 conditions and 2,338 TAF/yr under 2060 conditions. The energy use  
16 for north Delta intake pumping and tunnel conveyance was estimated to be 207 GWh/yr under 2025  
17 conditions and 193 GWh/yr for LLT, which is greater than the No Action Alternative (requires no  
18 pumping at the North Delta). However, operation of the water conveyance facility would be  
19 managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
20 Accordingly, implementation of Alternative 7 would not result in a wasteful or inefficient energy use.  
21 There would be no adverse effect.

22 **CEQA Conclusion:** Operation of Alternative 7 would require additional energy for north Delta  
23 pumping of 207 GWh/yr under 2025 conditions and 193 GWh/yr under 2060 conditions for north  
24 Delta pumping, relative to Existing Conditions. However, operation of the water conveyance facility  
25 would be managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
26 Accordingly, implementation of Alternative 7 would not result in a wasteful or inefficient energy use.  
27 Accordingly, this impact would be less than significant. No mitigation is required.

### 28 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2-CM22** 29 **with Plans and Policies**

30 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
31 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 7  
32 would be compatible with applicable plans and policies related to energy sources.

33 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed in  
34 impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
35 consistency of the alternative with relevant plans and polices. The relationship between plans,  
36 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
37 *Use*, Section 13.2.3.

1 **21.3.3.15 Alternative 8—Dual Conveyance with Pipeline/Tunnel, Intakes 2,**  
2 **3, and 5, and Increased Delta Outflow (9,000 cfs; Operational**  
3 **Scenario F)**

4 Alternative 8 would require energy transmission and use for a pumping capacity of 9,000 cfs at  
5 north Delta intakes and conveyance through the tunnel. The maximum power requirements to  
6 operate the alternative would be about 80 MW for pumping to transport a maximum flow of 9,000  
7 cfs from the Sacramento River near Hood to the SWP Clifton Court Forebay near Tracy. The  
8 maximum north Delta intakes and conveyance energy factor for Alternative 8 is 105 MWh/TAF.

9 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

10 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 9-year  
11 construction period would be about 1,355 GWh. This is an average of 151 GWh/year, with a peak  
12 use of 366 GWh occurring in year 6. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*,  
13 Section 22.3.3.15, construction of the water conveyance facilities associated with Alternative 8  
14 includes all feasible control measures to improve equipment efficiency and energy use. Although  
15 energy will be consumed as a result of construction activities, BMPs will ensure that only high-  
16 efficiency equipment is utilized during construction. Construction activities would therefore not  
17 result in the wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would  
18 be no adverse effect.

19 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
20 associated with Alternative 8 equate to 1,355 GWh over the 9-year construction period. As discussed  
21 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.15, construction activities include all  
22 feasible control measures to improve equipment efficiency and energy use. Construction of the  
23 water conveyance facilities associated with Alternative 8 would therefore not result in the wasteful,  
24 inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than  
25 significant and no mitigation is required.

26 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

27 **NEPA Effects:** As shown in Table 21-11 for Alternative 8, the average north Delta intake pumping  
28 was 2,326 TAF/yr under 2025 conditions and 2,182 TAF/yr under 2060 conditions for north Delta  
29 pumping, relative to Existing Conditions. However, operation of the water conveyance facility would  
30 be managed to maximize efficient energy use, including off-peak pumping and use of gravity.  
31 Accordingly, implementation of Alternative 8 would not result in a wasteful or inefficient energy use.  
32 Accordingly, there would be no adverse effect.

33 **CEQA Conclusion:** Operation of Alternative 8 would require an additional 199 GWh/yr under 2025  
34 conditions and 185 GWh/yr under 2060 conditions for north Delta pumping, relative to Existing  
35 Conditions. However, operation of the water conveyance facility would be managed to maximize  
36 efficient energy use, including off-peak pumping and use of gravity. Accordingly, implementation of  
37 Alternative 8 would not result in a wasteful or inefficient energy use. Accordingly, this impact would  
38 be less than significant. No mitigation is required.

1 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22**  
 2 **with Plans and Policies**

3 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
 4 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 8  
 5 would be compatible with applicable plans and policies related to energy sources.

6 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 7 in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
 8 consistency of the alternative with relevant plans and polices. The relationship between plans,  
 9 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 10 *Use*, Section 13.2.3.

11 **21.3.3.16 Alternative 9—Through Delta/Separate Corridors (15,000 cfs;**  
 12 **Operational Scenario G)**

13 This alternative would require very small additional energy use for south Delta circulation pumps  
 14 with a total capacity of 500 cfs. These circulation pumps would be used continuously. DWR has  
 15 estimated the electrical energy requirements for construction to be about one-half of the east  
 16 alignment construction energy. This estimate may be high relative to the size of the pumping  
 17 stations and other facilities required to construct the San Joaquin River separate corridor along Old  
 18 River, the fish screens at Delta Cross Channel and Georgiana Slough, and the tidal gates at Threemile  
 19 Slough. DWR has estimated the two pumping plants would require an electrical capacity of 2 MW.  
 20 The additional annual energy use would therefore be about 18 GWh.

21 **Impact ENG-1: Wasteful or Inefficient Energy Use for Temporary Construction Activities**

22 **NEPA Effects:** Table 21-9 indicates that the total construction energy use estimate for the 7-year  
 23 construction period would be about 186 GWh. This is an average of 27 GWh/year, with a peak use of  
 24 42 GWh occurring in year 4. As discussed in Chapter 22, *Air Quality and Greenhouse Gases*, Section  
 25 22.3.3.16, construction of the water conveyance facilities associated with Alternative 9 includes all  
 26 feasible control measures to improve equipment efficiency and energy use. Although energy will be  
 27 consumed as a result of construction activities, BMPs will ensure that only high-efficiency  
 28 equipment is utilized during construction. Construction activities would therefore not result in the  
 29 wasteful, inefficient or unnecessary consumption of energy. Accordingly, there would be no adverse  
 30 effect.

31 **CEQA Conclusion:** Energy requirements for construction of the water conveyance facilities  
 32 associated with Alternative 9 equate to 186 GWh over the 9-year construction period. As discussed  
 33 in Chapter 22, *Air Quality and Greenhouse Gases*, Section 22.3.3.16, construction activities include all  
 34 feasible control measures to improve equipment efficiency and energy use. Construction of the  
 35 water conveyance facilities associated with Alternative 9 would therefore not result in the wasteful,  
 36 inefficient or unnecessary consumption of energy. Accordingly, this impact would be less than  
 37 significant and no mitigation is required.

38 **Impact ENG-2: Wasteful or Inefficient Energy Use for Pumping and Conveyance**

39 **NEPA Effects:** The CALSIM-II simulated total exports for Alternative 9 were 4,629 TAF/yr under  
 40 2025 conditions and 4,377 TAF/yr under 2060 conditions. Table 21-11 shows that Alternative 9  
 41 annual energy use for circulation pumping would be about 18 GWh/yr. This small increase in energy

1 use, relative to the No Action Alternative (2060), would be managed to maximize efficient energy  
 2 use. Accordingly, implementation of Alternative 9 would not result in a wasteful or inefficient energy  
 3 use. There would be no adverse effect.

4 **CEQA Conclusion:** Operation of Alternative 9 would require an additional 18 GWh/yr under 2025  
 5 and 2060 conditions for circulation pumping in the south Delta. This small increase in energy use,  
 6 relative to Existing Conditions, would be managed to maximize efficient energy use. Accordingly,  
 7 implementation of Alternative 9 would not result in a wasteful or inefficient energy use. Accordingly,  
 8 this impact would be less than significant. No mitigation is required.

### 9 **Impact ENG-3: Compatibility of the Proposed Water Conveyance Facilities and CM2–CM22** 10 **with Plans and Policies**

11 **NEPA Effects:** The potential for inconsistencies with plans or polices would be similar to the  
 12 discussion in Alternative 1A, Impact ENG-3. Construction and implementation of Alternative 9  
 13 would be compatible with applicable plans and policies related to energy sources.

14 **CEQA Conclusion:** Physical effects associated with implementation of the alternative are discussed  
 15 in impacts ENG-1 and ENG-2, above and no additional CEQA conclusion is required related to the  
 16 consistency of the alternative with relevant plans and polices. The relationship between plans,  
 17 policies, and regulations and impacts on the physical environment is discussed in Chapter 13, *Land*  
 18 *Use*, Section 13.2.3.

### 19 **21.3.3.17 Cumulative Analysis**

20 This cumulative analysis considers other past, present and reasonably foreseeable future projects  
 21 that could affect the same resources during the same timeframe as the BDCP, resulting in a  
 22 cumulative energy effect. Energy use and local communities' demands for energy are expected to  
 23 increase as a result of reasonably foreseeable future projects related to population growth and  
 24 energy uses. It is expected that some changes related to energy use will take place although it is  
 25 assumed that all future projects would include design and construction practices to avoid or  
 26 minimize potential energy effects.

27 Cumulative effects of the BDCP alternatives on electrical energy generation and use within the three  
 28 regions of the BDCP are expected to change as a result of past, present, and reasonably foreseeable  
 29 future projects related to population growth and changes in economic activity in the three regions  
 30 (see Chapter 30, *Growth Inducement and Other Indirect Effects*, Section 30.3.2).

31 When the effects of the BDCP alternatives on increased energy use are considered in connection  
 32 with the potential effects of projects listed in Appendix 3D, *Defining Existing Conditions, the No*  
 33 *Action/No Project, and Cumulative Impacts Conditions*, the cumulative effects on energy use are  
 34 adverse because many of the other projects would also increase energy use in the three BDCP  
 35 regions. The specific programs, projects, and policies are identified below, based on the potential to  
 36 contribute to a BDCP energy impact that would be cumulatively considerable. The potential for  
 37 cumulative impacts on energy generation and use are described for BDCP operational effects on  
 38 energy use within the Delta and energy use in the South of Delta region of CVP and SWP water  
 39 deliveries related to CM1.

40 Table 21-13 summarizes foreseeable projects and programs that may affect energy resources. Only  
 41 those projects included in the cumulative analysis are listed.

1 **Table 21-13. Summary of Foreseeable Projects and Programs that May Affect Energy Resources**

| Agency  | Program/ Project                                       | Description of Program/Project  | Energy Effect   |
|---|--|---|---|
| DWR   | Oroville Facilities Relicensing                        | The objective of the relicensing process was to continue operation and maintenance of the Oroville Facilities for electric power generation, along with implementation of any terms and conditions to be considered for inclusion in a new FERC hydroelectric license   | May reduce energy generation or require additional energy |
| Freeport Regional Water Authority and U.S. Bureau of Reclamation                                      | Freeport Regional Water Project                        | Construction of a new water intake facility/pumping plant and 17-mile underground water pipeline within Sacramento County.  | Increased energy demand                                   |
| Davis, Woodland, and University of California, Davis  | Davis-Woodland Water Supply Project                    | Divert up to about 46,100 acre-feet per year of surface water from the Sacramento River and convey it for treatment and subsequent use in Davis and Woodland and on the University of California, Davis campus  | May reduce energy generation or require additional energy |
| Contra Costa Water District, U.S. Bureau of Reclamation, and California Department of Water Resources | Contra Costa Water District Alternate Intake Project   | Locate a new drinking water intake at Victoria Canal, about 2.5 miles east of Contra Costa Water District's (CCWD) existing intake on the Old River, which would allow CCWD to divert higher quality water when it is available   | Increased energy demand                                   |
| Contra Costa Water District and U.S. Bureau of Reclamation  | Los Vaqueros Reservoir Expansion Project               | Increase the reservoir capacity to 275,000 acre-feet and add a new 470 cfs connection that would allow the Los Vaqueros system to provide water to South Bay water agencies – Alameda County Flood Control and Water Conservation District, Zone 7, Alameda County Water District, and Santa Clara Valley Water District – that otherwise would receive all of their Delta supplies through the existing SWP and CVP export pumps | Increased energy demand                                   |
| U.S. Bureau of Reclamation and California State Water Resources Control Board                         | Battle Creek Salmon and Steelhead Restoration Project  | Restoration of Battle Creek will be accomplished primarily through the modification of the Battle Creek Hydroelectric Project (Federal Energy Regulatory Commission [FERC] Project No. 1121) facilities and operations, including instream flow releases. Facility changes include the removal of five diversion dams and construction of fish ladders and fish screens at three diversion dams.                                  | May reduce energy generation or require additional energy |
| U.S. Bureau of Reclamation and Tehama Colusa Canal Authority  | Red Bluff Diversion Dam Fish Passage Project           | Includes a new pumping plant and fish screen with a pumping capacity of 2,500 cubic feet per second (cfs). The initial installed pumping capacity will be 2,000 cfs.  | May reduce energy generation or require additional energy |
| U.S. Bureau of Reclamation  | Delta-Mendota Canal Intertie Pumping Plant             | Construction and operation of a pumping plant and pipeline connection between the Delta Mendota Canal (DMC) and the California Aqueduct. The Intertie would include a 450-cfs pumping plant at the DMC that would allow up to 400 cfs to be pumped from the DMC to the California Aqueduct via an underground pipeline. The additional 400 cfs would bring the Jones Pumping Plant to its authorized amount of 4,600 cfs.         | Increased energy demand                                   |
| Zone 7 Water Agency and Department of Water Resources   | South Bay Aqueduct Improvement and Enlargement Program | Increase the existing capacity of the water conveyance system up to its design capacity of 300 cfs, and expand capacity in a portion of the project to add 130 cfs (total of 430 cfs).  | Increased energy demand                                   |

1       **No Action Alternative**

2       The No Action Alternative is not anticipated to cumulatively effect energy resources in the study  
3       area. The combined energy factor for CVP and SWP pumping would be about 1.5 GWh/TAF. Slight  
4       variances would be expected from the potential reoperation of reservoirs and energy generation  
5       facilities to accommodate changes in future precipitation and water management. Ongoing and  
6       reasonably foreseeable future projects that use more energy may also affect regional energy use.  
7       However, the No Action Alternative would not create new demand that would cumulatively effect  
8       energy resources or the energy use factor for CVP and SWP south of Delta pumping.

9       The Delta and vicinity are within a highly active seismic area, with a generally high potential for  
10       major future earthquake events along nearby and/or regional faults, and with the probability for  
11       such events increasing over time. Based on the location, extent and non-engineered nature of many  
12       existing levee structures in the Delta area, the potential for significant damage to, or failure of, these  
13       structures during a major local seismic event is generally moderate to high. In the instance of a large  
14       seismic event, levees constructed on liquefiable foundations are expected to experience large  
15       deformations (in excess of 10 feet) under a moderate to large earthquake in the region. While there  
16       are no set thresholds for salinity, bromide, or other contaminants at which the Banks and/or Jones  
17       Pumping Plants would cease operations, an event that would alter the hydrology of the Delta such  
18       that brackish water or seawater is drawn into the southwest portion of the Delta would likely result  
19       in these pumps shutting down until freshwater flows can be reestablished and flush the brackish  
20       water/seawater from the vicinity of these pumping plants' intakes. (See Appendix 3E, *Potential*  
21       *Seismic and Climate Change Risks to SWP/CVP Water Supplies* for more detailed discussion)  
22       Depending on the duration of the interruption, this could result in a substantial decrease in energy  
23       use at the SWP and CVP Delta pumping plants. This decrease in energy use could be offset if south of  
24       Delta water uses switch to alternative water supplies. To reclaim land or rebuild levees after a  
25       catastrophic event due to climate change or a seismic event would create an increase in energy use  
26       during construction. While similar risks would occur under implementation of the action  
27       alternatives, these risks may be reduced by BDCP-related levee improvements along with those  
28       projects identified for the purposes of flood protection in Table 12-13.

29       **Impact ENG-4: Cumulative Impact on Energy Use for Operation of the BDCP Water Pumping**  
30       **and Conveyance Facilities In the Delta**

31       ***NEPA Effects: Alternatives 1A through 8***

32       For Alternatives 1A through 8, the construction and operation of north Delta intakes and a new  
33       Delta conveyance facility from the north Delta to the existing CVP and SWP pumping plants in the  
34       south Delta under CM1 would not result in adverse effects on energy use within the Delta region. As  
35       indicated in Table 21-11, the amount of energy use each year will depend on the hydrological  
36       conditions as well as the specific features of the alternative (i.e., pumping capacity and energy  
37       factor). Each of these BDCP alternatives would require an average annual increased energy use of  
38       between 18 GWh and 421 GWh, relative to the No Action Alternative (2060), for pumping and  
39       conveyance through the Delta. Because all of this electrical energy would be transmitted from  
40       existing or new generation facilities to the new pumping plants on the existing transmission grid,  
41       other projects that use more energy would contribute cumulatively to this effect on regional energy  
42       use (Table 21-13). However, the increase attributable to any alternative compared to statewide use  
43       (300,000 GWh) is not cumulatively considerable.

1 **CEQA Conclusion:** Each of these BDCP alternatives would require an annual increase energy use,  
2 relative to existing conditions. When combined with ongoing and reasonably foreseeable future  
3 projects, cumulative energy demand may affect regional resources. However, the increase  
4 attributable to any alternative compared to statewide use (300,000 GWh) is not cumulatively  
5 considerable. Accordingly, there is no cumulative effect on energy use from Alternatives 1A through  
6 8. This impact would be less-than-significant. No mitigation is required.

#### 7 **NEPA Effects: Alternative 9**

8 Alternative 9 would rely on the existing Delta channels (with some dredging) and tidal energy to  
9 transport water from the Sacramento River to the existing south Delta channels. Dredging for  
10 Alternative 9 would require considerable amounts of diesel fuel during the dredging period (2–3  
11 years), but not much electrical energy would be used. Although some new circulation pumps would  
12 be needed as part of the separation of the San Joaquin River corridor from the south Delta pumping  
13 plants to reduce fish entrainment, no substantial new energy use would be required. There would be  
14 no cumulative effect on energy use from Alternative 9.

15 **CEQA Conclusion:** Alternative 9 would rely on the existing Delta channels (with some dredging) and  
16 tidal energy to transport water from the Sacramento River to the existing south Delta channels.  
17 Although some new circulation pumps would be needed as part of the separation of the San Joaquin  
18 River corridor from the south Delta pumping plants to reduce fish entrainment, no substantial new  
19 energy use would be required. Accordingly, there is no cumulative effect on energy use within the  
20 Delta from Alternative 9. This impact would be less-than-significant. No mitigation is required.

#### 21 **Impact ENG-5: Cumulative Impact on Energy Use at Existing CVP and SWP Pumping Plants to** 22 **Deliver Additional Water Supplies**

#### 23 **NEPA Effects: Alternatives 1A through 5**

24 For Alternatives 1A through 5, the operations under CM1 would allow increased Delta exports and  
25 water supply delivery compared to the No Action Alternative (2060). Table 21-11 provides a  
26 comparative summary of the annual average energy use for additional pumping for increased water  
27 supply deliveries to CVP and SWP contractors. This increased pumping is less than the maximum  
28 monthly energy requirement planned and previously operated for CVP and SWP water supply  
29 deliveries. This increased energy use contributes to the cumulative effects on increased energy use  
30 in the South of Delta water supply region. Although this increased energy use at the existing CVP and  
31 SWP pumping plants was not considered a project impact on energy resources (the energy sources  
32 were planned and constructed as part of the CVP and SWP and therefore do not represent a *new*  
33 energy demand), this increased energy use would contribute to the cumulative energy use in this  
34 large portion of California. The high energy requirements of the SWP are well described and  
35 understood (California Energy Commission 2005; Natural Resources Defense Council 2004) and are  
36 a significant factor in the cumulative energy use of the south of Delta water supply region. However,  
37 the increase attributable to any alternative compared to statewide use (300,000 GWh) would not be  
38 cumulatively considerable.

39 **CEQA Conclusion:** Increased energy use for pumping of increased water deliveries to the South of  
40 Delta CVP and SWP water supply region could result in cumulative impacts on energy use within the  
41 water supply region. This cumulative impact is considered significant but the contribution from  
42 Alternatives 1A through 2C, and Alternatives 4 and 5 would not be cumulatively considerable  
43 because this energy use is within the planned maximum capacity for the CVP and SWP. Because this

1 energy use is part of the energy uses for existing facilities, the incremental impact from the BDCP  
 2 alternatives on cumulative energy use in the South of Delta region would be less-than-significant. No  
 3 mitigation is required.

#### 4 **NEPA Effects: Alternatives 6A through 9**

5 Alternatives 6A through 9 each would reduce somewhat the energy used to pump water from the  
 6 Delta to CVP and SWP contractors because these alternatives would reduce the annual average CVP  
 7 and SWP south of Delta water deliveries and reduce the average annual energy use, relative to the  
 8 No Action Alternative (2060), by about 100 GWh/yr to 1,800 GWh/yr, depending on the alternative,  
 9 (Table 21-11). These alternatives would reduce the cumulative effect on energy use in the CVP and  
 10 SWP South of Delta water supply region and the increase attributable to any alternative compared  
 11 to statewide use (300,000 GWh) would not be cumulatively considerable.

12 **CEQA Conclusion:** Alternatives 6A through 9 would provide somewhat less CVP and SWP water  
 13 supply deliveries and would reduce the cumulative energy use for pumping from the No Action  
 14 Alternative. There would be no cumulative energy impact in the South of Delta water supply region.  
 15 Accordingly, this impact would be less-than-significant. No mitigation is required.

## 16 **21.4 References**

### 17 **21.4.1 Printed References**

18 Bureau of Reclamation. 2009. *Glossary*. Available:

19 <<http://www.usbr.gov/projects/glossary.jsp#preference>>. Accessed: August 27, 2009.

20 Bureau of Reclamation. 2012. *Projects and Facilities Database*. Available:

21 <<http://www.usbr.gov/projects>>. Accessed: June 3, 2012.

22 California Department of Water Resources. 2006. *Draft Environmental Impact Statement for*

23 *Hydropower License, Oroville Facilities-FERC Project No. 2100*. Accessed August 21, 2009. URL =

24 [http://www.water.ca.gov/orovillerelicensing/docs/OFR/Draft%20Environmental%20Impact%](http://www.water.ca.gov/orovillerelicensing/docs/OFR/Draft%20Environmental%20Impact%20Statement.pdf)  
 25 [20Statement.pdf](http://www.water.ca.gov/orovillerelicensing/docs/OFR/Draft%20Environmental%20Impact%20Statement.pdf).

26 ———. 2009a. *Oroville Complex—Thermalito Facilities*. Available:

27 <<http://www.water.ca.gov/swp/facilities/Oroville/thermalito.cfm>>. Accessed: August 21, 2009.

28 ———. 2009b. *Oroville Facilities—Hyatt Powerplant*. Available:

29 <<http://www.water.ca.gov/swp/facilities/Oroville/OroFacilitiesComplex.cfm>>. Accessed:  
 30 August 21, 2009.

31 ———. 2010. *SWP Facilities in the South Bay Area*. Available: Available:

32 <<http://www.water.ca.gov/swp/facilities/southbay.cfm>>. Accessed: May 21 2010.

33 California Energy Commission. 2005. *California's Water-Energy Relationship*.

34 <[http://www.energy.ca.gov/2005publications/CEC-700-2005-011/CEC-700-2005-011-](http://www.energy.ca.gov/2005publications/CEC-700-2005-011/CEC-700-2005-011-SF.PDF)  
 35 [SF.PDF](http://www.energy.ca.gov/2005publications/CEC-700-2005-011/CEC-700-2005-011-SF.PDF)>

- 1 ———. 2009a. *2008 Net System Power Report*. July. Available:  
2 <[http://www.energy.ca.gov/2009publications/CEC-200-2009-010/CEC-200-2009-010-  
4 CMF.PDF](http://www.energy.ca.gov/2009publications/CEC-200-2009-010/CEC-200-2009-010-<br/>3 CMF.PDF)>. Accessed: June 3, 2010.
- 4 ———. 2009b. *Warren-Alquist Act*. Available: <[http://www.energy.ca.gov/reports/Warren-  
6 Alquist\\_Act/](http://www.energy.ca.gov/reports/Warren-<br/>5 Alquist_Act/)>. Accessed: August 25, 2009.
- 6 California Independent System Operator. 2009. *More Power to You, Understanding the Power Grid*.  
7 Brochure. Available: <<http://www.caiso.com/1bc3/1bc380bf45050.pdf>>. Accessed: August 21,  
8 2009.
- 9 California Public Utilities Commission. 2007. *California Public Utilities Commission*. Available:  
10 <<http://www.cpuc.ca.gov/puc/>>. Accessed: June 27, 2013.
- 11 Federal Energy Regulatory Commission. 2006. *About FERC. Strategic Plan*.  
12 Available: <<http://www.ferc.gov/about/strat-docs/strat-plan.asp>>. Accessed: August 24, 2009.
- 13 ———. 2009a. *Landmark Orders, Order No. 888*. Available: <[http://www.ferc.gov/legal/maj-ord-  
15 reg/land-docs/order888.asp](http://www.ferc.gov/legal/maj-ord-<br/>14 reg/land-docs/order888.asp)>. Accessed: August 25, 2009
- 15 ———. 2009b. *Order No. 889 Issued April 24, 1996*. Available: <[http://www.ferc.gov/legal/maj-ord-  
17 reg/land-docs/rm95-9-00k.txt](http://www.ferc.gov/legal/maj-ord-<br/>16 reg/land-docs/rm95-9-00k.txt)>. Accessed: August 24, 2009.
- 17 Natural Resources Defense Council. 2004. *Energy Down the Drain: The Hidden Cost of California's*  
18 *Water Supply*. Available:< <http://www.nrdc.org/water/conservation/edrain/contents.asp>>
- 19 Western Area Power Administration. 2009. *About Western*. Available:  
20 <<http://www.wapa.gov/about/default.htm>>. Accessed: August 24, 2009.